

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County:

Tillamook

Conventional or Direct Filtration

Month/Year:

Jun-25

System Name:		Netarts Water District			ID#: 41	00556	WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.025	0.030	0.027	0.026	0.025	0.025	0.067
2	0.025	0.025	0.027	0.024	0.049	0.026	0.078
3	0.025	0.024	0.021	0.025	0.031	0.024	0.037
4	0.024	0.024	0.024	0.030	0.046	0.024	0.129
5	0.025	0.024	0.028	0.023	0.034	0.024	0.041
6	0.024	0.031	0.028	0.023	0.024	0.024	0.065
7	0.024	0.024	0.024	0.027	0.025	0.025	0.111
8	0.025	0.024	0.026	0.027	0.024	0.023	0.040
9	0.027	0.027	0.023	0.026	0.026	0.024	0.045
10	0.027	0.024	0.026	0.026	0.031	0.027	0.037
11	0.030	0.025	0.025	0.025	0.027	0.027	0.049
12	0.026	0.025	0.025	0.042	0.031	0.021	0.057
13	0.021	0.024	0.027	0.024	0.023	0.025	0.067
14	0.023	0.023	0.023	0.027	0.025	0.024	0.038
15	0.025	0.023	0.024	0.027	0.026	0.026	0.153
16	0.041	0.030	0.036	0.034	0.029	0.040	0.147
17	0.051	0.039	0.040	0.024	0.025	0.025	0.212
18	0.026	0.027	0.107	0.112	0.113	0.027	0.123
19	0.025	0.024	0.026	0.024	0.024	0.025	0.060
20	0.025	0.025	0.080	0.101	0.064	0.104	0.122
21	0.051	0.032	0.035	0.330	0.268	0.217	0.381
22	0.177	0.170	0.163	0.128	0.114	0.122	0.239
23	0.124	0.120	0.090	0.045	0.038	0.046	0.123
24	0.048	0.035	0.036	0.029	0.034	0.030	0.075
25	0.038	0.029	0.045	0.027	0.031	0.029	0.089
26	0.042	0.027	0.027	0.031	0.034	0.030	0.243
27	0.029	0.027	0.029	0.026	0.029	0.027	0.080
28	0.036	0.026	0.032	0.030	0.027	0.036	0.098
29	0.027	0.026	0.035	0.056	0.087	0.029	0.099
30	0.027	0.026	0.029	0.098	0.024	0.020	0.098
31							

Conventional or Direct Filtration

95% of daily turbidity readings $\leq$ 0.3 NTU?

Yes/No

All daily turbidity readings $\leq$ 1 NTU?

Yes/No

All turbidity readings $<$ IFE² triggers

Yes/No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes/No

All Cl₂ residual at entry
point

Yes/No

Notes:

PRINTED NAME:

SIGNATURE:

DATE:

PHONE #: ()

CERT #:

Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns
12 AM through 8 PM may not

correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

503 842 9405

T-09183

D-09449

DAVID Hancock

David Hancock

7/1/25

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: Jun-25	Disinfection Giardia Log Reduction	0.5	
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	11:00	1.15	108	124.2	12.3	7.91	23.2	Yes	183
2	06:00	1.09	108	117.7	12.9	7.95	22.5	Yes	188
3	01:52	1.10	108	118.8	12.6	7.77	21.5	Yes	182
4	06:00	1.10	108	118.8	15.1	8.06	20.3	Yes	182
5	06:00	1.19	108	128.5	13.1	7.83	21.5	Yes	175
6	06:00	1.23	108	132.8	13.5	7.84	21.1	Yes	190
7	16:00	1.26	108	136.1	12.7	7.84	22.3	Yes	177
8	04:45	1.37	108	147.4	12.9	7.88	22.6	Yes	184
9	02:00	1.29	108	139.8	12.9	7.88	22.4	Yes	197
10	04:30	1.18	108	127.0	13.2	7.88	21.7	Yes	150
11	18:08	1.17	108	126.4	13.4	7.88	21.4	Yes	146
12	05:00	1.18	108	127.7	12.9	7.89	22.2	Yes	173
13	07:00	1.13	108	121.7	12.9	7.88	22.0	Yes	290
14	05:20	1.04	108	112.5	12.4	7.88	22.5	Yes	295
15	00:44	0.97	108	104.8	12.6	7.81	21.5	Yes	444
16	06:00	0.97	108	104.8	13.1	7.95	21.9	Yes	317
17	09:00	0.98	108	105.8	12.4	8.05	23.7	Yes	300
18	08:00	1.13	108	122.0	12.7	7.83	21.9	Yes	154
19	11:00	1.20	108	129.6	12.6	7.86	22.5	Yes	165
20	21:00	1.30	108	140.4	12.7	7.89	22.8	Yes	214
21	21:00	1.20	108	129.6	12.6	7.91	22.9	Yes	202
22	09:00	1.12	108	121.0	12.6	7.91	22.7	Yes	168
23	12:30	1.13	108	122.4	13.7	7.83	20.6	Yes	354
24	02:38	1.07	108	115.8	13.0	7.81	21.1	Yes	164
25	12:00	1.13	108	122.4	12.9	7.77	21.1	Yes	240
26	14:15	1.18	108	127.0	13.4	7.77	20.5	Yes	358
27	01:12	1.19	108	128.3	13.1	7.79	21.1	Yes	433
28	03:46	1.19	108	129.0	13.0	7.83	21.6	Yes	281
29	05:58	1.22	108	131.7	13.9	7.83	20.4	Yes	215
30	16:00	1.23	108	132.8	13.0	9.91	46.4	Yes	377
31			108	0.0			4.2		

† met, DWP to be notified by end of next business day.

Revised February 2012