

OHA - Drinking Water Program - Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: July 2025

System Name:	Netarts Water District			ID#: 41	00556	WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.023	0.026	0.026	0.051	0.029	0.025	0.146
2	0.023	0.023	0.031	0.070	0.024	0.023	0.070
3	0.026	0.025	0.023	0.030	0.030	0.030	0.106
4	0.020	0.020	0.020	0.020	0.020	0.020	0.069
5	0.020	0.030	0.020	0.040	0.030	0.020	0.065
6	0.040	0.030	0.040	0.043	0.040	0.029	0.131
7	0.102	0.056	0.050	0.032	0.029	0.025	0.130
8	0.023	0.029	0.025	0.021	0.023	0.025	0.156
9	0.024	0.032	0.030	0.027	0.032	0.027	0.148
10	0.032	0.032	0.029	0.023	0.023	0.023	0.048
11	0.025	0.025	0.023	0.023	0.023	0.032	0.098
12	0.024	0.024	0.024	0.025	0.026	0.025	0.141
13	0.023	0.023	0.023	0.026	0.025	0.023	0.038
14	0.024	0.023	0.026	0.084	0.029	0.024	0.113
15	0.024	0.027	0.023	0.031	0.023	0.026	0.109
16	0.023	0.021	0.029	0.023	0.023	0.031	0.860
17	0.020	0.024	0.034	0.031	0.023	0.023	0.095
18	0.023	0.024	0.025	0.250	0.200	0.230	0.069
19	0.024	0.024	0.027	0.023	0.024	0.030	0.085
20	0.023	0.024	0.021	0.023	0.027	0.023	0.053
21	0.023	0.025	0.029	0.025	0.026	0.023	0.074
22	0.027	0.025	0.025	0.023	0.023	0.035	0.233
23	0.024	0.023	0.024	0.024	0.025	0.129	0.155
24	0.027	0.025	0.026	0.025	0.027	0.024	0.060
25	0.023	0.025	0.026	0.024	0.024	0.023	0.108
26	0.030	0.024	0.031	0.024	0.024	0.025	0.123
27	0.023	0.023	0.038	0.025	0.024	0.024	0.069
28	0.021	0.021	0.040	0.043	0.041	0.021	0.084
29	0.023	0.052	0.026	0.021	0.021	0.029	0.063
30	0.024	0.021	0.023	0.023	0.025	0.025	0.048
31	0.027	0.021	0.030	0.025	0.021	0.023	0.074

Conventional or Direct Filtration95% of daily turbidity readings $\leq$ 0.3 NTU?Yes / NoAll daily turbidity readings $\leq$ 1 NTU?Yes / NoAll turbidity readings < IFE² triggersYes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)Yes / NoAll Cl₂ residual at entry
pointYes / No

Notes:

PRINTED NAME: DAVID HANCOCK

SIGNATURE:

DATE:

PHONE #: ()

CERT #:

Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns
12 AM through 8 PM may not

correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

David Hancock
T-09183
D-09449
503-842-9405

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Nefarts Water District		ID#: 41	00556	Month/Year: Jan-21	Disinfection Giardia Log Location	0.5	
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	09:00	1.18	108	127.4	13.3	10.51	56.3	Yes	179
2	21:00	1.14	108	123.1	13.2	10.96	66.5	Yes	266
1	08:00	1.13	108	122.0	13.3	8.27	24.7	Yes	271
4	08:00	1.26	108	136.1	13.3	8.01	22.8	Yes	360
5	08:00	1.26	108	136.1	13.1	7.98	22.9	Yes	450
6	09:00	1.35	108	146.2	13.2	8.06	23.6	Yes	286
7	21:00	0.99	108	106.9	13.3	8.05	22.5	Yes	279
8	11:00	0.98	108	105.8	13.2	8.04	22.5	Yes	216
9	21:00	1.16	108	125.3	13.4	8.03	22.6	Yes	232
10	09:00	1.16	108	125.3	13.5	8.01	22.3	Yes	177
11	21:00	1.16	108	125.3	13.5	7.98	22.0	Yes	276
12	21:00	1.15	108	124.2	13.5	7.98	22.0	Yes	262
13	10:30	1.14	108	123.0	13.9	7.96	21.2	Yes	235
14	17:30	1.01	108	109.2	14.5	7.96	20.1	Yes	268
15	22:00	1.05	108	113.8	14.3	7.93	20.2	Yes	217
16	05:32	1.09	108	117.7	14.3	7.91	20.2	Yes	259
17	03:23	1.09	108	117.7	14.1	7.93	20.6	Yes	204
18	06:46	1.09	108	117.7	14.5	7.93	20.1	Yes	317
19	05:32	1.09	108	117.7	14.0	7.98	21.2	Yes	406
20	21:00	1.07	108	115.6	13.9	7.98	21.2	Yes	237
21	21:00	1.07	108	115.6	13.9	8.00	21.4	Yes	284
22	21:00	1.02	108	110.2	13.8	8.00	21.4	Yes	267
23	21:00	1.02	108	110.2	13.9	8.01	21.3	Yes	229
24	21:00	1.18	108	127.4	14.0	8.01	21.6	Yes	232
25	21:00	1.16	108	125.3	14.0	8.00	21.5	Yes	252
26	10:00	1.20	108	129.6	14.0	8.01	21.6	Yes	243
27	11:58	1.18	108	127.2	14.1	8.01	21.5	Yes	249
28	04:26	1.26	108	135.6	13.9	8.06	28.0	Yes	269
29	21:36	1.14	108	123.0	14.1	8.05	21.7	Yes	226
30	02:58	1.10	108	119.1	14.5	8.06	21.2	Yes	244
31	01:34	1.07	108	115.8	14.2	8.06	21.4	Yes	246

if met, DWP to be notified by end of next business day.

Revised February 2012