

OHA - Drinking Water Program - Turbidity Monitoring Report Form

County:

Tillamook

Conventional or Direct Filtration

Month/Year:

Aug-25

System Name:	Netarts Water District			ID#: 41	00556	WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.024	0.024	0.029	0.021	0.023	0.036	0.107
2	0.021	0.023	0.023	0.023	0.024	0.023	0.103
3	0.025	0.023	0.023	0.023	0.024	0.025	0.108
4	0.025	0.023	0.023	0.025	0.024	0.025	0.086
5	0.025	0.023	0.025	0.025	0.023	0.025	0.217
6	0.024	0.082	0.080	0.153	0.144	0.166	0.311
7	0.133	0.126	0.125	0.080	0.030	0.030	0.210
8	0.030	0.030	0.030	0.026	0.025	0.022	0.032
9	0.038	0.026	0.026	0.025	0.030	0.032	0.062
10	0.025	0.024	0.027	0.148	0.026	0.024	0.086
11	0.025	0.027	0.030	0.034	0.043	0.038	0.199
12	0.025	0.035	0.030	0.023	0.025	0.035	0.278
13	0.041	0.035	0.046	0.023	0.025	0.035	0.260
14	0.025	0.025	0.024	0.025	0.029	0.021	0.081
15	0.024	0.025	0.026	0.101	0.095	0.090	0.117
16	0.089	0.087	0.087	P.O.	0.208	0.185	0.361
17	0.163	0.078	0.038	0.036	0.098	0.101	0.269
18	0.074	0.113	0.063	0.092	0.036	0.037	0.276
19	0.034	0.036	0.034	0.031	0.024	0.016	0.112
20	0.032	0.031	0.039	0.042	0.034	0.030	0.091
21	0.027	0.026	0.029	0.035	0.029	0.036	0.081
22	0.029	0.047	0.036	0.030	0.032	0.029	0.048
23	0.026	0.027	0.029	0.029	0.032	0.032	0.069
24	0.029	0.029	0.040	0.027	0.027	0.031	0.096
25	0.051	0.030	0.030	0.024	0.025	0.026	0.141
26	0.136	0.048	0.025	0.032	0.027	0.031	0.129
27	0.026	0.024	0.024	0.025	0.043	0.034	0.064
28	0.034	0.026	0.025	0.025	0.024	0.051	0.051
29	0.024	0.023	0.026	0.034	0.038	0.056	0.106
30	0.041	0.045	0.091	0.051	0.041	0.046	0.108
31	0.038	0.040	0.042	0.038	0.043	0.043	0.104

Conventional or Direct Filtration

95% of daily turbidity readings $\leq$ 0.3 NTU?

Yes / No

All daily turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry
point

Yes / No

Notes:

PRINTED NAME:

SIGNATURE:

DATE:

PHONE #: ()

CERT #:

Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns
12 AM through 8 PM may not

correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

DAVID B Hancock
David Hancock

503-842-9405

9/3/2025

T-09183

D-09449

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year:	Aug-25	Disinfection Giardia Log Reduction	0.5
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
Aug		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	06:00	1.04	108	112.3	14.3	8.06	21.2	Yes	244
2	01:00	1.02	108	110.2	14.3	8.05	21.1	Yes	245
3	23:22	1.00	108	108.0	14.3	8.08	21.3	Yes	250
4	15:30	1.01	108	109.1	14.5	8.00	20.4	Yes	277
5	09:07	1.08	108	116.6	14.5	8.00	20.6	Yes	238
6	12:57	0.88	108	95.0	14.2	7.96	20.2	Yes	240
7	21:00	0.82	108	88.6	14.1	7.95	20.1	Yes	379
8	21:10	1.24	108	133.9	14.9	7.96	20.1	Yes	394
9		1.46	108	157.7	14.1	7.96	21.7	Yes	319
10	09:30	1.18	108	127.4	14.3	7.93	20.5	Yes	328
11	05:48	1.19	108	128.5	14.3	7.93	20.6	Yes	325
12	01:06	1.14	108	123.1	14.6	7.84	19.4	Yes	266
13	04:30	1.07	108	115.6	14.7	7.84	19.1	Yes	260
14	00:24	1.00	108	107.9	14.9	7.89	19.1	Yes	300
15	22:00	0.95	108	102.6	14.9	7.89	19.0	Yes	248
16	18:20	0.94	108	101.5	15.3	7.91	18.6	Yes	279
17	02:41	0.90	108	97.2	14.6	8.05	20.4	Yes	276
18	07:00	0.87	108	94.0	14.5	8.30	22.4	Yes	270
19	07:00	0.86	108	92.9	14.6	8.03	20.2	Yes	278
20	07:00	0.91	108	98.3	14.5	7.93	19.7	Yes	308
21	07:00	0.94	108	101.5	14.3	8.03	20.7	Yes	286
22	07:00	0.95	108	102.6	14.3	7.95	20.2	Yes	275
23	08:00	1.34	108	144.7	14.5	7.95	20.8	Yes	271
24	23:00	1.32	108	142.6	14.6	7.88	20.0	Yes	287
25	06:30	0.98	108	105.8	14.9	7.96	19.5	Yes	259
26	04:52	0.81	108	87.4	14.5	7.95	19.6	Yes	254
27	03:54	0.65	108	70.3	14.5	7.91	19.0	Yes	250
28	03:00	0.64	108	69.1	14.2	7.91	19.3	Yes	244
29	10:26	0.71	108	76.9	14.1	7.93	19.8	Yes	288
30	06:14	0.94	108	102.0	14.0	7.95	20.6	Yes	266
31	00:40	0.95	108	102.6	14.9	7.95	19.3	Yes	273

† met, DWP to be notified by end of next business day.

Revised February 2012