

OHA - Drinking Water Program - Turbidity Monitoring Report Form

County:

Tillamook

Conventional or Direct Filtration

Month/Year:

Sep-25

System Name:

Netarts Water District

ID#: 41

00556

WTP: TP -

A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.057	0.029	0.034	0.023	0.031	0.031	0.254
2	0.063	0.057	0.034	0.034	0.027	0.026	0.150
3	0.023	0.023	0.024	0.025	0.029	0.029	0.191
4	0.029	0.024	0.024	0.031	0.027	0.037	0.063
5	0.026	0.025	0.025	0.025	0.032	0.025	0.156
6	0.031	0.031	0.030	0.045	0.032	0.030	0.074
7	0.032	0.027	0.031	0.025	0.027	0.029	0.067
8	0.025	0.026	0.024	0.034	0.031	0.024	0.118
9	0.024	0.025	0.052	0.030	0.030	0.026	0.103
10	0.025	0.025	0.024	0.027	0.023	0.021	0.120
11	0.023	0.023	0.023	0.026	0.026	0.025	0.057
12	0.023	0.023	0.025	0.025	0.023	0.023	0.063
13	0.024	0.024	0.024	0.026	0.023	0.023	0.244
14	0.040	0.217	0.238	PO	PO	P.O.	0.383
15	0.383	P.O.	0.294	0.053	0.040	0.042	0.389
16	0.037	0.034	0.036	0.031	0.036	0.045	0.074
17	0.030	0.027	0.029	0.027	0.045	0.030	0.075
18	0.031	0.030	0.034	0.035	0.052	0.045	0.098
19	0.038	0.036	0.029	0.031	0.035	0.029	0.070
20	0.029	0.027	0.027	0.047	0.032	0.027	0.065
21	0.026	0.026	0.035	0.096	0.126	0.112	0.258
22	0.098	0.104	0.117	0.049	0.042	0.031	0.117
23	0.029	0.030	0.036	0.027	0.030	0.029	0.097
24	0.026	0.026	0.026	0.042	0.032	0.035	0.053
25	0.031	0.039	0.034	0.020	0.026	0.024	0.039
26	0.030	0.030	0.036	0.024	0.024	0.023	0.046
27	0.024	0.025	0.026	0.024	0.023	0.024	0.054
28	0.025	0.024	0.027	0.027	0.029	0.026	0.086
29	0.032	0.030	0.206	0.202	0.141	0.234	0.293
30	0.276	0.238	0.234	0.108	0.129	0.115	0.276
31							

Conventional or Direct Filtration

95% of daily turbidity readings $\leq$ 0.3 NTU?

Yes / No

All daily turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings $<$ IFE² triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry
point

Yes / No

Notes:

PRINTED NAME:

SIGNATURE:

DATE:

PHONE #: ()

CERT #:

including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns
12 AM through 8 PM may not

correspond to continuous readings' maximum. ² IFE = Indiv. Filter Effl. (333-061-0040(1)(e)(B&C))

PAGE 1 of 2

DAVID Hancock
David Hancock
503 842 9905
10/1/2025 T- 09183
D- 09449

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: Sep-25	Disinfection Giardia Log Residual		0.5
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	07:00	0.94	108	101.5	13.9	10.36	49.9	Yes	273
2	07:00	0.96	108	103.7	14.0	10.07	44.7	Yes	255
3	07:00	1.09	108	117.7	14.2	8.03	21.2	Yes	267
4	07:00	1.39	108	150.1	14.2	8.06	22.2	Yes	254
5	07:00	1.55	108	167.4	14.1	8.20	24.0	Yes	272
6	07:00	1.45	108	156.6	14.2	8.10	22.7	Yes	270
7	05:30	0.85	108	92.0	14.1	8.05	20.9	Yes	263
8	02:05	0.95	108	102.6	14.1	7.98	20.7	Yes	262
9	00:20	0.92	108	99.3	14.6	7.96	19.7	Yes	251
10	17:26	1.10	108	119.1	14.5	8.00	20.7	Yes	260
11	09:40	1.12	108	120.4	14.1	8.01	21.3	Yes	240
12	08:00	1.07	108	115.1	13.9	8.03	21.6	Yes	264
13	02:48	0.97	108	105.2	14.0	8.03	21.2	Yes	272
14	07:00	0.82	108	88.6	14.0	8.03	20.9	Yes	248
15	07:00	0.79	108	85.3	13.9	8.03	20.9	Yes	371
16	07:00	0.78	108	84.2	13.9	7.98	20.5	Yes	245
17	07:00	1.08	108	116.6	14.1	7.98	21.0	Yes	279
18	07:00	1.16	108	125.3	13.9	8.01	21.7	Yes	267
19	07:00	1.27	108	137.2	13.7	8.01	22.2	Yes	273
20	07:00	1.12	108	121.0	13.7	8.01	21.9	Yes	244
21	00:40	0.85	108	92.0	13.4	7.95	21.2	Yes	242
22	17:00	0.99	108	106.9	14.2	7.81	19.4	Yes	266
23	00:08	1.07	108	115.8	13.5	7.81	20.4	Yes	258
24	03:00	1.09	108	117.9	13.4	7.81	20.6	Yes	245
25	00:06	1.10	108	119.1	13.4	7.81	20.7	Yes	248
26	20:00	1.19	108	128.3	13.5	7.88	21.3	Yes	260
27	04:20	1.31	108	141.5	13.3	7.89	22.0	Yes	253
28	07:00	1.31	108	141.5	13.2	7.91	22.3	Yes	234
29	08:00	1.08	108	116.6	13.2	7.89	21.5	Yes	195
30	08:00	0.97	108	104.8	13.2	7.89	21.3	Yes	156
31			108	0.0			4.2		

† met, DWP to be notified by end of next business day.

Revised February 2012