

OHA - Drinking Water Program - Turbidity Monitoring Report Form

County:

Tillamook

Conventional or Direct Filtration

Month/Year:

Oct-25

System Name:

Netarts Water District

ID#: 41

00556

WTP: TP -

A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.111	0.114	0.098	0.102	0.086	0.098	0.162
2	0.086	0.101	0.097	0.103	0.091	0.092	0.162
3	0.086	0.089	0.081	0.063	0.063	0.056	0.122
4	0.047	0.053	0.052	0.037	0.059	0.046	0.089
5	0.045	0.046	0.036	0.031	0.038	0.032	0.068
6	0.035	0.034	0.032	0.030	0.031	0.042	0.129
7	0.034	0.031	0.031	0.034	0.029	0.056	0.157
8	0.036	0.032	0.032	0.026	0.030	0.021	0.089
9	0.035	0.027	0.026	0.025	0.024	0.024	0.060
10	0.025	0.024	0.053	0.080	0.071	0.059	0.113
11	0.059	0.045	0.042	0.166	0.194	0.174	0.203
12	0.155	0.123	0.122	0.128	0.151	0.145	0.164
13	0.139	0.135	0.136	0.119	0.141	0.155	0.296
14	0.136	0.131	0.108	0.067	0.069	0.054	0.136
15	0.064	0.058	0.048	0.036	0.035	0.036	0.090
16	0.035	0.039	0.034	0.034	0.031	0.031	0.036
17	0.029	0.031	0.029	0.034	0.030	0.030	0.034
18	0.030	0.031	0.034	0.025	0.026	0.048	0.102
19	0.082	0.087	0.134	0.158	0.124	0.108	0.195
20	0.126	0.123	0.135	0.111	0.052	P.O.	0.150
21	P.O.	P.O.	P.O.	0.118	0.170	0.147	0.172
22	0.085	0.092	0.091	0.019	0.024	0.023	0.109
23	0.023	0.023	0.026	0.024	0.025	0.023	0.186
24	0.029	0.029	0.040	0.197	0.234	0.202	0.602
25	P.O.	PO	PO	0.250	0.207	0.174	0.569
26	0.142	0.135	0.129	P.O.	P.O.	0.216	0.250
27	0.179	0.169	0.141	0.202	0.185	0.177	0.255
28	0.210	0.183	0.148	0.151	0.153	0.152	0.219
29	0.155	0.155	0.217	0.218	0.163	0.147	0.249
30	0.141	0.145	0.147	0.097	0.161	0.032	0.214
31	0.035	0.034	0.034	0.035	0.025	0.025	0.103

Conventional or Direct Filtration

95% of daily turbidity readings $\leq$ 0.3 NTU?

Yes / No

All daily turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings $<$ IFE² triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry
point

Yes / No

Notes:

PRINTED NAME:

SIGNATURE:

DATE:

PHONE #: ()

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not

correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

DAVID HANCOCK
David Hancock 11/3/2025
 503-842-9405
 T-09183
 D-09449

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: Oct-25	Disinfection Giardia Log Reduction		0.5	
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]	
1	02:10	0.94	108	102.0	13.8	7.89	20.3	Yes	140	
2	11:07	0.94	108	101.3	13.1	7.76	20.3	Yes	143	
3	09:30	0.99	108	106.9	13.0	7.89	21.6	Yes	154	
4	03:45	1.06	108	114.5	13.1	7.93	21.9	Yes	183	
5	09:00	1.21	108	130.7	13.0	10.58	59.1	Yes	192	
6	11:00	1.42	108	153.4	13.0	10.78	65.1	Yes	166	
7	08:00	1.23	108	132.8	13.2	8.00	22.8	Yes	158	
8	10:00	1.19	108	128.5	12.9	7.96	22.8	Yes	147	
9	09:00	1.16	108	125.3	12.9	7.98	22.9	Yes	145	
10	15:00	1.04	108	112.3	12.8	8.15	24.2	Yes	165	
11	10:00	0.89	108	96.1	12.8	7.98	22.4	Yes	195	
12	15:00	0.81	108	87.4	13.0	7.93	21.4	Yes	187	
13	11:00	0.80	108	86.4	12.0	7.95	23.1	Yes	162	
14	08:00	0.99	108	106.9	11.8	8.12	25.4	Yes	148	
15	09:00	1.13	108	122.0	11.8	8.12	25.8	Yes	126	
16	11:00	1.16	108	125.3	11.6	8.12	26.2	Yes	135	
17	10:00	0.92	108	99.4	11.7	8.10	25.2	Yes	168	
18	09:00	0.82	108	88.6	11.5	8.06	24.9	Yes	159	
19	07:40	0.81	108	86.9	11.8	8.05	24.2	Yes	174	
20	12:00	0.77	108	83.5	12.1	8.05	23.7	Yes	153	
21	06:50	1.10	108	119.1	11.8	8.01	24.7	Yes	154	
22	02:48	1.25	108	134.9	11.8	7.93	24.4	Yes	142	
23	04:56	1.35	108	146.1	12.0	7.83	23.5	Yes	129	
24	20:00	1.25	108	134.9	12.1	7.84	23.1	Yes	130	
25	07:36	0.75	108	80.8	11.8	7.96	23.3	Yes	159	
26	09:00	0.70	108	75.6	11.5	8.17	25.5	Yes	161	
27	10:00	1.00	108	108.0	11.5	8.10	25.7	Yes	138	
28	09:00	0.96	108	103.7	11.9	8.32	27.0	Yes	134	
29	10:00	0.96	108	103.7	11.3	8.20	26.9	Yes	132	
30	10:00	0.91	108	98.3	11.2	8.17	26.6	Yes	136	
31	12:00	0.96	108	103.7	11.2	8.08	26.0	Yes	146	

If not met, DWP to be notified by end of next business day.

Revised February 2012