

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: Nov-25

System Name:	Netarts Water District			ID#: 41	00556		WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.025	0.025	0.025	P.O.	0.151	0.032	0.400
2	0.030	0.027	0.027	0.223	0.289	0.189	0.412
3	0.197	0.177	0.149	0.098	0.067	0.029	0.368
4	0.043	0.042	0.030	0.030	0.030	PO	0.102
5	PO	PO	PO	0.164	0.080	0.052	0.398
6	0.145	0.222	0.056	0.124	0.175	0.263	0.932
7	PO	PO	PO	0.126	0.120	0.123	0.156
8	0.124	0.128	0.137	0.031	0.031	0.027	0.245
9	0.026	0.026	0.025	0.059	0.096	0.100	0.280
10	0.096	0.102	0.107	0.091	0.080	0.069	0.127
11	0.071	0.058	0.058	0.041	0.034	0.027	0.186
12	0.025	0.031	0.078	0.060	0.057	0.074	0.206
13	0.031	0.029	0.034	0.026	0.024	0.144	0.103
14	0.037	0.100	0.078	0.192	0.168	0.175	0.146
15	0.156	0.169	0.146	0.129	0.115	0.124	0.210
16	0.129	0.151	0.139	0.117	0.124	0.057	0.361
17	0.041	0.042	0.049	0.048	0.045	0.052	0.199
18	0.040	0.052	0.032	0.043	0.043	0.045	0.133
19	0.043	0.042	0.041	0.047	0.043	0.045	0.140
20	0.046	0.035	0.084	0.067	0.095	0.029	0.125
21	0.046	0.035	0.084	0.067	0.095	0.029	0.297
22	0.257	0.045	0.030	0.042	0.034	0.045	0.273
23	0.026	0.043	0.029	0.063	0.069	0.042	0.207
24	0.046	0.031	0.076	0.042	0.192	0.082	0.192
25	0.136	0.036	0.049	0.041	0.046	0.026	0.212
26	0.038	0.045	P.O.	0.068	0.035	PO	0.282
27	PO	PO	PO	0.074	0.087	0.076	0.306
28	0.315	0.178	0.169	0.197	0.172	0.267	0.267
29	0.106	0.040	0.038	0.038	0.040	0.045	0.209
30	0.047	0.036	0.041	0.051	0.062	0.069	0.133
31							

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 0.3 NTU?	<u>Yes</u> / No	CT's met everyday? (see back)	All Cl2 residual at entry point
All daily turbidity readings ≤ 1 NTU?	<u>Yes</u> / No	<u>Yes</u> / No	<u>Yes</u> / No
All turbidity readings < IFE <sup>2</sup> triggers	<u>Yes</u> / No		
<b>Notes:</b>		<b>PRINTED NAME:</b>	
		<b>SIGNATURE:</b>	<b>DATE:</b>
		<b>PHONE #: ( )</b>	<b>CERT #:</b>

Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

DAVID HANCOCK T-09183  
 David Hancock 12/2/25 D 09449  
 503-842-9405

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A  
 Disinfection  
 Giardia Log  
 Location

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: Nov-25	WTP - : A		
Date	Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	10:00	0.98	108	105.8	11.5	8.20	26.6	Yes	163
2	05:34	1.19	108	129.0	11.5	8.54	30.9	Yes	171
3	04:12	1.15	108	124.3	11.3	9.52	44.5	Yes	151
4	11:58	1.30	108	140.2	11.4	9.81	50.3	Yes	371
5	03:40	1.19	108	129.0	11.6	7.48	20.9	Yes	136
6	13:06	1.18	108	127.7	11.7	7.52	21.1	Yes	157
7	08:00	1.10	108	119.1	11.5	7.74	23.0	Yes	179
8	07:15	1.09	108	117.7	11.5	7.74	22.9	Yes	184
9	11:00	1.10	108	118.8	11.5	7.76	23.1	Yes	198
10	09:00	0.96	108	103.7	11.5	7.60	21.5	Yes	179
11	08:00	0.91	108	98.3	11.3	9.59	44.4	Yes	177
12	10:00	1.24	108	133.9	11.5	10.31	59.6	Yes	153
13	09:00	1.18	108	127.4	11.5	8.39	29.2	Yes	160
14	10:00	1.13	108	122.0	11.6	8.46	29.5	Yes	158
15	11:00	0.94	108	101.5	11.6	8.46	28.9	Yes	179
16	10:00	0.86	108	93.3	11.6	8.27	26.7	Yes	198
17	01:38	0.83	108	90.1	11.2	8.03	25.1	Yes	159
18	06:18	0.91	108	98.6	10.8	8.05	26.2	Yes	188
19	04:45	1.01	108	108.5	10.8	7.76	23.8	Yes	134
20	19:54	1.10	108	118.8	10.8	7.76	23.0	Yes	142
21	19:28	1.26	108	136.1	10.7	7.77	24.9	Yes	167
22	12:00	1.32	108	142.6	10.8	7.88	25.9	Yes	194
23	08:00	1.29	108	139.3	10.5	7.91	26.6	Yes	194
24	18:00	1.02	108	110.2	10.5	8.24	29.0	Yes	162
25	08:00	0.84	108	90.7	10.3	8.27	29.1	Yes	171
26	23:30	0.77	108	83.2	10.4	8.13	27.3	Yes	227
27	23:00	0.72	108	78.2	10.4	8.10	26.8	Yes	213
28	10:00	0.99	108	106.9	10.6	8.25	28.8	Yes	219
29	09:00	1.41	108	152.3	10.5	8.05	28.3	Yes	209
30	08:00	1.09	108	117.7	10.4	7.81	25.3	Yes	209
31			108	0.0			4.2		

if met, DWP to be notified by end of next business day.

Revised February 2012