

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook

Conventional or Direct Filtration

Month/Year: Dec-25

System Name: Netarts Water District ID#: 41 00556 WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.056	0.048	0.082	0.073	0.052	0.069	0.161
2	0.069	0.064	0.086	0.038	0.046	0.049	0.103
3	0.038	0.052	0.043	0.075	0.062	0.058	0.120
4	0.086	0.037	0.053	0.059	0.068	0.067	0.829
5	0.152	0.144	po	P.O.	0.040	0.048	0.630
6	0.059	0.079	0.042	0.031	0.151	0.175	0.626
7	0.152	0.155	0.201	0.019	0.200	0.169	0.246
8	0.051	0.158	0.129	P.O.	0.299	0.040	0.349
9	0.070	0.266	0.368	0.150	0.246	0.043	0.469
10	0.023	0.023	0.068	0.234	0.243	0.202	0.269
11	0.085	0.225	0.249	0.272	0.228	0.027	0.637
12	0.032	0.031	0.036	0.035	0.063	0.070	0.128
13	0.032	0.031	0.031	0.091	0.090	0.096	0.180
14	0.093	0.095	0.103	0.060	0.023	0.031	0.257
15	0.060	0.030	0.076	0.070	0.070	0.036	0.196
16	0.045	0.035	0.062	0.073	0.065	0.036	0.174
17	0.036	0.034	0.046	0.096	0.115	PO	0.631
18	PO	PO	0.036	0.124	0.186	0.272	0.669
19	PO	0.128	0.034	0.032	0.024	0.025	0.229
20	0.027	0.030	0.037	0.027	0.045	0.034	0.241
21	0.026	0.025	0.026	0.025	0.029	0.024	0.317
22	0.023	0.024	0.027	0.034	0.058	0.062	0.190
23	0.027	0.070	0.036	0.057	0.031	0.053	0.202
24	0.029	0.057	0.082	0.056	0.054	0.059	0.196
25	PO	0.053	0.032	0.046	0.036	0.058	0.153
26	0.053	0.049	0.032	0.069	0.031	0.063	0.195
27	0.059	0.034	0.040	0.054	0.047	0.046	0.130
28	0.032	0.064	0.043	0.062	0.060	0.124	0.118
29	0.107	0.037	0.034	0.041	0.041	0.049	0.136
30	0.060	0.031	0.058	0.049	0.049	0.059	0.138
31	0.054	0.051	0.056	0.065	0.056	0.048	0.133

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 0.3 NTU?	<u>Yes</u> /No	CT's met everyday? (see back)	All Cl2 residual at entry point
All daily turbidity readings ≤ 1 NTU?	<u>Yes</u> /No	<u>Yes</u> /No	<u>Yes</u> /No
All turbidity readings < IFE <sup>2</sup> triggers	<u>Yes</u> /No	<b>PRINTED NAME:</b>	
<b>Notes:</b>	<b>SIGNATURE:</b>		<b>DATE:</b>
	<b>PHONE #: ( )</b>		<b>CERT #:</b>

Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns

12 AM through 8 PM may not

correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

David Hancock  
 David Hancock 1/2/26  
 T-09183  
 D-09449

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A  
 Disinfection  
 Giardia Log  
 Negative  
 0.5

System Name:		Netarts Water District		ID#: 41	00556	Month/Year:	Dec-25		
Date	Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	06:28	1.02	108	110.5	10.2	7.71	24.4	Yes	158
2	14:24	1.02	108	109.8	10.4	8.08	27.5	Yes	153
3	00:06	1.34	108	144.8	10.1	7.67	25.3	Yes	149
4	05:46	1.25	108	134.9	10.2	7.77	25.6	Yes	152
5	23:40	1.23	108	132.9	10.6	8.18	28.9	Yes	163
6	05:34	1.12	108	120.4	10.8	7.45	21.7	Yes	176
7	09:00	1.10	108	118.8	10.8	7.96	26.0	Yes	207
8	10:00	1.15	108	124.2	11.0	8.38	29.9	Yes	171
9	08:00	1.09	108	117.7	11.3	8.48	30.2	Yes	267
10	09:00	0.89	108	96.1	11.4	8.37	28.2	Yes	162
11	10:00	0.92	108	99.4	11.6	7.89	23.5	Yes	166
12	17:00	0.93	108	100.4	11.5	7.89	23.7	Yes	165
13	10:00	0.68	108	73.4	11.3	8.78	32.1	Yes	180
14	02:36	1.18	108	127.0	11.5	8.68	32.3	Yes	195
15	15:40	1.34	108	144.8	11.6	7.84	24.2	Yes	170
16	06:42	1.26	108	136.2	11.3	7.77	23.8	Yes	220
17	16:00	1.23	108	132.9	11.5	7.83	24.0	Yes	162
18	04:10	1.47	108	158.7	11.0	7.52	22.9	Yes	158
19	04:24	1.46	108	158.0	10.9	7.52	22.9	Yes	175
20	06:36	1.30	108	140.2	10.7	7.47	22.4	Yes	185
21	11:00	1.24	108	133.9	10.7	7.89	25.9	Yes	185
22	10:00	1.27	108	137.2	10.5	8.25	30.0	Yes	173
23	08:00	1.25	108	135.0	10.4	8.01	27.6	Yes	181
24	09:00	1.24	108	133.9	10.2	7.70	25.0	Yes	177
25	10:00	1.23	108	132.8	10.4	7.79	25.5	Yes	182
26	10:00	1.23	108	132.8	10.1	7.67	24.9	Yes	187
27	10:00	1.30	108	140.4	10.0	7.67	25.3	Yes	189
28	06:00	1.25	108	134.9	9.7	7.91	27.8	Yes	209
29	04:00	1.09	108	117.7	9.7	8.36	32.2	Yes	210
30	05:46	1.20	108	129.6	9.6	9.36	47.5	Yes	236
31	08:00	1.04	108	111.8	9.9	9.68	51.6	Yes	204

<sup>3</sup> met, DWP to be notified by end of next business day.

Revised February 2012