

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Tillamook
 Month/Year: January 2026

Conventional or Direct Filtration

System Name:	Netarts Water District			ID#: 41	00556		WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.029	0.054	0.043	0.065	0.056	0.048	0.142
2	0.029	0.054	0.093	0.096	0.025	0.073	0.246
3	0.067	0.029	0.064	0.069	0.048	0.057	0.260
4	0.027	0.117	0.162	0.122	0.133	0.185	0.232
5	0.175	0.152	0.137	0.102	0.093	0.091	0.205
6	0.089	0.092		0.101	0.258	0.702	0.784
7	0.147	0.109	0.106	0.107	0.087	0.089	0.318
8	0.100	0.085	0.076	0.102	0.128	0.113	0.279
9	0.177	0.097	0.076	0.103	0.093	0.089	0.146
10	0.097	0.091	0.080	0.090	0.071	0.092	0.130
11	0.089	0.079	0.084	0.115	0.089	0.087	0.300
12	0.074	0.086	0.092	0.082	0.084	0.081	0.114
13	0.091	0.093	0.076	0.068	0.064	0.071	0.277
14	0.048	0.019	0.059	0.023	0.084	0.036	0.093
15	0.032	0.048	0.063	0.036	0.060	0.042	0.093
16	0.027	0.042	0.047	0.038	0.056	0.015	0.092
17	0.047	0.014	0.051	0.049	0.013	0.040	0.085
18	0.046	0.013	0.045	0.042	0.046	0.052	0.148
19	0.049	0.016	0.049	0.020	0.049	0.045	0.092
20	0.015	0.042	0.048	0.045	0.058	0.019	0.082
21	0.041	0.013	0.043	0.041	0.046	0.042	0.086
22	0.012	0.045	0.044	0.013	0.042	0.012	0.067
23	0.031	0.049	0.046	0.041	0.038	0.078	0.080
24	0.041	0.016	0.013	0.014	0.014	0.012	0.049
25	0.014	0.013	0.057	0.016	0.012	0.012	0.060
26	0.023	0.021	0.013	0.026	0.013	0.029	0.104
27	0.047	0.014	0.040	0.040	0.037	0.041	0.080
28	0.025	0.090	0.078	0.064	0.078	0.030	0.103
29	0.054	0.087	0.107	0.038	0.103	0.058	0.135
30	0.038	0.045	0.016	0.082	0.152	0.059	0.210
31	0.063	0.025	0.075	0.080	0.083	0.152	0.218

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	<u>Yes</u> /No	CT's met everyday? (see back)	All Cl2 residual at entry point
All daily turbidity readings ≤ 1 NTU?	<u>Yes</u> /No	<u>Yes</u> /No	<u>Yes</u> /No
All turbidity readings < IFE ² triggers	<u>Yes</u> /No		
Notes:	PRINTED NAME:		
	SIGNATURE:		DATE:
	PHONE #: ()		CERT #:

¹including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

David Hancock
 503.842.9405
 D-09449
 T-09183
 1/21/26

System Name:		Netarts Water District		ID#: 41	00556	Month/Year: Jan 25	Disinfection Giardia Log Location:	0.5	
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	07:21	1.04	108	111.8	9.9	9.68	51.6	Yes	212
2	08:00	1.08	108	116.6	10.1	8.01	27.6	Yes	216
3	12:18	0.89	108	96.0	10.3	8.13	27.9	Yes	223
4	09:00	0.91	108	98.3	10.1	8.20	29.0	Yes	216
5	16:00	0.93	108	100.4	9.7	8.01	27.9	Yes	227
6	00:00	0.93	108	100.4	10.1	7.96	26.7	Yes	232
7	07:30	0.89	108	96.1	9.4	7.40	22.8	Yes	218
8	09:00	0.90	108	97.2	9.4	8.17	30.1	Yes	279
9	14:00	0.88	108	95.0	9.5	8.61	34.9	Yes	248
10	10:00	0.86	108	92.9	9.4	8.53	34.1	Yes	248
11	12:54	1.12	108	120.4	10.1	8.27	30.6	Yes	249
12	12:18	1.08	108	117.1	9.9	8.63	35.0	Yes	234
13	12:34	1.04	108	112.5	9.9	8.51	33.3	Yes	277
14	15:02	1.07	108	115.8	10.5	8.42	31.1	Yes	212
15	00:23	1.23	108	132.8	10.6	8.37	31.0	Yes	230
16	23:30	1.24	108	133.9	10.2	8.10	28.8	Yes	225
17	21:22	1.21	108	131.0	10.3	8.08	28.4	Yes	263
18	16:00	1.23	108	132.3	10.4	8.06	28.0	Yes	263
19	07:48	1.24	108	133.6	9.6	8.03	29.3	Yes	259
20	05:16	1.29	108	138.9	9.7	8.08	29.9	Yes	319
21	06:12	1.24	108	134.2	8.8	8.06	31.2	Yes	215
22	10:00	1.23	108	132.8	8.8	8.10	31.7	Yes	222
23	09:00	1.19	108	128.5	8.8	8.00	30.4	Yes	226
24	09:00	1.18	108	127.4	8.6	7.96	30.4	Yes	241
25	10:00	1.22	108	131.8	8.3	8.03	32.0	Yes	243
26	10:00	1.16	108	125.3	9.0	8.32	33.6	Yes	235
27	08:00	1.14	108	123.1	9.1	8.53	36.0	Yes	224
28	07:00	1.16	108	125.3	9.3	8.51	35.3	Yes	286
29	05:06	1.03	108	111.1	9.7	8.00	28.2	Yes	210
30	21:12	1.12	108	121.1	10.1	7.96	27.3	Yes	213
31	12:00	1.25	108	134.9	10.4	7.96	27.1	Yes	232

† met, DWP to be notified by end of next business day.

Revised February 2012