

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Lincoln  
 Month/Year: Feb-24

Conventional or Direct Filtration

<b>System Name:</b>		<b>Bay Hills Water Association</b>			<b>ID#: 41-00564</b>		<b>WTP :</b>		<b>TP-A</b>		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]				
1											
2											
3											
4											
5											
6											
7											
8	0.08	0.04	0.03	0.04			0.08				
9											
10											
11											
12											
13											
14											
15											
16											
17	0.05	0.05	0.08	0.04			0.08				
18											
19											
20											
21											
22											
23											
24											
25	0.05	0.04	0.04	0.04			0.05				
26											
27											
28											
29											
30											
31											
<b>Conventional or Direct Filtration</b>					<b>Monthly Summary (Answer Yes or No)</b>						
95% of 4-hour turbidity readings ≤ 0.3 NTU?					<b>Yes</b>		CT's met everyday? (see back)		<b>Yes</b>		
All 4-hour turbidity readings ≤ 1 NTU?					<b>Yes</b>		All Cl2 residual at entry point ≥ 0.2 mg/l?		<b>Yes</b>		
All turbidity readings < IFE <sup>2</sup> triggers					<b>Yes</b>						
<b>Notes:</b>					<b>PRINTED NAME: John MacKown</b>						
					<b>SIGNATURE:</b>						<b>3/2/24</b>
					<b>PHONE #: (541) 265-3245</b>						<b>CERT #: 6905</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

**OHA - Drinking Water Program - Surface Water Quality Data Form**

<b>System Name:</b> Bay Hills Water Association <b>ID#:</b> 41-00564 <b>Month/Year:</b> 24-Feb				<b>WTP - :</b>		<b>TP-A</b>	
				Disinfection <i>Giardia</i> Log Inactive:		0.5	

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1		426						
2		426						
3		426						
4		426						
5		426						
6		426						
7		426						
8	0.46	426	196.0	9.1	7.00	19.3	YES	10.5
9		426						
10		426						
11		426						
12		426						
13		426						
14		426						
15		426						
16		426						
17	0.55	426	234.3	10.0	7.10	19.0	YES	10.5
18		426						
19		426						
20		426						
21		426						
22		426						
23		426						
24		426						
25	0.55	426	234.3	9.0	7.50	23.3	YES	10.5
26		426						
27		426						
28		426						
29		426						
30		426						
31		426						

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

**Return by 10th of following month by email, fax, or mail to:**  
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350