


OHA - Drinking Water Program - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Lincoln**
 Month/Year: **Mar-21**

System Name:	Newport, City of			ID#: 41-00566 A			WTP: TP -	Membrane
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1	P/O	P/O	0.015	0.015	0.013	P/O	0.020	
2	P/O	P/O	0.013	0.014	0.013	P/O	0.015	
3	P/O	P/O	0.013	0.013	P/O	0.013	0.019	
4	P/O	P/O	0.013	P/O	0.013	0.013	0.015	
5	P/O	P/O	P/O	0.014	0.013	0.013	0.021	
6	P/O	P/O	0.015	0.015	P/O	P/O	0.018	
7	P/O	0.013	0.013	P/O	0.013	0.013	0.016	
8	P/O	0.013	0.014	P/O	0.013	0.013	0.014	
9	0.013	P/O	P/O	0.013	0.013	0.013	0.015	
10	P/O	P/O	P/O	0.013	0.013	P/O	0.016	
11	P/O	P/O	0.013	0.015	P/O	P/O	0.015	
12	0.013	0.013	P/O	P/O	0.013	0.013	0.018	
13	0.013	P/O	P/O	0.013	0.013	0.013	0.015	
14	P/O	P/O	P/O	0.014	0.013	0.013	0.015	
15	P/O	P/O	P/O	0.014	0.013	0.013	0.015	
16	P/O	P/O	P/O	0.015	0.014	0.013	0.017	
17	P/O	P/O	0.015	0.013	0.013	0.013	0.015	
18	P/O	P/O	P/O	0.015	0.013	0.014	0.015	
19	P/O	P/O	0.014	0.013	0.013	P/O	0.015	
20	P/O	P/O	0.013	0.013	0.018	P/O	0.018	
21	P/O	0.014	0.014	P/O	0.013	0.013	0.015	
22	P/O	P/O	0.014	0.014	0.013	0.013	0.015	
23	P/O	P/O	0.014	0.014	0.013	0.013	0.016	
24	P/O	P/O	0.014	0.014	0.013	P/O	0.018	
25	P/O	0.013	0.014	0.015	0.014	P/O	0.017	
26	P/O	0.013	0.013	P/O	0.013	0.013	0.017	
27	0.013	P/O	P/O	0.013	0.013	0.013	0.015	
28	P/O	P/O	P/O	0.014	0.013	0.013	0.015	
29	P/O	P/O	P/O	0.014	0.013	0.013	0.017	
30	P/O	P/O	P/O	0.013	0.013	0.013	0.021	
31	P/O	P/O	P/O	0.014	0.013	0.014	0.023	

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ² <input checked="" type="radio"/> Yes/ No	CT's met everyday? <input checked="" type="radio"/> Yes/ No	All Cl ₂ residual at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes/ No
All daily turbidity readings \leq 5 NTU? <input checked="" type="radio"/> Yes/ No		
Notes: P/O = PLANT OFF	PRINTED NAME: Steve Stewart	
	SIGNATURE: 	DATE: 4/1/2021
	PHONE #: (541) 265-7421	CERT #: 2445

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: Membrane

Disinfection
Giardia Log

System Name: NEWPORT, CITY OF

ID#: 41-00566

Month/Year: Mar-21

Inactive: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
3/1/2021 9:15	1.1	100	114	9	7.9	30	Yes	2252
3/2/2021 8:22	1.1	99	112	9	7.9	30	Yes	2286
3/3/2021 4:04	1.2	101	118	9	8.0	30	Yes	2214
3/4/2021 15:10	1.0	108	112	9	8.0	30	Yes	2256
3/5/2021 9:22	1.2	99	114	9	8.0	30	Yes	2268
3/6/2021 7:42	1.2	101	116	9	8.0	31	Yes	2263
3/7/2021 13:27	1.0	102	104	9	8.0	30	Yes	2201
3/8/2021 14:30	1.0	113	115	9	8.1	31	Yes	2152
3/9/2021 11:00	1.2	103	122	9	8.0	30	Yes	2179
3/10/2021 7:54	1.2	102	123	8	7.9	31	Yes	2208
3/11/2021 4:24	1.2	101	124	8	8.0	31	Yes	2233
3/12/2021 13:50	1.1	103	113	8	7.9	30	Yes	2163
3/13/2021 10:33	1.2	103	126	9	7.9	30	Yes	2169
3/14/2021 9:17	1.2	102	125	9	7.9	29	Yes	2218
3/15/2021 11:04	1.2	104	126	8	7.9	30	Yes	2169
3/16/2021 8:48	1.2	100	121	8	7.9	30	Yes	2249
3/17/2021 8:45	1.2	101	122	8	7.9	31	Yes	2197
3/18/2021 8:12	1.2	100	122	8	7.9	30	Yes	2235
3/19/2021 6:57	1.2	106	127	9	7.9	29	Yes	2203
3/20/2021 5:30	1.2	101	120	9	7.9	29	Yes	2232
3/21/2021 12:18	1.1	103	112	9	7.9	28	Yes	2180
3/22/2021 8:17	1.2	102	119	9	7.9	28	Yes	2209
3/23/2021 7:57	1.2	97	113	9	7.9	28	Yes	2234
3/24/2021 6:32	1.2	104	122	9	7.8	28	Yes	2203
3/25/2021 2:12	1.2	103	122	10	7.8	27	Yes	2229
3/26/2021 14:12	1.2	101	120	9	7.8	27	Yes	2237
3/27/2021 12:25	1.2	105	121	10	7.8	27	Yes	2170
3/28/2021 11:02	1.2	101	117	10	7.8	26	Yes	2214
3/29/2021 9:30	1.2	101	117	9	7.8	27	Yes	2212
3/30/2021 9:04	1.1	102	116	9	7.8	28	Yes	2239
3/31/2021 9:19	1.1	102	114	9	7.8	28	Yes	2219

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised September 2016

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, P.O. Box 14350, Portland, OR 97293-0350