


**OHA - Drinking Water Program - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Lincoln**  
 Month/Year: **Apr-22**  
 WTP: TP - **Membrane**

System Name:	Newport, City of			ID#: 41-00566 A			WTP: TP -	Membrane
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]	
1	P/O	P/O	P/O	0.015	0.014	0.014	0.020	
2	P/O	P/O	P/O	0.015	0.015	0.013	0.023	
3	P/O	P/O	P/O	0.013	0.014	0.014	0.063	
4	P/O	P/O	0.019	0.013	0.013	0.013	0.019	
5	P/O	P/O	P/O	0.014	0.013	0.013	0.016	
6	P/O	P/O	0.018	0.013	0.013	0.013	0.020	
7	P/O	P/O	P/O	0.014	0.014	0.013	0.021	
8	P/O	P/O	0.014	0.013	0.013	P/O	0.016	
9	P/O	P/O	P/O	0.013	0.013	0.014	0.017	
10	P/O	P/O	0.015	0.016	0.013	P/O	0.043	
11	P/O	P/O	0.013	0.013	0.013	P/O	0.023	
12	P/O	P/O	0.014	0.014	0.013	0.014	0.016	
13	P/O	P/O	P/O	0.016	0.013	0.014	0.018	
14	P/O	P/O	0.014	0.017	0.013	P/O	0.018	
15	P/O	P/O	0.016	0.014	0.014	P/O	0.025	
16	P/O	P/O	0.014	0.013	0.013	P/O	0.018	
17	P/O	P/O	0.016	0.013	0.013	P/O	0.028	
18	P/O	P/O	0.013	0.014	0.014	P/O	0.025	
19	P/O	P/O	0.014	0.014	0.014	P/O	0.016	
20	P/O	0.013	0.014	0.014	0.013	P/O	0.020	
21	P/O	P/O	P/O	0.015	0.013	0.013	0.075	
22	P/O	P/O	P/O	0.013	0.014	0.013	0.016	
23	P/O	P/O	0.018	0.013	0.014	P/O	0.018	
24	P/O	P/O	0.014	0.014	0.013	P/O	0.023	
25	P/O	P/O	0.014	0.013	0.013	P/O	0.016	
26	P/O	0.015	0.014	0.013	0.013	P/O	0.023	
27	P/O	0.013	0.014	0.013	P/O	P/O	0.019	
28	0.013	P/O	P/O	0.017	0.014	0.013	0.045	
29	P/O	P/O	P/O	0.014	0.014	P/O	0.022	
30	P/O	P/O	0.014	0.013	0.013	P/O	0.018	

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings $\leq$ 1 NTU? <sup>2</sup>	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday?	All Cl <sub>2</sub> residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
<b>Notes: P/O = PLANT OFF</b>		<b>PRINTED NAME: Steve Stewart</b>	
		<b>SIGNATURE:</b> 	<b>DATE: 5/2/2022</b>
		<b>PHONE #: ( 541 ) 265-7421</b>	<b>CERT #: 2445</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: Membrane

System Name: NEWPORT, CITY OF

ID#: 41-00566

Month/Year: Apr-22

Disinfection  
Giardia Log

Inactive: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
4/1/2022 8:12	1.1	91	98	11	7.9	26	Yes	2450
4/2/2022 9:14	1.0	93	97	11	7.9	24	Yes	2409
4/3/2022 8:37	1.1	98	106	11	8.0	25	Yes	2318
4/4/2022 7:32	0.9	94	80	11	7.9	24	Yes	2402
4/5/2022 8:07	1.0	93	96	11	8.0	26	Yes	2423
4/6/2022 8:44	1.0	95	95	11	8.0	26	Yes	2353
4/7/2022 8:51	1.0	94	95	11	8.0	25	Yes	2408
4/8/2022 7:54	1.0	93	92	12	8.0	25	Yes	2411
4/9/2022 7:49	1.0	93	93	11	8.1	26	Yes	2415
4/10/2022 7:59	1.0	94	92	11	8.1	26	Yes	2403
4/11/2022 5:39	1.0	95	98	11	8.1	26	Yes	2407
4/12/2022 5:59	1.0	99	103	11	8.1	27	Yes	2354
4/13/2022 9:34	1.1	93	100	11	8.1	28	Yes	2400
4/14/2022 6:32	1.1	93	99	10	8.1	28	Yes	2399
4/15/2022 4:29	1.0	94	98	10	8.2	30	Yes	2409
4/16/2022 3:54	1.0	93	97	10	8.2	29	Yes	2395
4/17/2022 5:47	1.0	97	101	10	8.3	30	Yes	2395
4/18/2022 5:38	1.0	95	96	11	8.3	29	Yes	2341
4/19/2022 4:29	1.0	94	96	10	8.3	30	Yes	2394
4/20/2022 1:54	1.1	93	99	11	8.3	30	Yes	2420
4/21/2022 8:04	1.0	94	95	10	8.2	29	Yes	2407
4/22/2022 8:45	0.8	95	77	11	8.2	28	Yes	2391
4/23/2022 6:26	1.0	97	101	11	8.3	29	Yes	2385
4/24/2022 8:13	1.0	96	97	11	8.3	28	Yes	2353
4/25/2022 6:31	1.1	95	101	12	8.2	27	Yes	2400
4/26/2022 4:59	1.0	91	95	12	8.2	27	Yes	2419
4/27/2022 19:46	0.7	96	72	12	8.2	25	Yes	2340
4/28/2022 11:37	1.0	92	96	12	8.2	25	Yes	2382
4/29/2022 12:41	1.1	94	104	12	8.1	25	Yes	2391
4/30/2022 5:54	1.1	95	100	12	8.1	24	Yes	2336

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised September 2016

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, P.O. Box 14350, Portland, OR 97293-0350