


OHA - Drinking Water Program - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Lincoln
Month/Year: Nov-22

System Name: Newport, City of		ID#: 41-00566 A					WTP: TP -	Membrane
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1	P/O	P/O	P/O	0.015	0.015	0.015	0.016	
2	P/O	P/O	P/O	0.015	0.015	P/O	0.017	
3	P/O	P/O	0.017	0.015	0.015	P/O	0.017	
4	P/O	0.018	0.015	P/O	0.015	0.015	0.018	
5	P/O	P/O	P/O	0.015	0.015	0.015	0.021	
6	P/O	P/O	P/O	0.016	0.015	P/O	0.019	
7	P/O	P/O	0.016	0.015	0.015	P/O	0.019	
8	0.015	P/O	P/O	0.015	0.016	0.015	0.017	
9	P/O	P/O	0.015	0.016	0.015	0.015	0.018	
10	P/O	P/O	0.016	0.015	0.015	0.015	0.017	
11	P/O	P/O	0.016	0.015	0.015	P/O	0.019	
12	P/O	P/O	0.015	0.016	0.016	P/O	0.017	
13	P/O	P/O	0.015	0.017	0.015	0.015	0.017	
14	P/O	P/O	0.015	0.015	0.015	0.015	0.018	
15	P/O	P/O	P/O	0.017	0.015	P/O	0.028	
16	P/O	P/O	0.015	0.015	0.015	0.015	0.016	
17	P/O	P/O	0.015	0.013	0.013	P/O	0.017	
18	P/O	P/O	0.013	0.013	0.013	P/O	0.015	
19	P/O	0.013	P/O	P/O	0.013	0.013	0.014	
20	P/O	P/O	P/O	0.013	0.013	0.013	0.017	
21	P/O	P/O	P/O	0.013	0.013	0.013	0.014	
22	P/O	P/O	0.013	0.013	0.012	0.013	0.017	
23	P/O	P/O	0.013	P/O	0.013	0.012	0.015	
24	P/O	P/O	P/O	0.013	0.013	P/O	0.014	
25	P/O	P/O	0.013	0.012	0.012	P/O	0.015	
26	P/O	P/O	0.012	P/O	0.012	0.013	0.016	
27	P/O	P/O	P/O	0.012	0.012	P/O	0.013	
28	P/O	0.012	0.012	P/O	0.012	0.012	0.014	
29	P/O	P/O	P/O	0.013	0.013	P/O	0.017	
30	P/O	P/O	0.013	0.013	P/O	P/O	0.017	

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes/ No	CT's met everyday?	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes/ No	Yes/ No	Yes/ No

Notes: P/O = PLANT OFF		PRINTED NAME: Steve Stewart	
		SIGNATURE: 	DATE: 12/01/2022
		PHONE #: (541) 265-7421	CERT #: 2445

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: Membrane

System Name: NEWPORT, CITY OF

ID#: 41-00566

Month/Year: Nov-22

Disinfection
Giardia Log

Inactive: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[° C]		formula	Yes / No	[GPM]
11/1/2022 7:48	0.7	88	65	12	8.0	23	Yes	2587
11/2/2022 8:29	0.9	87	79	12	8.0	24	Yes	2598
11/3/2022 7:32	1.0	88	84	11	8.0	25	Yes	2582
11/4/2022 3:43	1.0	88	90	12	8.0	25	Yes	2594
11/5/2022 9:06	0.5	91	43	12	8.0	23	Yes	2587
11/6/2022 8:13	0.8	85	70	11	8.0	25	Yes	2601
11/7/2022 7:13	0.7	94	62	10	8.1	27	Yes	2560
11/8/2022 10:43	1.0	88	84	10	8.1	28	Yes	2568
11/9/2022 6:48	1.0	92	88	9	8.1	30	Yes	2580
11/10/2022 7:16	0.7	94	65	9	8.0	28	Yes	2482
11/11/2022 7:27	0.9	91	77	9	8.1	30	Yes	2552
11/12/2022 7:06	0.6	85	51	9	8.1	29	Yes	2570
11/13/2022 6:50	0.9	87	78	8	8.1	31	Yes	2564
11/14/2022 7:11	0.7	92	61	8	8.1	32	Yes	2564
11/15/2022 8:13	0.9	89	84	8	8.1	33	Yes	2549
11/16/2022 7:03	1.0	87	89	7	8.0	33	Yes	2560
11/17/2022 7:06	0.7	92	61	7	7.9	31	Yes	2566
11/18/2022 9:18	1.0	86	83	7	7.9	33	Yes	2577
11/19/2022 12:19	0.8	99	80	6	7.9	34	Yes	2497
11/20/2022 8:04	0.9	85	79	6	7.9	35	Yes	2579
11/21/2022 7:53	0.8	93	76	6	7.9	35	Yes	2562
11/22/2022 7:29	0.8	93	75	6	7.9	34	Yes	2552
11/23/2022 5:14	1.0	92	93	6	7.9	34	Yes	2563
11/24/2022 8:16	0.9	87	78	6	7.9	34	Yes	2559
11/25/2022 6:56	0.8	94	78	6	7.8	33	Yes	2556
11/26/2022 4:52	1.0	84	80	6	7.8	34	Yes	2560
11/27/2022 9:46	0.6	91	57	6	7.8	32	Yes	2557
11/28/2022 14:04	0.9	90	80	6	7.8	32	Yes	2560
11/29/2022 9:41	0.9	88	77	6	7.7	32	Yes	2556
11/30/2022 6:58	1.0	90	91	6	7.7	32	Yes	2558

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised September 2016

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, P.O. Box 14350, Portland, OR 97293-0350