


**OHA - Drinking Water Program - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Lincoln**  
 Month/Year: **Sep-24**

System Name: <b>Newport, City of</b>			ID#: <b>41-00566 A</b>				WTP: <b>TP - Membrane</b>
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	P/O	P/O	0.017	0.017	0.015	0.015	0.023
2	P/O	P/O	P/O	0.015	0.015	0.015	0.035
3	0.015	P/O	P/O	0.014	0.015	0.015	0.019
4	P/O	P/O	0.015	0.015	0.015	0.015	0.019
5	0.015	P/O	P/O	0.014	0.015	0.015	0.028
6	0.015	P/O	P/O	0.015	0.016	0.016	0.036
7	0.016	P/O	P/O	0.015	0.015	0.015	0.028
8	0.015	P/O	P/O	0.014	0.014	0.014	0.021
9	P/O	P/O	0.014	0.015	0.015	0.015	0.020
10	P/O	P/O	0.015	0.015	0.015	0.015	0.020
11	P/O	P/O	0.015	0.015	0.015	0.015	0.030
12	P/O	P/O	0.017	0.015	0.014	0.015	0.025
13	P/O	P/O	0.016	0.015	0.016	P/O	0.022
14	0.015	0.015	P/O	P/O	0.015	0.015	0.021
15	0.015	P/O	P/O	0.015	0.015	0.015	0.020
16	P/O	P/O	P/O	0.015	0.015	0.015	0.019
17	P/O	P/O	0.015	0.014	0.015	0.015	0.018
18	P/O	P/O	0.015	0.015	0.015	P/O	0.020
19	P/O	P/O	0.015	0.015	0.015	P/O	0.029
20	P/O	P/O	0.016	0.015	0.015	0.015	0.022
21	P/O	P/O	0.021	0.015	0.015	0.015	0.021
22	P/O	0.015	P/O	P/O	0.015	P/O	0.020
23	P/O	0.015	0.015	0.015	0.015	P/O	0.050
24	P/O	P/O	0.015	0.014	0.015	P/O	0.020
25	P/O	P/O	0.015	0.015	0.015	P/O	0.037
26	P/O	0.015	0.015	P/O	0.014	0.015	0.021
27	0.015	P/O	P/O	0.015	0.014	P/O	0.017
28	P/O	P/O	0.015	0.015	0.015	P/O	0.022
29	P/O	P/O	0.015	0.015	0.015	P/O	0.026
30	P/O	0.019	0.015	0.015	0.015	P/O	0.019

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday?	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
<b>Notes: P/O = PLANT OFF</b>		<b>PRINTED NAME: Steve Stewart</b>	
		<b>SIGNATURE:</b> 	<b>DATE: 10/2/2024</b>
		<b>PHONE #: ( 541 ) 265-7421</b>	<b>CERT #: 2445</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**WTP: Membrane**

**Disinfection  
Giardia Log**

**System Name: NEWPORT, CITY OF**

**ID#: 41-00566**

**Month/Year: Sep-24**

**Inactive: 0.5**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
9/1/2024 7:20	1.1	89	95	19	7.6	13	Yes	2606
9/2/2024 9:31	1.1	83	89	19	7.5	12	Yes	2596
9/3/2024 7:58	1.1	89	96	19	7.4	12	Yes	2564
9/4/2024 8:08	1.2	85	99	18	8.6	20	Yes	2570
9/5/2024 8:00	0.7	91	62	19	8.3	16	Yes	2591
9/6/2024 7:56	0.7	87	64	19	8.3	16	Yes	2604
9/7/2024 9:21	0.8	84	65	19	8.3	16	Yes	2592
9/8/2024 8:55	0.5	89	42	19	8.2	15	Yes	2580
9/9/2024 22:08	1.3	88	110	19	8.0	16	Yes	2608
9/10/2024 7:03	0.7	90	62	19	8.2	16	Yes	2501
9/11/2024 5:26	1.0	84	88	19	8.2	16	Yes	2609
9/12/2024 7:33	1.1	87	92	19	8.1	16	Yes	2605
9/13/2024 5:51	1.2	87	101	19	8.1	16	Yes	2602
9/14/2024 13:00	0.5	89	48	19	8.1	15	Yes	2607
9/15/2024 8:30	0.7	88	59	19	8.1	15	Yes	2591
9/16/2024 7:47	1.1	84	89	18	8.1	16	Yes	2591
9/17/2024 7:11	0.6	89	53	18	8.0	15	Yes	2605
9/18/2024 5:01	1.1	84	93	18	8.0	16	Yes	2609
9/19/2024 6:36	1.0	89	89	18	8.0	16	Yes	2550
9/20/2024 6:47	0.9	87	79	18	7.9	16	Yes	2564
9/21/2024 7:31	1.0	85	85	17	7.9	17	Yes	2566
9/22/2024 11:58	0.6	89	55	18	8.0	16	Yes	2563
9/23/2024 2:55	1.1	89	96	17	8.0	17	Yes	2610
9/24/2024 4:08	1.1	89	94	17	7.9	16	Yes	2544
9/25/2024 4:08	0.8	86	73	17	7.8	15	Yes	2540
9/26/2024 14:15	0.6	89	54	17	7.8	15	Yes	2582
9/27/2024 8:38	0.6	92	59	17	7.8	15	Yes	2599
9/28/2024 5:08	0.9	91	80	17	7.7	15	Yes	2588
9/29/2024 6:40	1.0	84	84	17	7.7	16	Yes	2610
9/30/2024 3:33	1.1	89	96	16	7.8	17	Yes	2609

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised September 2016

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, P.O. Box 14350, Portland, OR 97293-0350

