


OHA - Drinking Water Program - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Lincoln**
 Month/Year: **Jan-25**
 WTP: TP - **Membrane**

System Name: Newport, City of				ID#: 41-00566 A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	P/O	P/O	P/O	0.017	0.015	P/O	0.021
2	P/O	P/O	0.014	0.014	0.014	P/O	0.021
3	P/O	P/O	0.014	0.015	0.016	P/O	0.025
4	P/O	P/O	P/O	0.019	0.015	P/O	0.027
5	P/O	P/O	P/O	0.014	0.014	P/O	0.025
6	P/O	P/O	P/O	0.015	0.015	P/O	0.019
7	P/O	P/O	P/O	0.015	0.015	P/O	0.025
8	P/O	P/O	P/O	0.019	0.014	0.014	0.020
9	P/O	P/O	P/O	0.014	0.016	0.014	0.022
10	P/O	P/O	0.015	0.015	0.014	P/O	0.025
11	P/O	P/O	P/O	0.015	0.015	0.014	0.022
12	P/O	P/O	P/O	0.014	0.015	0.014	0.026
13	P/O	P/O	P/O	0.016	0.014	0.014	0.030
14	P/O	P/O	P/O	0.015	0.015	P/O	0.018
15	P/O	P/O	0.015	0.014	0.014	0.014	0.023
16	P/O	P/O	P/O	0.016	0.014	0.014	0.017
17	P/O	P/O	P/O	0.015	0.016	0.015	0.019
18	P/O	P/O	P/O	0.014	0.014	0.016	0.016
19	P/O	P/O	P/O	0.015	0.015	0.015	0.019
20	P/O	P/O	P/O	0.016	0.014	0.015	0.025
21	P/O	P/O	0.018	0.015	0.014	0.015	0.027
22	P/O	P/O	P/O	0.017	0.014	P/O	0.028
23	P/O	P/O	0.016	0.015	P/O	P/O	0.019
24	0.015	0.014	P/O	0.015	0.014	0.014	0.017
25	P/O	P/O	P/O	0.016	0.014	0.015	0.016
26	P/O	P/O	P/O	0.015	0.015	P/O	0.026
27	P/O	P/O	0.018	0.015	0.014	P/O	0.018
28	P/O	P/O	P/O	0.016	0.016	0.014	0.016
29	P/O	P/O	P/O	P/O	0.014	P/O	0.016
30	P/O	P/O	P/O	0.015	0.014	0.014	0.019
31	P/O	P/O	P/O	0.015	0.024	0.016	0.067

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ²	☒ Yes / ☐ No	CT's met everyday?	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	☒ Yes / ☐ No	☒ Yes / ☐ No	☒ Yes / ☐ No
Notes: P/O = PLANT OFF		PRINTED NAME: Steve Stewart	
		SIGNATURE: 	DATE: 2/3/2025
		PHONE #: (541) 265-7421	CERT #: 2445

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form
WTP: Membrane
System Name: NEWPORT, CITY OF
ID#: 41-00566
Month/Year: Jan-25
**Disinfection
Giardia Log
Inactive: 0.5**

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/1/2025 8:14	1.1	85	95	9	8.0	30	Yes	2619
1/2/2025 7:14	1.1	88	98	9	8.0	30	Yes	2611
1/3/2025 7:52	1.2	86	102	9	8.0	30	Yes	2607
1/4/2025 7:57	1.2	86	101	9	8.0	29	Yes	2608
1/5/2025 7:58	1.2	89	104	9	7.9	28	Yes	2555
1/6/2025 8:28	1.2	86	103	10	7.9	28	Yes	2613
1/7/2025 10:07	1.2	84	102	9	7.9	28	Yes	2619
1/8/2025 8:24	1.2	85	99	9	7.8	28	Yes	2623
1/9/2025 9:21	1.2	88	103	9	7.8	28	Yes	2604
1/10/2025 6:43	1.3	88	112	9	7.8	29	Yes	2607
1/11/2025 8:14	1.2	86	105	9	7.9	29	Yes	2614
1/12/2025 9:52	1.1	86	96	9	7.8	28	Yes	2609
1/13/2025 8:34	1.1	86	97	8	7.8	29	Yes	2619
1/14/2025 8:57	1.0	87	89	8	7.8	29	Yes	2618
1/15/2025 7:19	1.1	88	95	8	7.9	31	Yes	2545
1/16/2025 7:53	1.1	86	97	7	7.9	33	Yes	2614
1/17/2025 8:07	1.2	86	107	7	8.0	34	Yes	2607
1/18/2025 8:52	1.2	87	102	7	8.0	35	Yes	2600
1/19/2025 8:39	1.2	89	104	6	8.1	37	Yes	2507
1/20/2025 9:11	1.1	86	97	6	8.1	39	Yes	2619
1/21/2025 7:44	1.1	88	93	5	8.0	38	Yes	2616
1/22/2025 8:39	1.1	88	97	5	8.0	39	Yes	2541
1/23/2025 5:19	1.1	86	96	5	8.0	40	Yes	2617
1/24/2025 10:57	1.0	87	88	5	8.0	38	Yes	2564
1/25/2025 9:39	1.1	87	96	5	8.0	39	Yes	2602
1/26/2025 9:32	1.1	91	104	5	8.0	40	Yes	2535
1/27/2025 7:45	1.1	83	90	4	8.0	41	Yes	2617
1/28/2025 8:06	1.1	83	88	4	8.0	41	Yes	2696
1/29/2025 4:24	1.2	87	101	4	8.0	42	Yes	2571
1/30/2025 8:08	1.1	86	97	4	8.0	41	Yes	2626
1/31/2025 10:14	1.1	86	94	5	8.0	40	Yes	2611

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised September 2016

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, P.O. Box 14350, Portland, OR 97293-0350