

OHA - DWS

Membrane Filter Monthly Operating Report

County: **Lincoln**

System Name: **Newport, City of**

Month/Year: **Jun-2025**

PWS ID#: 41 - **00566**

Minimum test pressure applied: **25** psi

Plant ID: WTP - **A**

Minimum test pressure req'd: **20** psi

(e.g., "A")

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇔

PDR = Pressure Decay Rate

LRC = Log Removal Credit

PDR_{Max} [psi/min]

LRC [log removal]

0.060

4.00


DIT
Daily

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 Min duration)	Highest PDR of day [psi/min]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	0.022	0.022	0.037	0.05	4.77	Y
2	0.021	0.026	0.039	0.05	4.75	Y
3	0.036	0.038	0.069	0.05	4.74	Y
4	0.040	0.046	0.050	0.05	4.76	Y
5	0.029	0.036	0.028	0.05	4.72	Y
6	0.029	0.037	0.034	0.05	4.70	Y
7	0.028	0.032	0.028	0.05	4.74	Y
8	0.035	0.044	0.040	0.05	4.75	Y
9	0.027	0.037	0.028	0.05	4.78	Y
10	0.021	0.029	0.031	0.05	4.74	Y
11	0.047	0.047	0.035	0.05	4.70	Y
12	0.031	0.034	0.033	0.05	4.73	Y
13	0.025	0.031	0.035	0.05	4.74	Y
14	0.023	0.027	0.037	0.05	4.74	Y
15	0.024	0.032	0.033	0.05	4.72	Y
16	0.023	0.031	0.029	0.05	4.69	Y
17	0.029	0.032	0.071	0.05	4.72	Y
18	0.059	0.096	0.055	0.05	4.73	Y
19	0.025	0.033	0.039	0.05	4.77	Y
20	0.020	0.036	0.039	0.05	4.73	Y
21	0.023	0.035	0.047	0.05	4.74	Y
22	0.023	0.039	0.038	0.05	4.75	Y
23	0.028	0.035	0.032	0.06	4.74	Y
24	0.019	0.028	0.035	0.05	4.75	Y
25	0.024	0.078	0.032	0.05	4.77	Y
26	0.018	0.023	0.034	0.05	4.72	Y
27	0.018	0.025	0.050	0.05	4.74	Y
28	0.018	0.029	0.043	0.06	4.71	Y
29	0.023	0.038	0.039	0.06	4.62	Y
30	0.021	0.027	0.054	0.05	4.60	Y

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily?
Yes	Yes	Yes	Yes	Yes
CT's met daily? (p. 2)	All Cl ₂ residual at EP ≥ 0.2 mg/L?	PDR ≤ PDR _{Max} ?	LRV _{ambient} ≥ LRC?	
Yes	Yes	Yes	Yes	

PRINTED NAME: Steve Stewart

SIGNATURE: 

Notes:

DATE: 7/2/2025

WT CERT #: 2445

PHONE #: 541-265-7421

p. 1 of 2

Disinfection Monthly Operating ReportSystem Name: **Newport, City of**PWS ID#: 41 - **00566**Plant ID : WTP - **A****0.5**Log
Inactivation
Required via
Disinfection

Day	Minimum Cl ₂ Residual at 1 st User (C) * [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	1.2	85	103	17	7.7	16	YES	2,604	
2	1.2	69	80	17	7.8	16	YES	3,101	
3	1.2	84	99	17	7.9	17	YES	2,557	
4	1.1	85	95	18	7.9	16	YES	2,554	
5	1.2	90	105	18	7.8	16	YES	2,497	
6	1.2	87	104	18	7.8	15	YES	2,545	
7	1.2	87	105	18	7.8	16	YES	2,573	
8	1.2	88	105	18	7.9	16	YES	2,578	
9	1.2	87	106	19	7.8	15	YES	2,553	
10	1.2	90	109	19	7.7	14	YES	2,544	
11	1.2	91	108	19	7.8	14	YES	2,571	
12	1.2	88	103	19	7.9	15	YES	2,570	
13	1.0	86	88	19	8.0	15	YES	2,580	
14	1.1	89	93	18	8.0	16	YES	2,566	
15	0.9	86	76	18	8.0	16	YES	2,579	
16	1.1	88	93	18	8.0	17	YES	2,589	
17	1.1	85	92	18	8.0	17	YES	2,582	
18	1.1	88	95	18	8.1	17	YES	2,575	
19	0.8	90	75	18	8.0	16	YES	2,571	
20	1.1	87	95	18	7.9	15	YES	2,571	
21	1.1	86	91	18	7.8	15	YES	2,578	
22	1.1	86	90	18	7.9	15	YES	2,578	
23	1.0	88	87	18	7.9	16	YES	2,601	
24	1.0	85	84	18	7.6	15	YES	2,579	
25	1.1	86	98	18	7.7	15	YES	2,585	
26	1.2	88	103	18	7.7	15	YES	2,578	
27	0.9	89	81	18	7.8	15	YES	2,577	
28	1.2	88	106	18	7.9	16	YES	2,586	
29	1.0	89	93	18	8.0	16	YES	2,578	
30	1.1	88	93	19	8.1	16	YES	2,578	

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
PO Box 14350
Portland, OR 97293-0350

email: dwp.dmce@odhsoha.oregon.gov

fax: 971-673-0458

p. 2 of 2