

OHA - DWS

Membrane Filter Monthly Operating Report

County: **Lincoln**

System Name: **Newport, City of**

Month/Year: **Sep-2025**

PWS ID#: 41 - **00566**

Minimum test pressure applied: **25** psi

Plant ID: WTP - **A**

Minimum test pressure req'd: **20** psi

(e.g., "A")

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇌

PDR = Pressure Decay Rate

LRC = Log Removal Credit

PDR_{Max} [psi/min]

0.060

LRC [log removal]

4.00

DIT
Daily

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 Min duration)	Highest PDR of day [psi/min]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	0.035	0.061	0.025	0.05	4.76	Y
2	0.034	0.062	0.027	0.05	4.75	Y
3	0.028	0.090	0.025	0.05	4.72	Y
4	0.086	0.134	0.044	0.05	4.71	Y
5	0.048	0.166	0.025	0.05	4.69	Y
6	0.066	0.199	0.026	0.06	4.60	Y
7	0.098	0.169	0.028	0.06	4.53	Y
8	0.054	0.104	0.030	0.04	4.65	Y
9	0.109	0.112	0.035	0.04	4.77	Y
10	0.025	0.067	0.024	0.05	4.75	Y
11	0.075	0.081	0.035	0.04	4.77	Y
12	0.068	0.075	0.038	0.04	4.78	Y
13	0.025	0.058	0.027	0.04	4.75	Y
14	0.029	0.069	0.034	0.05	4.71	Y
15	0.029	0.088	0.028	0.04	4.71	Y
16	0.026	0.062	0.026	0.05	4.68	Y
17	0.050	0.051	0.041	0.04	4.78	Y
18	0.026	0.056	0.051	0.04	4.75	Y
19	0.039	0.053	0.040	0.04	4.72	Y
20	0.027	0.073	0.050	0.05	4.74	Y
21	0.047	0.057	0.036	0.04	4.75	Y
22	0.027	0.050	0.063	0.05	4.75	Y
23	0.066	0.067	0.073	0.04	4.74	Y
24	0.023	0.054	0.040	0.04	4.71	Y
25	0.021	0.044	0.050	0.04	4.78	Y
26	0.024	0.047	0.044	0.05	4.72	Y
27	0.032	0.075	0.028	0.04	4.70	Y
28	0.025	0.054	0.025	0.05	4.73	Y
29	0.040	0.094	0.029	0.04	4.76	Y
30	0.061	0.080	0.033	0.05	4.73	Y

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily?
Yes	Yes	Yes	Yes	Yes
CT's met daily? (p. 2)	All Cl ₂ residual at EP ≥ 0.2 mg/L?	PDR ≤ PDR _{Max} ?	LRV _{ambient} ≥ LRC?	
Yes	Yes	Yes	Yes	

PRINTED NAME: **Steve Stewart**

SIGNATURE: 

Notes:

DATE: **10/2/2025**

WT CERT #: **2445**

PHONE #: **541-265-7421**

p. 1 of 2

Disinfection Monthly Operating ReportSystem Name: **Newport, City of**PWS ID#: 41 - **00566**Plant ID : WTP - **A****0.5**Log
Inactivation
Required via
Disinfection

Day	Minimum Cl ₂ Residual at 1 st User (C) * [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	1.1	90	95	19	7.9	15	YES	2,570	
2	0.9	91	86	19	8.0	15	YES	2,576	
3	0.7	89	65	20	8.0	14	YES	2,575	
4	1.1	89	96	19	8.0	15	YES	2,584	
5	1.1	87	94	19	8.0	15	YES	2,583	
6	1.1	93	101	19	8.2	16	YES	2,500	
7	0.6	89	55	19	8.2	15	YES	2,529	
8	0.9	86	76	19	8.2	16	YES	2,579	
9	1.1	91	101	19	8.1	16	YES	2,554	
10	1.1	89	101	19	8.1	15	YES	2,557	
11	0.6	91	59	19	8.1	15	YES	2,550	
12	1.1	87	99	19	8.0	15	YES	2,555	
13	0.6	89	51	19	8.0	14	YES	2,597	
14	1.1	85	95	19	8.0	15	YES	2,585	
15	0.5	90	48	18	8.0	15	YES	2,571	
16	1.0	84	87	18	8.0	16	YES	2,588	
17	1.1	86	94	19	8.0	15	YES	2,582	
18	0.6	83	50	19	8.0	15	YES	2,582	
19	0.7	90	63	18	8.0	16	YES	2,576	
20	0.8	85	72	18	8.0	16	YES	2,581	
21	0.7	89	65	18	8.0	16	YES	2,583	
22	1.1	89	93	18	8.1	17	YES	2,584	
23	0.7	85	57	18	8.2	17	YES	2,569	
24	1.1	90	98	18	8.1	18	YES	2,567	
25	0.6	87	50	17	8.1	17	YES	2,579	
26	1.0	88	93	17	8.1	18	YES	2,589	
27	1.0	86	83	17	8.1	18	YES	2,576	
28	0.8	91	74	17	8.1	17	YES	2,588	
29	0.7	84	59	17	8.0	17	YES	2,577	
30	1.0	89	91	17	8.1	18	YES	2,593	

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
PO Box 14350
Portland, OR 97293-0350

email: dwp.dmce@odhsoha.oregon.gov

fax: 971-673-0458

p. 2 of 2