


OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Lincoln

Conventional or Direct Filtration

Month/Year: Feb-22

System Name:	Beverly Beach Water District			ID#: 41 00568	WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3	OFF	OFF	OFF	OFF	0.08	0.04	0.08
4	0.03	0.03	0.02	0.02	0.02	OFF	0.03
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	OFF	OFF	OFF	OFF	OFF	OFF	OFF
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14	OFF	OFF	OFF	OFF	OFF	0.03	0.03
15	0.04	0.04	0.04	0.03	0.02	0.03	0.04
16	0.04	0.03	0.02	0.02	0.02	0.02	0.04
17	0.02	0.02	0.02	0.02	0.02	0.02	0.02
18	0.02	0.04	0.03	OFF	OFF	OFF	0.04
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF
22	OFF	OFF	OFF	OFF	0.09	0.02	0.09
23	0.02	0.02	0.02	0.03	0.05	OFF	0.05
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25	OFF	OFF	OFF	OFF	OFF	0.02	0.02
26	0.02	0.02	0.02	0.02	OFF	0.02	0.02
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No
Notes:	PRINTED NAME: Aaron Olson SIGNATURE:  PHONE #: (503) 487-7591	DATE: 03-03-22 CERT #: T-09128

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form						WTP - : A	Inactivation
System Name:	Beverly Beach Water District	ID#: 41 00568	Month/Year:	Feb-22	Disinfection <i>Giardia</i> Log Inactive:	1	

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Feb	OFF	70						
2-Feb	OFF	70						
3-Feb	0.7	70	49.0	10.0	7.0	37.3	Yes	50
4-Feb	1.2	70	84.0	10.0	7.4	45.4	Yes	50
5-Feb	OFF	70						
6-Feb	OFF	70						
7-Feb	OFF	70						
8-Feb	OFF	70						
9-Feb	OFF	70						
10-Feb	OFF	70						
11-Feb	OFF	70						
12-Feb	OFF	70						
13-Feb	OFF	70						
14-Feb	1.3	70	91.0	9.0	7.2	45.7	Yes	50
15-Feb	1.2	70	84.0	9.0	7.2	45.2	Yes	50
16-Feb	1.2	70	84.0	9.0	7.3	46.8	Yes	50
17-Feb	1.3	70	91.0	9.0	7.3	47.4	Yes	50
18-Feb	OFF	70						
19-Feb	OFF	70						
20-Feb	OFF	70						
21-Feb	OFF	70						
22-Feb	0.8	70	56.0	10.0	7.3	41.9	Yes	50
23-Feb	1.3	70	91.0	8.0	7.3	50.6	Yes	50
24-Feb	OFF	70						
25-Feb	0.9	70	63.0	10.0	7.1	39.5	Yes	50
26-Feb	1.6	70	112.0	9.0	7.3	49.0	Yes	50
27-Feb	OFF	70						
28-Feb	OFF	70						

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours. Revised July 2018
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350
PAGE 2 of 2

Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name: Beverly Beach WD **ID#** 41 00568 **Month/Year:** Feb / 2022

Minimum UVT [%] during month: LAB Duty sensor variation from reference sensor %: _____ Reference Sensor test in manual

Minimum Validated UVT : {Insert Req'd Value} 88%

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[mW/cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	OFF					
2	OFF					
3	50	0.59	Y	22689	6.3	1.30%
4	50	0.56	Y	52941	14.7	1.30%
5	OFF					
6	OFF					
7	OFF					
8	OFF					
9	OFF					
10	OFF					
11	OFF					
12	OFF					
13	OFF					
14	50	0.82	Y	22141	4.2	0.90%
15	50	0.53	Y	74331	26.1	1.75%
16	50	0.49	Y	75912	25.1	1.60%
17	50	0.51	Y	74331	23.1	1.55%
18	50	0.44	Y	25296	10.5	2.00%
19	OFF					
20	OFF					
21	OFF					
22	50	0.49	Y	26766	9.5	1.70%
23	50	0.52	Y	52424	13.7	1.20%
24	OFF					
25	50	0.48	Y	22804	8.4	1.80%
26	50	0.44	Y	46666	24.1	2.60%
27	OFF					
28	OFF					
29						
30						
31						

Monthly Cumulative % Off-Spec Water Produced **17.70%**

rev 1/11 E:\MC\forms\Turbidity Report Form – UV and opt mod.doc

Signature: 

Op Cert #: T-09128

Date: 3/3/2022