

# Amended July Report for Beverly Beach

## OHA - Drinking Water Services -Turbidity Monitoring Report Form

### Conventional or Direct Filtration

County: **Lincoln**

Month/Year: **Jul-23**

System Name: <b>Beverly Beach Water District</b>		ID#: <b>41 00568</b>					WTP : TP - <b>A</b>	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1-Jul	0.023	0.023	0.023	0.035	0.130	OFF	0.13	
2-Jul	OFF	OFF	OFF	OFF	OFF	0.025	0.03	
3-Jul	0.025	0.025	0.045	OFF	0.035	0.078	0.08	
4-Jul	0.023	0.027	0.048	0.110	OFF	OFF	0.11	
5-Jul	OFF	OFF	OFF	OFF	OFF	0.020	0.02	
6-Jul	0.020	0.020	0.066	OFF	OFF	0.024	0.07	
7-Jul	0.023	0.023	0.029	0.166	OFF	OFF	0.17	
8-Jul	OFF	OFF	OFF	0.098	0.031	0.024	0.10	
9-Jul	0.023	0.048	OFF	OFF	OFF	OFF	0.05	
10-Jul	OFF	OFF	OFF	OFF	0.031	0.023	0.03	
11-Jul	0.023	0.030	0.130	0.025	0.025	0.025	0.13	
12-Jul	OFF	OFF	OFF	OFF	0.040	0.023	0.04	
13-Jul	0.023	0.050	0.160	OFF	OFF	OFF	0.16	
14-Jul	OFF	OFF	OFF	0.030	OFF	0.045	0.05	
15-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
16-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
17-Jul	0.040	0.025	0.025	0.025	0.115	0.060	0.12	
18-Jul	0.024	0.023	0.023	0.038	OFF	OFF	0.04	
19-Jul	0.034	0.022	0.021	0.021	OFF	OFF	0.03	
20-Jul	0.021	0.021	0.021	0.022	OFF	OFF	0.02	
21-Jul	0.022	0.021	0.021	0.028	OFF	0.021	0.03	
22-Jul	0.021	0.028	0.078	0.200	OFF	OFF	0.20	
23-Jul	0.053	0.021	0.021	0.021	0.210	OFF	0.21	
24-Jul	0.036	0.021	OFF	OFF	OFF	OFF	0.04	
25-Jul	0.023	0.023	0.023	0.039	OFF	OFF	0.04	
26-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
27-Jul	OFF	0.022	0.022	0.022	0.180	OFF	0.18	
28-Jul	OFF	0.023	0.023	0.030	OFF	OFF	0.03	
29-Jul	OFF	OFF	OFF	0.035	0.023	0.035	0.04	
30-Jul	0.030	0.022	0.022	0.024	OFF	OFF	0.03	
31-Jul	OFF	OFF	OFF	OFF	0.025	OFF		

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <span style="float: right;"><input checked="" type="radio"/> Yes <input type="radio"/> No</span> All 4-hour turbidity readings ≤ 1 NTU? <span style="float: right;"><input checked="" type="radio"/> Yes <input type="radio"/> No</span> All turbidity readings < IFE <sup>2</sup> triggers <span style="float: right;"><input checked="" type="radio"/> Yes <input type="radio"/> No</span>	CT's met everyday? (see back)  <span style="float: right;"><input checked="" type="radio"/> Yes <input type="radio"/> No</span>	All Cl2 residual at entry point ≥ 0.2 mg/l?  <span style="float: right;"><input checked="" type="radio"/> Yes <input type="radio"/> No</span>

<b>Notes:</b>  	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;"><b>PRINTED NAME:</b> JJ Olson</td> <td style="width: 40%;"><b>DATE:</b> 08-24-23</td> </tr> <tr> <td><b>SIGNATURE:</b> <i>Jeffrey Olson</i></td> <td><b>CERT #:</b> T766039</td> </tr> <tr> <td><b>PHONE #:</b> (503) 554-8333</td> <td></td> </tr> </table>	<b>PRINTED NAME:</b> JJ Olson	<b>DATE:</b> 08-24-23	<b>SIGNATURE:</b> <i>Jeffrey Olson</i>	<b>CERT #:</b> T766039	<b>PHONE #:</b> (503) 554-8333	
<b>PRINTED NAME:</b> JJ Olson	<b>DATE:</b> 08-24-23						
<b>SIGNATURE:</b> <i>Jeffrey Olson</i>	<b>CERT #:</b> T766039						
<b>PHONE #:</b> (503) 554-8333							

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form						WTP - : A	Inactivation
System Name:	Beverly Beach Water District	ID#: 41 00568	Month/Year:	Jul-23	Disinfection <i>Giardia</i> Log Inactive:		1

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1-Jul	1.2	70	84.0	15.0	7.1	28.9	Yes	50
2-Jul	1.4	70	98.0	16.0	7.4	30.9	Yes	50
3-Jul	1.2	70	84.0	15.0	7.3	31.1	Yes	50
4-Jul	1.1	70	77.0	15.0	7.3	30.8	Yes	50
5-Jul	1.3	70	91.0	16.0	7.3	29.5	Yes	50
6-Jul	1.5	70	105.0	17.0	7.4	29.3	Yes	50
7-Jul	1.5	70	105.0	15.0	7.6	36.0	Yes	50
8-Jul	1.5	70	105.0	16.0	7.6	33.7	Yes	50
9-Jul	1.4	70	98.0	17.0	7.6	31.2	Yes	50
10-Jul	1.7	70	119.0	16.0	7.5	33.2	Yes	50
11-Jul	2.0	70	140.0	16.0	7.3	31.9	Yes	50
12-Jul	1.4	70	98.0	16.0	7.2	28.7	Yes	50
13-Jul	1.3	70	91.0	16.0	7.3	29.5	Yes	50
14-Jul	1.3	70	91.0	16.0	7.3	29.5	Yes	50
15-Jul	OFF							
16-Jul	OFF							
17-Jul	1.2	70	91.0	16.0	7.2	28.1	Yes	50
18-Jul	1.4	70	98.0	17.0	7.2	26.9	Yes	50
19-Jul	1.6	70	112.0	17.0	7.4	29.6	Yes	50
20-Jul	1.5	70	105.0	16.0	7.4	31.3	Yes	50
21-Jul	1.6	70	112.0	16.0	7.4	31.6	Yes	50
22-Jul	1.6	70	112.0	17.0	7.3	28.5	Yes	50
23-Jul	1.6	70	112.0	17.0	7.2	27.5	Yes	50
24-Jul	1.5	70	105.0	18.0	7.3	26.4	Yes	50
25-Jul	1.2	70	84.0	17.0	7.1	25.3	Yes	50
26-Jul	OFF							
27-Jul	1.3	70	91.0	17.0	7.2	26.6	Yes	50
28-Jul	1.1	70	77.0	17.0	7.0	24.1	Yes	50
29-Jul	1.4	70	98.0	16.0	7.2	28.7	Yes	50
30-Jul	1.2	70	84.0	15.0	7.2	30.0	Yes	50
31-Jul	1.4	70	98.0	16.0	7.4	30.9	Yes	50

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

[dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us); 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350