

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Lincoln

Conventional or Direct Filtration

Month/Year:

Jan-25

System Name: Beverly Beach Water District			ID#: 41 00568			WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	12 PM [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1-Jan	OFF	0.025	0.024	0.023	0.033	0.077	0.077
2-Jan	0.082	0.026	0.017	0.017	OFF	OFF	0.082
3-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
4-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
5-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8-Jan	OFF	OFF	OFF	0.110	OFF	OFF	0.110
9-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
10-Jan	OFF	OFF	OFF	OFF	OFF	0.180	0.180
11-Jan	0.020	0.015	0.015	0.015	0.015	0.015	0.020
12-Jan	0.015	0.015	0.015	0.017	0.030	OFF	0.030
13-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
17-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
18-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
19-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20-Jan	0.080	OFF	OFF	OFF	OFF	OFF	0.080
21-Jan	OFF	OFF	OFF	0.012	0.012	0.012	0.012
22-Jan	0.012	0.013	0.013	0.014	0.014	0.014	0.014
23-Jan	0.014	0.014	0.035	0.080	OFF	OFF	0.080
24-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
26-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
30-Jan	OFF	OFF	OFF	0.081	0.033	0.021	0.081
31-Jan	0.025	0.110	OFF	OFF	OFF	OFF	0.110

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	☒ Yes / ☐ No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	☒ Yes / ☐ No	☒ Yes / ☐ No	☒ Yes / ☐ No
All turbidity readings < IFE ² triggers	☒ Yes / ☐ No		

Notes:	PRINTED NAME: JJ Olson
	SIGNATURE: <i>Jeffrey Olson</i> 2/6/2025
	PHONE #: (503) 554-8333 CERT #: T766039

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indiv. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - : A	Inactivation
System Name:	Beverly Beach Water District		ID#: 41	00568	Month/Year:	Jan-25	Disinfection <i>Giardia</i> Log Inactive:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Jan	1.4	70	98	12	7.3	39.3	Yes	50
2-Jan	1.6	70	112	12	7.1	37.5	Yes	50
3-Jan								
4-Jan								
5-Jan								
6-Jan								
7-Jan								
8-Jan	0.9	70	63.0	11.0	7.0	35.8	Yes	50
9-Jan								
10-Jan	1.3	70	91.0	12.0	7.3	38.9	Yes	50
11-Jan	1.8	70	126.0	15.0	7.5	35.9	Yes	50
12-Jan	1.8	70	126.0	12.0	7.6	45.7	Yes	50
13-Jan								
14-Jan								
15-Jan								
16-Jan								
17-Jan								
18-Jan								
19-Jan								
20-Jan	0.9	70	63.0	12.0	7.0	33.6	Yes	50
21-Jan	1.7	70	119.0	7.0	7.1	52.8	Yes	50
22-Jan	1.5	70	105.0	7.0	7.5	59.5	Yes	50
23-Jan	1.3	70	91.0	8.0	7.5	54.4	Yes	50
24-Jan								
25-Jan								
26-Jan								
27-Jan								
28-Jan								
29-Jan								
30-Jan	1.3	70	91.0	12.0	7.5	41.7	Yes	50
31-Jan	1.8	70	126.0	13.0	7.7	44.1	Yes	50

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018