

## OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Lincoln

## Conventional or Direct Filtration

Month/Year:

Feb-25

System Name:		Beverly Beach Water District			ID#: 41 00568		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	12 PM [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
2-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
3-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
4-Feb	OFF	OFF	OFF	OFF	OFF	0.128	0.128	
5-Feb	0.030	0.019	0.028	0.166	OFF	0.028	0.166	
6-Feb	0.093	0.242	OFF	OFF	OFF	OFF	0.242	
7-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
8-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
9-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
10-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
11-Feb	OFF	0.014	0.014	0.013	0.013	0.013	0.014	
12-Feb	0.013	0.019	0.038	0.072	OFF	OFF	0.072	
13-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
14-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
15-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
16-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
17-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
18-Feb	OFF	OFF	OFF	OFF	OFF	0.190	0.190	
19-Feb	0.080	0.015	0.015	0.160	OFF	0.017	0.160	
20-Feb	0.013	0.013	0.015	0.023	0.042	0.074	0.074	
21-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
22-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
23-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
24-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
25-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
26-Feb	OFF	0.018	0.018	0.016	0.015	0.018	0.018	
27-Feb	0.150	0.015	0.015	OFF	OFF	OFF	0.150	
28-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
<b>Conventional or Direct Filtration</b>				<b>Monthly Summary (Answer Yes or No)</b>				
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?			<input checked="" type="radio"/> Yes / No		CT's met everyday? (see back)		All Cl2 residual at entry point $\geq$ 0.2 mg/l?	
All 4-hour turbidity readings $\leq$ 1 NTU?			<input checked="" type="radio"/> Yes / No		<input checked="" type="radio"/> Yes / No		<input checked="" type="radio"/> Yes / No	
All turbidity readings < IFE <sup>2</sup> triggers			<input checked="" type="radio"/> Yes / No					
<b>Notes:</b>				<b>PRINTED NAME:</b> JJ Olson				
				<b>SIGNATURE:</b> <i>Jeffrey Olson</i>				
				<b>PHONE #:</b> (563) 554-8333				
				<b>CERT #:</b> T766039				

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Indiv. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - : A	Inactivation
System Name:	Beverly Beach Water District	ID#: 41	00568	Month/Year:	Feb-25	Disinfection <i>Giardia</i> Log Inactive:	1	
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Feb	OFF							
2-Feb	OFF							
3-Feb	OFF							
4-Feb	1.1	70	77.0	9.0	7.3	46.3	Yes	50
5-Feb	1.8	70	126.0	9.0	7.4	52.0	Yes	50
6-Feb	1.3	70	91.0	9.0	7.3	47.4	Yes	50
7-Feb	OFF							
8-Feb	OFF							
9-Feb	OFF							
10-Feb	OFF							
11-Feb	1.8	70	126.0	9.0	7.4	52.0	Yes	50
12-Feb	1.5	70	105.0	7.0	7.5	59.5	Yes	50
13-Feb	OFF							
14-Feb	OFF							
15-Feb	OFF							
16-Feb	OFF							
17-Feb	OFF							
18-Feb	1.0	70	70.0	10.0	7.0	38.6	Yes	50
19-Feb	1.5	70	105.0	11.0	7.7	48.9	Yes	50
20-Feb	1.5	70	105.0	11.0	7.4	44.0	Yes	50
21-Feb	OFF							
22-Feb	OFF							
23-Feb	OFF							
24-Feb	OFF							
25-Feb	OFF							
26-Feb	1.6	70	112.0	11.0	7.6	47.7	Yes	50
27-Feb	1.2	70	84.0	10.0	7.3	43.8	Yes	50
28-Feb	OFF							

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018