

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Lincoln

Conventional or Direct Filtration

Month/Year:

Mar-25

System Name:		Beverly Beach Water District			ID#: 41 00568		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	12 PM [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
2-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
3-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
4-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
5-Mar	OFF	OFF	OFF	OFF	0.012	0.013	0.013	
6-Mar	0.015	0.016	0.028	0.120	OFF	OFF	0.120	
7-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
8-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
9-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
10-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
11-Mar	OFF	OFF	OFF	OFF	0.016	0.015	0.016	
12-Mar	0.015	0.014	0.016	0.210	OFF	OFF	0.210	
13-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
14-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
15-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
16-Mar	OFF	OFF	OFF	OFF	OFF	0.012	0.012	
17-Mar	0.010	0.010	0.010	0.009	0.011	0.012	0.012	
18-Mar	0.130	0.011	0.010	OFF	OFF	0.013	0.130	
19-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
20-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
21-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
22-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
23-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
24-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
25-Mar	OFF	OFF	OFF	OFF	OFF	0.068	0.068	
26-Mar	0.013	0.014	0.015	0.015	0.015	0.016	0.016	
27-Mar	0.017	0.020	0.019	0.019	OFF	OFF	0.020	
28-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
29-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
30-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
31-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of 4-hour turbidity readings ≤ 0.3 NTU?			<input checked="" type="radio"/> Yes / No		CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All 4-hour turbidity readings ≤ 1 NTU?			<input checked="" type="radio"/> Yes / No		<input checked="" type="radio"/> Yes / No		<input checked="" type="radio"/> Yes / No	
All turbidity readings < IFE ² triggers			<input checked="" type="radio"/> Yes / No					
Notes:				PRINTED NAME: Curtis Olson				
				SIGNATURE: <i>Curtis Olson</i>			4/7/2025	
				PHONE #: (503) 554-8333			CERT #: T216644	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - : A	Inactivation
System Name:	Beverly Beach Water District	ID#: 41	00568	Month/Year:	Mar-25	Disinfection <i>Giardia</i> Log Inactive:	1	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Mar	OFF							
2-Mar	OFF							
3-Mar	OFF							
4-Mar	OFF							
5-Mar	1.2	70	84.0	10.0	7.6	48.7	Yes	50
6-Mar	1.5	70	91.0	10.0	7.6	50.4	Yes	50
7-Mar	OFF							
8-Mar	OFF							
9-Mar	OFF							
10-Mar	OFF							
11-Mar	1.7	70	118.0	12.0	7.7	46.8	Yes	50
12-Mar	1.4	70	98.0	12.0	7.5	42.1	Yes	50
13-Mar	OFF							
14-Mar	OFF							
15-Mar	OFF							
16-Mar	0.9	70	63.0	11.0	7.4	41.1	Yes	50
17-Mar	1.3	70	91.0	10.0	7.3	44.3	Yes	50
18-Mar	1.4	70	98.0	10.0	7.5	48.1	Yes	50
19-Mar	OFF							
20-Mar	OFF							
21-Mar	OFF							
22-Mar	OFF							
23-Mar	OFF							
24-Mar	OFF							
25-Mar	1.1	70	77.0	12.0	7.2	36.7	Yes	50
26-Mar	1.6	70	112.0	12.0	7.3	40.2	Yes	50
27-Mar	1.3	70	91.0	12.0	7.5	41.7	Yes	50
28-Mar	OFF							
29-Mar	OFF							
30-Mar	OFF							
31-Mar	OFF							

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018