

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Lincoln

Conventional or Direct Filtration

Month/Year:

Apr-25

System Name: Beverly Beach Water District			ID#: 41 00568			WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	12 PM [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2-Apr	OFF	OFF	OFF	OFF	0.231	0.031	0.231
3-Apr	0.480	0.052	0.059	0.045	0.029	0.027	0.480
4-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
5-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8-Apr	0.088	OFF	OFF	OFF	OFF	0.155	0.155
9-Apr	0.105	0.020	0.015	0.010	0.010	0.013	0.105
10-Apr	0.013	0.010	0.010	0.016	OFF	OFF	0.016
11-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16-Apr	OFF	OFF	OFF	OFF	OFF	0.038	0.038
17-Apr	0.029	0.048	0.041	0.032	0.019	0.021	0.048
18-Apr	0.025	0.032	0.036	0.022	0.013	OFF	0.036
19-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
22-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
23-Apr	OFF	OFF	OFF	OFF	0.050	0.040	0.050
24-Apr	0.060	0.091	0.110	0.070	0.045	0.040	0.110
25-Apr	0.060	0.081	0.095	0.070	0.042	0.045	0.095
26-Apr	0.065	0.085	0.110	OFF	OFF	OFF	0.110
27-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
30-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?			☒ Yes / No		CT's met everyday? (see back)		All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?			☒ Yes / No		☒ Yes / No		☒ Yes / No
All turbidity readings < IFE ² triggers			☒ Yes / No				
Notes:				PRINTED NAME: Curtis Olson			
				SIGNATURE: <i>Curtis Olson</i>			5/7/2025
				PHONE #: (503) 554-8333			CERT #: T216644

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - : A	Inactivation
System Name:	Beverly Beach Water District		ID#: 41	00568	Month/Year:	Apr-25	Disinfection <i>Giardia</i> Log Inactive:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Apr	OFF							
2-Apr	1.0	70	70.0	12	7.5	40.3	Yes	50
3-Apr	1.5	70	105.0	12.0	7.6	44.1	Yes	50
4-Apr	OFF							
5-Apr	OFF							
6-Apr	OFF							
7-Apr	OFF							
8-Apr	1.0	70	70.0	12.0	7.3	37.6	Yes	50
9-Apr	1.2	70	84.0	12.0	7.5	41.2	Yes	50
10-Apr	1.2	70	84.0	12.0	7.7	44.2	Yes	50
11-Apr	OFF							
12-Apr	OFF							
13-Apr	OFF							
14-Apr	OFF							
15-Apr	OFF							
16-Apr	0.8	70	56.0	13.0	7.5	36.6	Yes	50
17-Apr	1.2	70	84.0	12.0	7.8	45.8	Yes	50
18-Apr	1.3	70	91.0	12.0	7.8	46.3	Yes	50
19-Apr	OFF							
20-Apr	OFF							
21-Apr	OFF							
22-Apr	OFF							
23-Apr	0.8	70	56.0	12.0	7.7	42.3	Yes	50
24-Apr	1.0	70	70.0	11.0	7.4	41.6	Yes	50
25-Apr	1.0	70	70.0	11.0	7.2	38.8	Yes	50
26-Apr	1.1	70	77.0	12.0	7.3	38.0	Yes	50
27-Apr	OFF							
28-Apr	OFF							
29-Apr	OFF							
30-Apr	OFF							

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018