

OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County:

Lincoln

Month/Year:

May-25

System Name: Beverly Beach Water District		ID#: 41 00568		WTP : TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	12 PM [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1-May	0.19	OFF	OFF	OFF	OFF	OFF	0.19
2-May	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3-May	OFF	OFF	OFF	OFF	OFF	0.01	0.01
4-May	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5-May	0.01	0.02	0.07	0.17	OFF	OFF	0.17
6-May	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7-May	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8-May	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9-May	OFF	OFF	OFF	OFF	OFF	OFF	OFF
10-May	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11-May	OFF	0.01	0.01	0.01	0.01	0.02	0.02
12-May	0.03	0.05	0.06	0.07	0.07	0.07	0.07
13-May	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14-May	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15-May	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16-May	OFF	OFF	OFF	OFF	OFF	OFF	OFF
17-May	OFF	OFF	OFF	OFF	OFF	OFF	OFF
18-May	OFF	OFF	OFF	OFF	0.04	OFF	0.04
19-May	0.02	0.02	0.02	0.03	0.06	OFF	0.06
20-May	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21-May	OFF	OFF	OFF	OFF	OFF	OFF	OFF
22-May	0.07	0.08	0.07	0.06	0.03	0.03	0.08
23-May	0.03	0.03	0.03	0.03	0.08	0.17	0.17
24-May	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25-May	OFF	OFF	OFF	OFF	OFF	OFF	OFF
26-May	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27-May	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28-May	OFF	OFF	OFF	OFF	0.080	0.030	0.08
29-May	0.04	0.04	0.04	0.07	0.10	0.13	0.13
30-May	0.18	0.19	0.17	OFF	OFF	OFF	0.19
31-May	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?			☒ Yes / No	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All 4-hour turbidity readings ≤ 1 NTU?			☒ Yes / No	☒ Yes / No		☒ Yes / No	
All turbidity readings < IFE ² triggers			☒ Yes / No				
Notes:				PRINTED NAME: Curtis Olson			
				SIGNATURE: <i>Curtis Olson</i>			6/8/2025
				PHONE #: (503) 554-8333			CERT #: T216644

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - : A	Inactivation
System Name:	Beverly Beach Water District	ID#: 41	00568	Month/Year:	May-25	Disinfection <i>Giardia</i> Log Inactive:	1	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-May	0.7	68	47.6	11.0	7.3	38.8	Yes	50
2-May	OFF							
3-May	0.9	70	63.0	11.0	7.4	41.1	Yes	50
4-May	1.1	70	77.0	11.0	7.6	45.1	Yes	50
5-May	1.1	70	77.0	11.0	7.6	45.1	Yes	50
6-May	OFF							
7-May	OFF							
8-May	OFF							
9-May	OFF							
10-May	OFF							
11-May	1.2	70	84.0	12.0	7.5	41.2	Yes	50
12-May	1.3	70	91.0	13.0	7.5	38.7	Yes	50
13-May	OFF							
14-May	OFF							
15-May	OFF							
16-May	OFF							
17-May	OFF							
18-May	0.7	70	49.0	13.0	7.4	34.9	Yes	50
19-May	1.1	71	78.1	13.0	7.4	36.5	Yes	50
20-May	OFF							
21-May	OFF							
22-May	1.1	69	75.9	13.0	7.4	36.5	Yes	50
23-May	1.2	70	84.0	13.0	7.5	38.3	Yes	50
24-May	OFF							
25-May	OFF							
26-May	OFF							
27-May	OFF							
28-May	0.8	70	56.0	13.0	7.3	34.0	Yes	50
29-May	1.2	70	84.0	13.0	7.3	35.6	Yes	50
30-May	1.0	70	70.0	13.0	7.2	33.5	Yes	50
31-May	OFF							

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018