

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Lincoln

Conventional or Direct Filtration

Month/Year:

Jun-25

System Name: Beverly Beach Water District			ID#: 41 00568			WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	12 PM [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF
4-Jun	OFF	OFF	OFF	OFF	OFF	0.04	0.04
5-Jun	0.10	0.02	0.02	0.02	0.02	0.02	0.10
6-Jun	0.05	0.15	0.24	OFF	OFF	OFF	0.244
7-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9-Jun	OFF	0.02	0.01	0.01	0.01	0.01	0.02
10-Jun	0.02	0.04	0.11	0.23	OFF	OFF	0.23
11-Jun	OFF	0.01	0.01	0.02	0.02	0.02	0.02
12-Jun	0.04	0.03	OFF	OFF	OFF	OFF	0.04
13-Jun	0.25	0.23	OFF	OFF	OFF	OFF	0.25
14-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF
17-Jun	0.07	0.15	0.14	0.15	0.10	0.080	0.15
18-Jun	0.08	0.08	0.09	0.19	0.12	0.13	0.19
19-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF
22-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF
23-Jun	0.17	OFF	OFF	OFF	OFF	0.17	0.17
24-Jun	0.05	0.03	0.03	0.03	0.04	0.13	0.13
25-Jun	0.15	0.24	0.23	OFF	OFF	OFF	0.24
26-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27-Jun	OFF	0.06	0.05	0.04	0.03	0.03	0.06
28-Jun	0.04	0.07	0.15	0.25	OFF	OFF	0.25
29-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF
30-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?			☒ Yes / No		CT's met everyday? (see back)		All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?			☒ Yes / No		☒ Yes / No		☒ Yes / No
All turbidity readings < IFE ² triggers			☒ Yes / No				
Notes:				PRINTED NAME: Curtis Olson			
				SIGNATURE: <i>Curtis Olson</i>			7/10/2025
				PHONE #: (503) 554-8333			CERT #: T216644

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - : A	Inactivation
System Name:	Beverly Beach Water District		ID#: 41	00568	Month/Year:	Jun-25	Disinfection <i>Giardia</i> Log Inactive:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Jun	OFF							
2-Jun	OFF							
3-Jun	OFF							
4-Jun	0.9	70	63.0	13.0	7.3	34.4	Yes	50
5-Jun	1.2	70	84.0	14.0	7.4	34.5	Yes	50
6-Jun	1.1	70	77.0	15.0	7.4	32.0	Yes	50
7-Jun	OFF							
8-Jun	OFF							
9-Jun	1.4	70	98.0	15.0	7.3	31.9	Yes	50
10-Jun	1.3	70	91.0	14.0	7.4	34.9	Yes	50
11-Jun	1.5	70	105.0	15.0	7.4	33.4	Yes	50
12-Jun	1.4	70	98.0	14.0	7.4	35.3	Yes	50
13-Jun	1.2	70	84.0	14.0	7.4	34.5	Yes	50
14-Jun	OFF							
15-Jun	OFF							
16-Jun	OFF							
17-Jun	1.2	70	84.0	14.0	7.4	34.5	Yes	50
18-Jun	1.2	70	84.0	14.0	7.3	33.3	Yes	50
19-Jun	OFF							
20-Jun	OFF							
21-Jun	OFF							
22-Jun	OFF							
23-Jun	0.7	70	49.0	14.0	7.4	32.6	Yes	50
24-Jun	1.1	70	77.0	14.0	7.3	32.9	Yes	50
25-Jun	1.0	70	70.0	15.0	7.3	30.4	Yes	50
26-Jun	OFF							
27-Jun	1.3	70	91.0	15.0	7.3	31.5	Yes	50
28-Jun	1.1	70	77.0	16.0	7.3	28.8	Yes	50
29-Jun	OFF							
30-Jun	OFF							

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018