

OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County:

Lincoln

Month/Year:

Jul-25

System Name:		Beverly Beach Water District			ID#: 41 00568		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	12 PM [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
2-Jul	OFF	0.08	0.07	0.06	0.05	0.04	0.080	
3-Jul	0.38	0.84	0.11	0.18	OFF	OFF	0.84	
4-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
5-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
6-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
7-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
8-Jul	OFF	0.05	0.04	0.05	0.03	0.02	0.05	
9-Jul	0.06	0.14	0.23	OFF	OFF	OFF	0.23	
10-Jul	OFF	0.07	0.06	0.04	0.04	0.04	0.07	
11-Jul	0.050	0.10	OFF	OFF	OFF	OFF	0.10	
12-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
13-Jul	OFF	OFF	OFF	0.23	0.11	0.09	0.23	
14-Jul	0.08	0.08	0.08	0.08	0.10	0.14	0.140	
15-Jul	0.16	0.17	0.18	OFF	OFF	OFF	0.175	
16-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
17-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
18-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
19-Jul	OFF	0.16	0.16	0.15	0.13	0.03	0.16	
20-Jul	0.03	0.10	0.18	0.24	OFF	OFF	0.240	
21-Jul	0.22	0.26	OFF	OFF	OFF	OFF	0.260	
22-Jul	0.22	0.26	OFF	OFF	OFF	OFF	0.26	
23-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
24-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
25-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
26-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
27-Jul	0.04	0.04	0.09	0.13	OFF	OFF	0.13	
28-Jul	0.07	0.04	0.04	0.04	0.04	0.18	0.18	
29-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
30-Jul	OFF	OFF	OFF	0.05	0.04	0.04	0.05	
31-Jul	0.07	0.11	0.16	0.25	OFF	OFF	0.25	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of 4-hour turbidity readings ≤ 0.3 NTU?				☒ Yes / No		CT's met everyday? (see back)		
All 4-hour turbidity readings ≤ 1 NTU?				☒ Yes / No		All Cl2 residual at entry point ≥ 0.2 mg/l?		
All turbidity readings < IFE ² triggers				☒ Yes / No		☒ Yes / No		
Notes:				PRINTED NAME: Curtis Olson				
				SIGNATURE: <i>Curtis Olson</i>			8/10/2025	
				PHONE #: (503) 554-8333			CERT #: T216644	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - : A	Inactivation
System Name:	Beverly Beach Water District		ID#: 41	00568	Month/Year:	Jul-25	Disinfection <i>Giardia</i> Log Inactive:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Jul	OFF							
2-Jul	1.3	70	91.0	15.0	7.4	32.7	Yes	50
3-Jul	1.2	70	84.0	15.0	7.4	32.3	Yes	50
4-Jul	OFF							
5-Jul	OFF							
6-Jul	OFF							
7-Jul	OFF							
8-Jul	1.5	70	105.0	15.0	7.5	34.7	Yes	50
9-Jul	1.0	70	70.0	16.0	7.4	29.6	Yes	50
10-Jul	1.3	70	91.0	16.0	7.4	30.6	Yes	50
11-Jul	1.2	70	84.0	15.0	7.4	32.3	Yes	50
12-Jul	OFF							
13-Jul	0.8	70	56.0	16.0	7.4	28.9	Yes	50
14-Jul	1.4	70	98.0	16.0	7.5	32.1	Yes	50
15-Jul	1.0	70	70.0	16.0	7.5	30.7	Yes	50
16-Jul	OFF							
17-Jul	OFF							
18-Jul	OFF							
19-Jul	1.2	71	85.2	15.0	7.5	33.5	Yes	50
20-Jul	1.0	72	72.0	15.0	7.4	31.6	Yes	50
21-Jul	1.1	73	80.3	15.0	7.4	32.0	Yes	50
22-Jul	1.3	69	89.7	16.0	7.5	31.7	Yes	50
23-Jul	OFF							
24-Jul	OFF							
25-Jul	OFF							
26-Jul	0.4	70	28.0	18.0	7.3	23.3	Yes	50
27-Jul	1.0	70	70.0	16.0	7.4	29.6	Yes	50
28-Jul	1.1	70	77.0	16.0	7.4	29.9	Yes	50
29-Jul	OFF							
30-Jul	0.4	70	28.0	17.0	7.3	24.9	Yes	50
31-Jul	0.9	71	63.9	17.0	7.2	25.4	Yes	50

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018