

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Lincoln

Conventional or Direct Filtration

Month/Year:

Aug-25

System Name: Beverly Beach Water District		ID#: 41 00568		WTP : TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	12 PM [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3-Aug	OFF	0.21	0.09	0.08	0.07	0.06	0.21
4-Aug	0.15	0.21	0.26	OFF	OFF	OFF	0.26
5-Aug	OFF	OFF	OFF	OFF	0.05	0.03	0.05
6-Aug	0.04	0.04	0.07	0.10	0.22	0.26	0.260
7-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8-Aug	OFF	OFF	OFF	0.07	0.04	0.04	0.07
9-Aug	0.05	0.09	0.15	0.22	0.29	OFF	0.29
10-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12-Aug	OFF	0.04	0.04	0.04	0.04	0.04	0.04
13-Aug	0.08	0.14	0.180	0.26	OFF	OFF	0.26
14-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
17-Aug	0.16	OFF	OFF	OFF	OFF	OFF	0.16
18-Aug	OFF	OFF	OFF	OFF	0.06	0.05	0.06
19-Aug	0.04	0.04	0.04	0.04	0.07	0.08	0.08
20-Aug	0.10	0.10	0.10	0.14	0.23	0.22	0.230
21-Aug	0.19	0.21	0.14	0.15	OFF	OFF	0.210
22-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
23-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
24-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25-Aug	OFF	OFF	0.04	0.04	0.04	0.03	0.04
26-Aug	0.04	0.03	0.04	0.07	0.06	0.07	0.070
27-Aug	0.07	OFF	OFF	OFF	OFF	OFF	0.07
28-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29-Aug	OFF	OFF	0.12	0.12	0.15	0.15	0.15
30-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
31-Aug	0.14	0.04	0.03	0.03	0.03	0.03	0.14
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?			☒ Yes / No	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All 4-hour turbidity readings ≤ 1 NTU?			☒ Yes / No	☒ Yes / No		☒ Yes / No	
All turbidity readings < IFE ² triggers			☒ Yes / No				
Notes:				PRINTED NAME: Curtis Olson			
				SIGNATURE: <i>Curtis Olson</i>		9/10/2025	
				PHONE #: (503) 554-8333		CERT #: T216644	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - : A	Inactivation
System Name:	Beverly Beach Water District	ID#: 41	00568	Month/Year:	Aug-25	Disinfection <i>Giardia</i> Log Inactive:	1	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Aug	OFF							
2-Aug	OFF							
3-Aug	1.0	70	70.0	16.0	7.3	28.5	Yes	50
4-Aug	1.2	70	84.0	17.0	7.4	28.3	Yes	50
5-Aug	1.5	70	105.0	17.0	7.4	29.3	Yes	50
6-Aug	1.2	70	84.0	16.0	7.4	30.2	Yes	50
7-Aug	OFF							
8-Aug	0.4	70	28.0	18.0	7.4	24.1	Yes	50
9-Aug	0.7	70	49.0	15.0	7.4	30.5	Yes	50
10-Aug	OFF							
11-Aug	OFF							
12-Aug	0.7	70	49.0	16.0	7.4	28.6	Yes	50
13-Aug	1.0	70	70.0	17.0	7.3	26.6	Yes	50
14-Aug	OFF							
15-Aug	OFF							
16-Aug	OFF							
17-Aug	0.5	70	35.0	16.0	7.3	26.9	Yes	50
18-Aug	0.8	70	56.0	16.0	7.4	28.9	Yes	50
19-Aug	1.0	71	71.0	16.0	7.4	29.6	Yes	50
20-Aug	0.6	72	43.2	16.0	7.3	27.2	Yes	50
21-Aug	0.9	73	65.7	16.0	7.4	29.2	Yes	50
22-Aug	OFF							
23-Aug	OFF							
24-Aug	OFF							
25-Aug	1.2	70	84.0	16.0	7.4	30.2	Yes	50
26-Aug	1.5	70	105.0	16.0	7.4	31.3	Yes	50
27-Aug	1.1	70	77.0	16.0	7.3	28.8	Yes	50
28-Aug	OFF							
29-Aug	1.3	70	91.0	16.0	7.4	30.6	Yes	50
30-Aug	OFF							
31-Aug	1.3	71	92.3	15.0	7.4	32.7	Yes	50

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name: Beverly Beach WDID# 41 00568Month/Year: Sep / 2025Minimum UVT [%] during month: 91.4Duty sensor variation from reference sensor %: 1.00%Minimum Validated UVT : 92%

<20% required, <10% recommended

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[^{mW} /cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	OFF					
2	OFF					
3	OFF					
4	OFF					
5	OFF					
6	OFF					
7	OFF					
8	OFF					
9	OFF					
10	OFF					
11	OFF					
12	OFF					
13	OFF					
14	OFF					
15	OFF					
16	OFF					
17	OFF					
18	OFF					
19	OFF					
20	OFF					
21	OFF					
22	OFF					
23	OFF					
24	OFF					
25	50	3.52	Y	59,810	0	0.00%
26	50	2.54	Y	73,610	0	0.00%
27	50	3.61	Y	245	0	0.00%
28	OFF					
29	50	3.74	Y	48,650	0	0.00%
30	OFF					
31	50	2.56	Y	72,926	0	0.00%
Monthly Cumulative % Off-Spec Water Produced						0.00%

Must be less than 5%

Signature: Curtis OlsonOp Cert #: T216644Date: 9/10/2025