

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Lincoln

Conventional or Direct Filtration

Month/Year: Nov-25

System Name:	Beverly Beach Water District			ID#: 41 00568			WTP : TP -	A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	12 PM [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1-Nov	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
2-Nov	OFF	OFF	OFF	0.02	0.02	0.02	0.02	
3-Nov	0.03	0.03	0.10	0.11	0.14	OFF	0.14	
4-Nov	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
5-Nov	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
6-Nov	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
7-Nov	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
8-Nov	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
9-Nov	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
10-Nov	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
11-Nov	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
12-Nov	0.03	0.03	0.03	0.02	0.03	0.05	0.05	
13-Nov	0.11	OFF	OFF	OFF	OFF	OFF	0.11	
14-Nov	OFF	OFF	OFF	0.11	0.08	0.04	0.11	
15-Nov	0.03	0.03	0.03	0.03	0.15	OFF	0.15	
16-Nov	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
17-Nov	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
18-Nov	OFF	OFF	OFF	OFF	OFF	0.07	0.07	
19-Nov	0.04	0.03	0.03	0.04	0.05	0.08	0.08	
20-Nov	0.03	OFF	OFF	OFF	OFF	OFF	0.030	
21-Nov	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
22-Nov	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
23-Nov	OFF	0.09	0.03	0.04	0.06	0.09	0.09	
24-Nov	0.10	0.10	0.11	OFF	OFF	OFF	0.11	
25-Nov	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
26-Nov	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
27-Nov	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
28-Nov	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
29-Nov	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
30-Nov	OFF	OFF	OFF	OFF	OFF	OFF	OFF	

Conventional or Direct Filtration			Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes	<input type="radio"/> No		

Notes:

PRINTED NAME: Curtis Olson	
SIGNATURE: <i>Curtis Olson</i>	12/5/2025
PHONE #: (503) 554-8333	CERT #: T216644

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - : A	Inactivation
System Name:	Beverly Beach Water District		ID#: 41	00568	Month/Year:	Nov-25	Disinfection <i>Giardia</i> Log Inactive:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Nov	OFF							
2-Nov	1.3	70	91.0	13.0	7.3	36.0	Yes	50
3-Nov	1.5	70	105.0	13.0	7.8	44.3	Yes	50
4-Nov	OFF							
5-Nov	OFF							
6-Nov	OFF							
7-Nov	OFF							
8-Nov	OFF							
9-Nov	OFF							
10-Nov	OFF							
11-Nov	1.0	70	70.0	13.0	7.6	38.9	Yes	50
12-Nov	1.5	70	105.0	14.0	7.8	41.4	Yes	50
13-Nov	1.2	70	84.0	14.0	7.8	40.0	Yes	50
14-Nov	1.4	70	98.0	14.0	7.9	42.5	Yes	50
15-Nov	1.5	70	105.0	13.0	7.8	44.3	Yes	50
16-Nov	OFF							
17-Nov	OFF							
18-Nov	1.0	70	70.0	11.0	7.6	44.6	Yes	50
19-Nov	1.1	71	78.1	11.0	7.8	48.4	Yes	50
20-Nov	1.3	72	93.6	11.0	7.7	47.8	Yes	50
21-Nov	OFF							
22-Nov	OFF							
23-Nov	1.5	70	105.0	12.0	7.8	47.4	Yes	50
24-Nov	1.4	70	98.0	11.0	8.0	53.8	Yes	50
25-Nov	OFF							
26-Nov	OFF							
27-Nov	OFF							
28-Nov	OFF							
29-Nov	OFF							
30-Nov	OFF							

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name: Beverly Beach WD **ID#** 41 00568 **Month/Year:** Nov / 2025
Minimum UVT [%] during month: 93.3 **Duty sensor variation from reference sensor %:** 1.00%
Minimum Validated UVT : 92% <20% required, <10% recommended

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[^{mW} /cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	OFF					
2	50	2.55	Y	34,934	0	0.00%
3	50	2.24	Y	46,354	0	0.00%
4	OFF					
5	OFF					
6	OFF					
7	OFF					
8	OFF					
9	OFF					
10	OFF					
11	50	2.87	Y	15,576	0	0.00%
12	50	2.47	Y	62,968	0	0.00%
13	50	2.56	Y	9,912	0	0.00%
14	50	2.78	Y	41,024	0	0.00%
15	50	2.54	Y	50,596	0	0.00%
16	OFF					
17	OFF					
18	50	2.48	Y	18,655	0	0.00%
19	50	2.46	Y	63,564	0	0.00%
20	50	4.08	Y	2,073	0	0.00%
21	OFF					
22	OFF					
23	50	2.29	Y	65,586	0	0.00%
24	50	2.56	Y	26,234	0	0.00%
25	OFF					
26	OFF					
27	OFF					
28	OFF					
29	OFF					
30	OFF					
Monthly Cumulative % Off-Spec Water Produced						0.01%

Must be less than 5%

Signature: Curtis Olson

Op Cert #: T216644

Date: 12/5/2025