

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Lincoln

Conventional or Direct Filtration

Month/Year: Dec-25

System Name: Beverly Beach Water District		ID#: 41 00568		WTP : TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	12 PM [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3-Dec	OFF	OFF	OFF	OFF	OFF	0.022	0.022
4-Dec	0.018	0.018	0.017	0.021	0.022	0.030	0.030
5-Dec	0.05	0.12	0.18	OFF	OFF	OFF	0.180
6-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
10-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13-Dec	OFF	0.035	0.023	OFF	OFF	OFF	0.035
14-Dec	OFF	OFF	OFF	OFF	0.02	0.02	0.023
15-Dec	0.019	0.021	0.018	0.022	0.020	0.019	0.022
16-Dec	0.105	0.023	0.096	OFF	OFF	OFF	0.105
17-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
18-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
19-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
22-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
23-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
24-Dec	OFF	OFF	OFF	OFF	0.024	0.026	0.026
25-Dec	0.029	0.032	OFF	OFF	OFF	OFF	0.032
26-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
30-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF
31-Dec	OFF	OFF	OFF	OFF	0.034	0.038	0.038

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:		PRINTED NAME: Curtis Olson	
		SIGNATURE: <i>Curtis Olson</i>	1/10/2026
		PHONE #: (503) 554-8333	CERT #: T216644

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - : A	Inactivation
System Name:	Beverly Beach Water District		ID#: 41	00568	Month/Year:	Dec-25	Disinfection <i>Giardia</i> Log Inactive:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Dec	OFF							
2-Dec	OFF							
3-Dec	0.7	70	49.0	12.0	7.4	37.6	Yes	50
4-Dec	1.6	70	112.0	12.0	7.8	47.9	Yes	50
5-Dec	1.5	70	105.0	12.0	7.8	47.4	Yes	50
6-Dec	OFF							
7-Dec	OFF							
8-Dec	OFF							
9-Dec	OFF							
10-Dec	OFF							
11-Dec	OFF							
12-Dec	OFF							
13-Dec	1.5	70	105.0	13.0	7.8	44.3	Yes	50
14-Dec	1.3	70	91.0	12.0	7.7	44.7	Yes	50
15-Dec	1.6	70	112.0	13.0	7.9	46.4	Yes	50
16-Dec	1.4	70	98.0	13.0	7.8	43.8	Yes	50
17-Dec	OFF							
18-Dec	OFF							
19-Dec	OFF							
20-Dec	OFF							
21-Dec	OFF							
22-Dec	OFF							
23-Dec	OFF							
24-Dec	0.8	70	56.0	12.0	7.9	45.3	Yes	50
25-Dec	1.3	70	91.0	12.0	7.7	44.7	Yes	50
26-Dec	OFF							
27-Dec	OFF							
28-Dec	OFF							
29-Dec	OFF							
30-Dec	OFF							
31-Dec	0.9	70	63.0	12.0	7.5	39.9	Yes	50

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name: Beverly Beach WD **ID#** 41 00568 **Month/Year:** Dec / 2025
Minimum UVT [%] during month: 94.8 **Duty sensor variation from reference sensor %:** 1.00%
Minimum Validated UVT : 92% <20% required, <10% recommended

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[mW/cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	OFF					
2	OFF					
3	50	4.12	Y	21,446	0	0.00%
4	50	2.56	Y	66,413	0	0.00%
5	50	2.67	Y	24,213	0	0.00%
6	OFF					
7	OFF					
8	OFF					
9	OFF					
10	OFF					
11	OFF					
12	OFF					
13	50	3.44	Y	11,207	0	0.00%
14	50	3.63	Y	27,328	0	0.00%
15	50	2.56	Y	65,587	0	0.00%
16	50	2.96	Y	28,695	0	0.00%
17	OFF					
18	OFF					
19	OFF					
20	OFF					
21	OFF					
22	OFF					
23	OFF					
24	50	2.56	Y	24,647	0	0.00%
25	50	4.13	Y	16,653	0	0.00%
26	OFF					
27	OFF					
28	OFF					
29	OFF					
30	OFF					
31	50	3.61	Y	0	0	

Monthly Cumulative % Off-Spec Water Produced	0.00%
--	-------

Must be less than 5%

Signature: Curtis Olson **Op Cert #:** T216644 **Date:** 01/10/2026