

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Lincoln

Conventional or Direct Filtration

Month/Year: Jan-26

System Name: Beverly Beach Water District		ID#: 41 00568		WTP : TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	12 PM [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1-Jan	0.04	0.04	OFF	OFF	OFF	OFF	0.04
2-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
4-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
5-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
10-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
17-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
18-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
19-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21-Jan	OFF	OFF	OFF	OFF	OFF	0.029	0.029
22-Jan	0.031	0.031	0.038	0.041	0.047	0.043	0.05
23-Jan	0.052	0.056	0.058	0.078	0.066	0.092	0.09
24-Jan	0.233	OFF	OFF	OFF	OFF	OFF	0.233
25-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF
26-Jan	OFF	OFF	OFF	OFF	0.088	0.231	0.231
27-Jan	OFF	OFF	0.131	0.247	OFF	OFF	0.25
28-Jan	OFF	0.086	0.064	0.033	0.026	0.023	0.09
29-Jan	0.021	0.023	0.027	0.025	0.023	0.022	0.03
30-Jan	0.019	0.022	0.025	0.023	0.032	0.048	0.05
31-Jan	0.140	OFF	OFF	OFF	OFF	OFF	0.140

Conventional or Direct Filtration			Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No		CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No		<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No			
Notes:			PRINTED NAME: Curtis Olson	
			SIGNATURE: <i>Curtis Olson</i>	2/8/2026
			PHONE #: (503) 554-8333	CERT #: T216644

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - : A	Inactivation
System Name:	Beverly Beach Water District		ID#: 41	00568	Month/Year:	Jan-26	Disinfection <i>Giardia</i> Log Inactive:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Jan	1.4	68	95.2	12.0	7.8	46.8	Yes	50
2-Jan	OFF							
3-Jan	OFF							
4-Jan	OFF							
5-Jan	OFF							
6-Jan	OFF							
7-Jan	OFF							
8-Jan	OFF							
9-Jan	OFF							
10-Jan	OFF							
11-Jan	OFF							
12-Jan	OFF							
13-Jan	OFF							
14-Jan	OFF							
15-Jan	OFF							
16-Jan	OFF							
17-Jan	OFF							
18-Jan	OFF							
19-Jan	OFF							
20-Jan	OFF							
21-Jan	0.8	73	58.4	10.0	7.9	51.8	Yes	50
22-Jan	1.7	69	117.3	10.0	8.0	59.6	Yes	50
23-Jan	1.8	70	126.0	11.0	7.1	40.9	Yes	50
24-Jan	1.6	70	112.0	11.0	7.5	46.1	Yes	50
25-Jan	OFF							
26-Jan	1.1	70	77.0	11.0	7.2	39.2	Yes	50
27-Jan	1.0	70	70.0	11.0	7.3	40.1	Yes	50
28-Jan	1.6	70	112.0	12.0	7.2	38.8	Yes	50
29-Jan	1.4	70	98.0	13.0	7.6	41.1	Yes	50
30-Jan	1.7	70	119.0	12.0	7.8	48.5	Yes	50
31-Jan	1.9	70	133.0	12.0	7.9	51.4	Yes	50

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018