


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: 01/2021							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.23	N/A	N/A	N/A	0.23
2	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
3	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
4	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
5	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
6	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
7	N/A	N/A	0.24	N/A	N/A	N/A	0.24
8	N/A	N/A	0.29	N/A	N/A	N/A	0.29
9	N/A	N/A	0.37	N/A	N/A	N/A	0.37
10	N/A	N/A	0.34	N/A	N/A	N/A	0.34
11	N/A	N/A	0.36	N/A	N/A	N/A	0.36
12	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
13	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
14	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
15	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
16	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
17	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
18	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
19	N/A	N/A	0.24	N/A	N/A	N/A	0.24
20	N/A	N/A	0.24	N/A	N/A	N/A	0.24
21	N/A	N/A	0.28	N/A	N/A	N/A	0.28
22	N/A	N/A	0.44	N/A	N/A	N/A	0.44
23	N/A	N/A	0.23	N/A	N/A	N/A	0.23
24	N/A	N/A	0.21	N/A	N/A	N/A	0.21
25	N/A	N/A	0.20	N/A	N/A	N/A	0.20
26	N/A	N/A	0.21	N/A	N/A	N/A	0.21
27	N/A	N/A	0.23	N/A	N/A	N/A	0.23
28	N/A	N/A	0.20	N/A	N/A	N/A	0.20
29	N/A	N/A	0.27	N/A	N/A	N/A	0.27
30	N/A	N/A	0.24	N/A	N/A	N/A	0.24
31	N/A	N/A	0.20	N/A	N/A	N/A	0.20
<b>Slow Sand/Membrane/DE Filtration/ Unfiltered</b>				<b>Monthly Summary</b>			
95% of daily turbidity readings ≤ 1 NTU? <b>YES</b>				CT's met everyday? (see back) <b>YES</b>		All CL2 residual at entry point ≥ 0.2 mg/l? <b>YES</b>	
All daily readings ≤ 5 NTU? <b>YES</b>				PRINTED NAME: <b>Joe Rogers</b>			
Notes:				SIGNATURE 		DATE: 1/31/2021	
				PHONE #: (503) -723-3505		CERT #: T-09162	

**OHA - Drinking Water Program - Surface Water Quality Data Form**

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: 01/2021

**SLOW SAND FILTERS**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
01/01/21	6:00AM	1.67	91	152	7.4	7.8	64	Yes	3471
01/02/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
01/03/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
01/04/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
01/05/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
01/06/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
01/07/21	6:00AM	1.75	201	352	8.5	8.9	91	Yes	1495
01/08/21	6:00AM	1.93	118	229	8.1	8.1	71	Yes	2475
01/09/21	6:00AM	1.78	95	170	8.2	7.8	62	Yes	3302
01/10/21	6:00AM	1.72	91	157	7.3	7.8	65	Yes	3494
01/11/21	6:00AM	1.70	90	152	7.7	8.0	68	Yes	3474
01/12/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
01/13/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
01/14/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
01/15/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
01/16/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
01/17/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
01/18/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
01/19/21	6:00AM	1.75	104	182	7.4	7.5	58	Yes	2782
01/20/21	6:00AM	1.76	87	154	7.4	7.7	63	Yes	3481
01/21/21	6:00AM	1.79	84	150	6.8	7.7	65	Yes	3757
01/22/21	6:00AM	1.77	85	151	7.1	8.0	71	Yes	3780
01/23/21	6:00AM	1.68	86	144	6.5	7.9	70	Yes	3746
01/24/21	6:00AM	1.66	82	136	6.9	7.9	69	Yes	3753
01/25/21	6:00AM	1.66	90	150	6.5	7.8	67	Yes	3482
01/26/21	6:00AM	1.76	84	148	6.5	7.8	68	Yes	3746
01/27/21	6:00AM	1.76	86	151	6.7	7.8	68	Yes	3765
01/28/21	6:00AM	1.66	86	142	6.4	7.9	70	Yes	3678
01/29/21	6:00AM	1.77	85	151	6.6	7.7	66	Yes	3828
01/30/21	6:00AM	1.65	85	140	6.6	7.9	70	Yes	3760
01/31/21	6:00AM	1.60	109	174	6.7	8.1	74	Yes	2826

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day