


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: March 2021								
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]	
1	N/A	N/A	0.26	N/A	N/A	N/A	0.26	
2	N/A	N/A	0.21	N/A	N/A	N/A	0.21	
3	N/A	N/A	0.18	N/A	N/A	N/A	0.18	
4	N/A	N/A	0.16	N/A	N/A	N/A	0.16	
5	N/A	N/A	0.15	N/A	N/A	N/A	0.15	
6	N/A	N/A	0.13	N/A	N/A	N/A	0.13	
7	N/A	N/A	0.16	N/A	N/A	N/A	0.16	
8	N/A	N/A	0.13	N/A	N/A	N/A	0.13	
9	N/A	N/A	0.13	N/A	N/A	N/A	0.13	
10	N/A	N/A	0.19	N/A	N/A	N/A	0.19	
11	N/A	N/A	0.20	N/A	N/A	N/A	0.20	
12	N/A	N/A	0.17	N/A	N/A	N/A	0.17	
13	N/A	N/A	0.14	N/A	N/A	N/A	0.14	
14	N/A	N/A	0.15	N/A	N/A	N/A	0.15	
15	N/A	N/A	0.13	N/A	N/A	N/A	0.13	
16	N/A	N/A	0.15	N/A	N/A	N/A	0.15	
17	N/A	N/A	0.15	N/A	N/A	N/A	0.15	
18	N/A	N/A	0.16	N/A	N/A	N/A	0.16	
19	N/A	N/A	0.13	N/A	N/A	N/A	0.13	
20	N/A	N/A	0.12	N/A	N/A	N/A	0.12	
21	N/A	N/A	0.14	N/A	N/A	N/A	0.14	
22	N/A	N/A	0.15	N/A	N/A	N/A	0.15	
23	N/A	N/A	0.16	N/A	N/A	N/A	0.16	
24	N/A	N/A	0.16	N/A	N/A	N/A	0.16	
25	N/A	N/A	0.16	N/A	N/A	N/A	0.16	
26	N/A	N/A	0.15	N/A	N/A	N/A	0.15	
27	N/A	N/A	0.13	N/A	N/A	N/A	0.13	
28	N/A	N/A	0.16	N/A	N/A	N/A	0.16	
29	N/A	N/A	0.11	N/A	N/A	N/A	0.11	
30	N/A	N/A	0.12	N/A	N/A	N/A	0.12	
31	N/A	N/A	0.15	N/A	N/A	N/A	0.15	
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary				
95% of daily turbidity readings \leq 1 NTU? YES All daily readings \leq 5 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point \geq 0.2 mg/l? YES		
Notes:				PRINTED NAME: Joe Rogers				
				SIGNATURE 			DATE 4-1-21	
				PHONE #: (503) -723-3505			CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-BI Month/Year: MARCH 2021

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
03/01/21	6:00 AM	1.59	89	142	7.7	7.9	65	Yes	3522
03/02/21	6:00 AM	1.50	87	131	7.7	8.0	66	Yes	3603
03/03/21	6:00 AM	1.48	93	137	7.7	8.0	66	Yes	3403
03/04/21	6:00 AM	1.49	89	133	8.1	7.8	60	Yes	3534
03/05/21	6:00 AM	1.46	88	129	8.4	7.8	58	Yes	3529
03/06/21	6:00 AM	1.44	88	126	7.5	7.7	59	Yes	3504
03/07/21	6:00 AM	1.43	91	130	7.7	7.7	58	Yes	3456
03/08/21	6:00 AM	1.57	88	138	7.9	7.9	64	Yes	3420
03/09/21	6:00 AM	1.50	91	136	7.5	7.9	65	Yes	3266
03/10/21	6:00 AM	1.51	86	130	7.8	7.8	61	Yes	3690
03/11/21	6:00 AM	1.45	84	122	8.1	7.7	57	Yes	3828
03/12/21	6:00 AM	1.44	86	123	8.2	7.9	61	Yes	3757
03/13/21	6:00 AM	1.44	85	122	7.5	7.8	62	Yes	3677
03/14/21	6:00 AM	1.44	96	139	8.1	7.7	57	Yes	3233
03/15/21	6:00 AM	1.45	93	135	7.3	8.1	70	Yes	3235
03/16/21	6:00 AM	1.42	87	123	7.0	8.0	68	Yes	3381
03/17/21	6:00 AM	1.46	90	131	7.6	7.9	64	Yes	3542
03/18/21	6:00 AM	1.46	89	130	7.9	7.9	63	Yes	3574
03/19/21	6:00 AM	1.45	89	129	7.8	7.8	61	Yes	3570
03/20/21	6:00 AM	1.45	94	136	8.1	7.9	62	Yes	3051
03/21/21	6:00 AM	1.40	96	134	8.1	7.9	61	Yes	3026
03/22/21	6:00 AM	1.44	92	132	7.9	7.9	62	Yes	3474
03/23/21	6:00 AM	1.47	84	123	8.0	8.1	67	Yes	3813
03/24/21	6:00 AM	1.44	81	117	9.0	7.9	58	Yes	4004
03/25/21	6:00 AM	1.47	82	121	8.4	7.9	61	Yes	3784
03/26/21	6:00 AM	1.45	93	134	8.7	7.8	57	Yes	3395
03/27/21	6:00 AM	1.46	90	131	9.1	7.8	56	Yes	3557
03/28/21	6:00 AM	1.40	88	123	9.1	8.1	62	Yes	3613
03/29/21	6:00 AM	1.43	92	131	8.3	7.9	61	Yes	3474
03/30/21	6:00 AM	1.44	93	134	8.7	7.8	57	Yes	3346
03/31/21	6:00 AM	1.48	95	141	8.8	7.9	59	Yes	3275

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day