


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: 4/2021							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.12	N/A	N/A	N/A	0.12
2	N/A	N/A	0.10	N/A	N/A	N/A	0.10
3	N/A	N/A	0.09	N/A	N/A	N/A	0.09
4	N/A	N/A	0.10	N/A	N/A	N/A	0.10
5	N/A	N/A	0.05	N/A	N/A	N/A	0.05
6	N/A	N/A	0.11	N/A	N/A	N/A	0.11
7	N/A	N/A	0.13	N/A	N/A	N/A	0.13
8	N/A	N/A	0.16	N/A	N/A	N/A	0.16
9	N/A	N/A	0.10	N/A	N/A	N/A	0.10
10	N/A	N/A	0.10	N/A	N/A	N/A	0.10
11	N/A	N/A	0.11	N/A	N/A	N/A	0.11
12	N/A	N/A	0.25	N/A	N/A	N/A	0.25
13	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
14	N/A	N/A	0.15	N/A	N/A	N/A	0.15
15	N/A	N/A	0.09	N/A	N/A	N/A	0.09
16	N/A	N/A	0.12	N/A	N/A	N/A	0.12
17	N/A	N/A	0.11	N/A	N/A	N/A	0.11
18	N/A	N/A	0.08	N/A	N/A	N/A	0.08
19	N/A	N/A	0.04	N/A	N/A	N/A	0.04
20	N/A	N/A	0.09	N/A	N/A	N/A	0.09
21	N/A	N/A	0.10	N/A	N/A	N/A	0.10
22	N/A	N/A	0.12	N/A	N/A	N/A	0.12
23	N/A	N/A	0.13	N/A	N/A	N/A	0.13
24	N/A	N/A	0.11	N/A	N/A	N/A	0.11
25	N/A	N/A	0.10	N/A	N/A	N/A	0.10
26	N/A	N/A	0.11	N/A	N/A	N/A	0.11
27	N/A	N/A	0.11	N/A	N/A	N/A	0.11
28	N/A	N/A	0.10	N/A	N/A	N/A	0.10
29	N/A	N/A	0.13	N/A	N/A	N/A	0.13
30	N/A	N/A	0.10	N/A	N/A	N/A	0.10
31	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings ≤ 1 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point ≥ 0.2 mg/l? YES	
All daily readings ≤ 5 NTU? YES				PRINTED NAME: Joe Rogers			
Notes:				SIGNATURE 		DATE: 5/1/2021	
				PHONE #: (503) 723-3505		CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: 4/2021

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
								Yes / No	
04/01/21	6:00AM	1.44	88	126	9.2	8.0	60	Yes	3595
04/02/21	6:00AM	1.40	87	122	9.9	7.6	48	Yes	3577
04/03/21	6:00AM	1.37	108	148	9.4	7.8	54	Yes	2818
04/04/21	6:00AM	1.40	99	138	9.7	8.0	57	Yes	3150
04/05/21	6:00AM	1.42	92	131	8.9	8.1	63	Yes	3147
04/06/21	6:00AM	1.50	68	103	9.4	7.8	55	Yes	4231
04/07/21	6:00AM	1.42	57	80	9.8	8.0	57	Yes	5892
04/08/21	6:00AM	1.36	88	119	8.5	8.0	62	Yes	3593
04/09/21	6:00AM	1.40	86	120	8.6	7.8	57	Yes	3675
04/10/21	6:00AM	1.42	79	112	9.3	7.6	51	Yes	4192
04/11/21	6:00AM	1.42	69	97	8.5	7.9	60	Yes	4748
04/12/21	6:00AM	1.37	79	108	8.9	7.9	58	Yes	4138
04/13/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
04/14/21	6:00AM	1.29	70	90	9.1	7.6	51	Yes	4565
04/15/21	6:00AM	1.45	82	119	10.6	7.7	49	Yes	4011
04/16/21	6:00AM	1.42	74	105	11.0	7.8	49	Yes	4518
04/17/21	6:00AM	1.48	67	100	10.9	7.7	48	Yes	4790
04/18/21	6:00AM	1.47	87	128	11.1	7.9	51	Yes	3579
04/19/21	6:00AM	1.33	94	125	11.2	7.7	46	Yes	3190
04/20/21	6:00AM	1.57	120	189	11.3	7.9	51	Yes	2345
04/21/21	6:00AM	1.35	98	132	11.4	7.9	49	Yes	3032
04/22/21	6:00AM	1.34	97	129	11.7	8.0	50	Yes	3074
04/23/21	6:00AM	1.35	100	134	10.5	7.7	48	Yes	3126
04/24/21	6:00AM	1.32	137	181	10.5	7.8	50	Yes	2108
04/25/21	6:00AM	1.26	115	145	9.9	8.2	61	Yes	2580
04/26/21	6:00AM	1.42	92	131	10.6	7.5	44	Yes	3380
04/27/21	6:00AM	1.37	86	117	10.1	7.9	54	Yes	3510
04/28/21	6:00AM	1.44	72	103	11.0	7.8	49	Yes	4442
04/29/21	6:00AM	1.60	70	112	11.1	7.8	50	Yes	4813
04/30/21	6:00AM	1.31	75	98	11.9	7.8	46	Yes	4601

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day