


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: 5/2021							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.11	N/A	N/A	N/A	0.11
2	N/A	N/A	0.08	N/A	N/A	N/A	0.08
3	N/A	N/A	0.08	N/A	N/A	N/A	0.08
4	N/A	N/A	0.08	N/A	N/A	N/A	0.08
5	N/A	N/A	0.09	N/A	N/A	N/A	0.09
6	N/A	N/A	0.09	N/A	N/A	N/A	0.09
7	N/A	N/A	0.08	N/A	N/A	N/A	0.08
8	N/A	N/A	0.10	N/A	N/A	N/A	0.10
9	N/A	N/A	0.13	N/A	N/A	N/A	0.13
10	N/A	N/A	0.08	N/A	N/A	N/A	0.08
11	N/A	N/A	0.08	N/A	N/A	N/A	0.08
12	N/A	N/A	0.08	N/A	N/A	N/A	0.08
13	N/A	N/A	0.08	N/A	N/A	N/A	0.08
14	N/A	N/A	0.09	N/A	N/A	N/A	0.09
15	N/A	N/A	0.10	N/A	N/A	N/A	0.10
16	N/A	N/A	0.09	N/A	N/A	N/A	0.09
17	N/A	N/A	0.09	N/A	N/A	N/A	0.09
18	N/A	N/A	0.07	N/A	N/A	N/A	0.07
19	N/A	N/A	0.07	N/A	N/A	N/A	0.07
20	N/A	N/A	0.07	N/A	N/A	N/A	0.07
21	N/A	N/A	0.08	N/A	N/A	N/A	0.08
22	N/A	N/A	0.09	N/A	N/A	N/A	0.09
23	N/A	N/A	0.09	N/A	N/A	N/A	0.09
24	N/A	N/A	0.06	N/A	N/A	N/A	0.06
25	N/A	N/A	0.07	N/A	N/A	N/A	0.07
26	N/A	N/A	0.07	N/A	N/A	N/A	0.07
27	N/A	N/A	0.07	N/A	N/A	N/A	0.07
28	N/A	N/A	0.08	N/A	N/A	N/A	0.08
29	N/A	N/A	0.07	N/A	N/A	N/A	0.07
30	N/A	N/A	0.07	N/A	N/A	N/A	0.07
31	N/A	N/A	0.08	N/A	N/A	N/A	0.08
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings \leq 1 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point \geq 0.2 mg/l? YES	
All daily readings \leq 5 NTU? YES				PRINTED NAME: Joe Rogers			
Notes:				SIGNATURE 		DATE: 6/1/2021	
				PHONE #: (503) -793-3505		CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: **5-2021**

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
05/01/21	0600AM	1.4	78	108	11.7	7.8	46	Yes	4178
05/02/21	0600AM	1.3	73	96	11.6	7.7	45	Yes	4490
05/03/21	0600AM	1.4	68	94	11.9	8.1	51	Yes	4531
05/04/21	0600AM	1.5	56	82	11.5	7.8	48	Yes	6011
05/05/21	0600AM	1.4	59	84	12.3	7.7	43	Yes	6443
05/06/21	0600AM	1.4	64	88	12.5	7.8	44	Yes	5579
05/07/21	0600AM	1.4	65	90	11.8	7.7	44	Yes	5368
05/08/21	0600AM	1.3	76	98	11.3	7.8	48	Yes	4177
05/09/21	0600AM	1.3	78	100	11.8	7.8	46	Yes	4189
05/10/21	0600AM	1.3	75	97	11.7	8.0	50	Yes	4064
05/11/21	0600AM	1.4	62	87	12.8	8.0	46	Yes	5320
05/12/21	0600AM	1.4	66	89	13.5	7.5	36	Yes	5270
05/13/21	0600AM	1.3	66	87	14.1	7.7	37	Yes	5283
05/14/21	0600AM	1.3	69	92	14.5	7.7	36	Yes	4954
05/15/21	0600AM	1.3	65	86	14.2	7.6	35	Yes	5195
05/16/21	0600AM	1.3	81	107	14.8	7.8	36	Yes	4043
05/17/21	0600AM	1.3	81	106	15.7	8.1	38	Yes	3826
05/18/21	0600AM	1.4	85	118	14.6	7.6	34	Yes	3696
05/19/21	0600AM	1.4	71	95	14.1	7.7	37	Yes	4352
05/20/21	0600AM	1.5	60	88	13.7	7.9	41	Yes	5069
05/21/21	0600AM	1.5	65	95	13.2	7.7	40	Yes	5322
05/22/21	0600AM	1.6	78	123	12.5	7.6	42	Yes	4186
05/23/21	0600AM	1.3	79	104	13.1	8.0	45	Yes	4195
05/24/21	0600AM	1.3	72	93	12.3	8.0	48	Yes	4200
05/25/21	0600AM	1.4	61	88	12.5	7.7	42	Yes	5244
05/26/21	0600AM	1.4	58	81	12.9	7.6	39	Yes	5527
05/27/21	0600AM	1.4	61	87	12.8	7.7	41	Yes	5565
05/28/21	0600AM	1.3	71	90	14.1	7.9	40	Yes	4714
05/29/21	0600AM	1.3	58	77	13.9	7.7	37	Yes	5574
05/30/21	0600AM	1.3	57	74	15.4	7.9	36	Yes	6257
05/31/21	0600AM	1.3	60	77	15.9	7.5	30	Yes	6251

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day