


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: June 2021							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.08	N/A	N/A	N/A	0.08
2	N/A	N/A	0.08	N/A	N/A	N/A	0.08
3	N/A	N/A	0.09	N/A	N/A	N/A	0.09
4	N/A	N/A	0.12	N/A	N/A	N/A	0.12
5	N/A	N/A	0.07	N/A	N/A	N/A	0.07
6	N/A	N/A	0.08	N/A	N/A	N/A	0.08
7	N/A	N/A	0.07	N/A	N/A	N/A	0.07
8	N/A	N/A	0.07	N/A	N/A	N/A	0.07
9	N/A	N/A	0.07	N/A	N/A	N/A	0.07
10	N/A	N/A	0.07	N/A	N/A	N/A	0.07
11	N/A	N/A	0.11	N/A	N/A	N/A	0.11
12	N/A	N/A	0.09	N/A	N/A	N/A	0.09
13	N/A	N/A	0.12	N/A	N/A	N/A	0.12
14	N/A	N/A	0.09	N/A	N/A	N/A	0.09
15	N/A	N/A	0.09	N/A	N/A	N/A	0.09
16	N/A	N/A	0.08	N/A	N/A	N/A	0.08
17	N/A	N/A	0.07	N/A	N/A	N/A	0.07
18	N/A	N/A	0.10	N/A	N/A	N/A	0.10
19	N/A	N/A	0.09	N/A	N/A	N/A	0.09
20	N/A	N/A	0.09	N/A	N/A	N/A	0.09
21	N/A	N/A	0.06	N/A	N/A	N/A	0.06
22	N/A	N/A	0.07	N/A	N/A	N/A	0.07
23	N/A	N/A	0.08	N/A	N/A	N/A	0.08
24	N/A	N/A	0.08	N/A	N/A	N/A	0.08
25	N/A	N/A	0.10	N/A	N/A	N/A	0.10
26	N/A	N/A	0.13	N/A	N/A	N/A	0.13
27	N/A	N/A	0.11	N/A	N/A	N/A	0.11
28	N/A	N/A	0.09	N/A	N/A	N/A	0.09
29	N/A	N/A	0.10	N/A	N/A	N/A	0.10
30	N/A	N/A	0.07	N/A	N/A	N/A	0.07
31	N/A	N/A		N/A	N/A	N/A	0.00
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings ≤ 1 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point ≥ 0.2 mg/l? YES	
All daily readings ≤ 5 NTU? YES				PRINTED NAME: Joe Rogers			
Notes:				SIGNATURE 		DATE: 6/30/2021	
				PHONE #: (503) -723-3505		CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: June 2021

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
06/01/21	6:00AM	1.35	59	79	17.3	7.5	28	Yes	6363
06/02/21	6:00AM	1.34	53	71	18.3	7.6	27	Yes	6616
06/03/21	6:00AM	1.31	57	75	18.7	7.6	27	Yes	6637
06/04/21	6:00AM	1.38	55	75	18.8	7.7	28	Yes	6370
06/05/21	6:00AM	1.31	66	87	17.6	7.7	30	Yes	4875
06/06/21	6:00AM	1.31	77	101	17.1	7.5	28	Yes	4187
06/07/21	6:00AM	1.22	61	74	15.1	8.0	38	Yes	4812
06/08/21	6:00AM	1.34	60	81	17.2	7.9	33	Yes	5655
06/09/21	6:00AM	1.34	59	79	17.0	7.7	31	Yes	6092
06/10/21	6:00AM	1.30	61	79	17.2	7.7	30	Yes	5737
06/11/21	6:00AM	1.31	65	86	16.5	7.6	30	Yes	5416
06/12/21	6:00AM	1.29	77	100	15.3	7.5	30	Yes	4175
06/13/21	6:00AM	1.24	79	98	17.9	7.7	29	Yes	4196
06/14/21	6:00AM	1.28	65	83	16.3	7.6	30	Yes	4863
06/15/21	6:00AM	1.35	59	80	16.3	7.6	31	Yes	5573
06/16/21	6:00AM	1.17	63	74	17.2	7.5	27	Yes	5631
06/17/21	6:00AM	1.06	63	67	18.4	7.6	26	Yes	5655
06/18/21	6:00AM	1.06	64	68	18.7	7.6	26	Yes	5455
06/19/21	6:00AM	1.16	61	70	18.4	7.6	27	Yes	5425
06/20/21	6:00AM	1.04	72	75	19.1	7.6	25	Yes	4538
06/21/21	6:00AM	1.18	64	75	20.3	7.5	23	Yes	4841
06/22/21	6:00AM	1.13	57	64	21.1	7.5	22	Yes	5909
06/23/21	6:00AM	1.12	56	63	20.4	7.7	24	Yes	6121
06/24/21	6:00AM	1.04	61	64	20.9	7.8	24	Yes	5267
06/25/21	6:00AM	1.12	61	68	21.4	7.6	22	Yes	5978
06/26/21	6:00AM	1.03	53	55	22.2	7.7	21	Yes	7191
06/27/21	6:00AM	1.05	57	60	23.2	7.7	20	Yes	6738
06/28/21	6:00AM	1.07	58	62	24.1	7.7	18	Yes	6439
06/29/21	6:00AM	1.11	56	62	24.0	7.7	18	Yes	6358
06/30/21	6:00AM	1.13	55	62	23.7	7.6	18	Yes	6939

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day