


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: 8/2021							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.10	N/A	N/A	N/A	0.10
2	N/A	N/A	0.07	N/A	N/A	N/A	0.07
3	N/A	N/A	0.07	N/A	N/A	N/A	0.07
4	N/A	N/A	0.07	N/A	N/A	N/A	0.07
5	N/A	N/A	0.07	N/A	N/A	N/A	0.07
6	N/A	N/A	0.09	N/A	N/A	N/A	0.09
7	N/A	N/A	0.09	N/A	N/A	N/A	0.09
8	N/A	N/A	0.09	N/A	N/A	N/A	0.09
9	N/A	N/A	0.07	N/A	N/A	N/A	0.07
10	N/A	N/A	0.07	N/A	N/A	N/A	0.07
11	N/A	N/A	0.08	N/A	N/A	N/A	0.08
12	N/A	N/A	0.08	N/A	N/A	N/A	0.08
13	N/A	N/A	0.09	N/A	N/A	N/A	0.09
14	N/A	N/A	0.08	N/A	N/A	N/A	0.08
15	N/A	N/A	0.08	N/A	N/A	N/A	0.08
16	N/A	N/A	0.08	N/A	N/A	N/A	0.08
17	N/A	N/A	0.07	N/A	N/A	N/A	0.07
18	N/A	N/A	0.08	N/A	N/A	N/A	0.08
19	N/A	N/A	0.09	N/A	N/A	N/A	0.09
20	N/A	N/A	0.08	N/A	N/A	N/A	0.08
21	N/A	N/A	0.08	N/A	N/A	N/A	0.08
22	N/A	N/A	0.09	N/A	N/A	N/A	0.09
23	N/A	N/A	0.06	N/A	N/A	N/A	0.06
24	N/A	N/A	0.08	N/A	N/A	N/A	0.08
25	N/A	N/A	0.08	N/A	N/A	N/A	0.08
26	N/A	N/A	0.11	N/A	N/A	N/A	0.11
27	N/A	N/A	0.09	N/A	N/A	N/A	0.09
28	N/A	N/A	0.08	N/A	N/A	N/A	0.08
29	N/A	N/A	0.07	N/A	N/A	N/A	0.07
30	N/A	N/A	0.10	N/A	N/A	N/A	0.10
31	N/A	N/A	0.08	N/A	N/A	N/A	0.08
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings ≤ 1 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point ≥ 0.2 mg/l? YES	
All daily readings ≤ 5 NTU? YES				PRINTED NAME: Joe Rogers			
Notes:				SIGNATURE 		DATE 9-1-21	
				PHONE #: (503) -723-3505		CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: 8/2021

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
08/01/21	6:00AM	1.22	58	71	21.2	7.6	23	Yes	6748
08/02/21	6:00AM	1.16	52	61	22.7	7.7	21	Yes	6763
08/03/21	6:00AM	1.23	62	77	22.9	8.0	22	Yes	5213
08/04/21	6:00AM	1.22	58	70	22.8	7.8	21	Yes	6158
08/05/21	6:00AM	1.19	55	66	23.0	7.7	20	Yes	6966
08/06/21	6:00AM	1.13	60	68	22.0	7.6	21	Yes	6648
08/07/21	6:00AM	1.11	58	65	21.5	7.7	23	Yes	6627
08/08/21	6:00AM	1.12	52	58	21.0	7.6	23	Yes	6821
08/09/21	6:00AM	1.12	56	63	20.8	7.7	24	Yes	5653
08/10/21	6:00AM	1.21	57	69	21.6	7.7	23	Yes	6310
08/11/21	6:00AM	1.19	59	70	22.5	7.6	21	Yes	6610
08/12/21	6:00AM	1.16	62	72	23.5	7.5	18	Yes	6348
08/13/21	6:00AM	1.13	61	69	23.3	7.5	18	Yes	6436
08/14/21	6:00AM	1.11	59	65	23.2	7.5	19	Yes	6681
08/15/21	6:00AM	1.26	58	73	21.9	7.6	22	Yes	6732
08/16/21	6:00AM	1.11	55	61	22.9	7.5	19	Yes	6550
08/17/21	6:00AM	1.07	62	66	22.5	7.5	19	Yes	5077
08/18/21	6:00AM	1.25	62	77	20.1	7.6	25	Yes	5643
08/19/21	6:00AM	1.11	60	67	21.0	7.6	23	Yes	6159
08/20/21	6:00AM	1.08	61	66	21.5	7.7	22	Yes	6243
08/21/21	6:00AM	1.08	58	63	20.1	7.7	25	Yes	6496
08/22/21	6:00AM	1.15	66	76	19.9	7.8	26	Yes	5246
08/23/21	6:00AM	1.13	59	67	18.9	8.1	31	Yes	5197
08/24/21	6:00AM	1.21	55	66	19.4	7.8	27	Yes	6349
08/25/21	6:00AM	1.10	59	65	20.2	7.8	26	Yes	6338
08/26/21	6:00AM	1.07	62	66	20.1	7.7	25	Yes	6090
08/27/21	6:00AM	1.12	62	69	19.8	7.6	24	Yes	5894
08/28/21	6:00AM	1.02	65	66	19.2	7.5	23	Yes	5771
08/29/21	6:00AM	1.15	61	70	19.9	7.5	24	Yes	6099
08/30/21	6:00AM	1.15	70	81	20.2	7.7	25	Yes	4783
08/31/21	6:00AM	1.16	64	74	19.0	7.7	27	Yes	4801

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day