


OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B1 Month/Year: Sept 2021

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.11	N/A	N/A	N/A	0.11
2	N/A	N/A	0.10	N/A	N/A	N/A	0.10
3	N/A	N/A	0.10	N/A	N/A	N/A	0.10
4	N/A	N/A	0.10	N/A	N/A	N/A	0.10
5	N/A	N/A	0.09	N/A	N/A	N/A	0.09
6	N/A	N/A	0.10	N/A	N/A	N/A	0.10
7	N/A	N/A	0.11	N/A	N/A	N/A	0.11
8	N/A	N/A	0.15	N/A	N/A	N/A	0.15
9	N/A	N/A	0.12	N/A	N/A	N/A	0.12
10	N/A	N/A	0.09	N/A	N/A	N/A	0.09
11	N/A	N/A	0.09	N/A	N/A	N/A	0.09
12	N/A	N/A	0.10	N/A	N/A	N/A	0.10
13	N/A	N/A	0.11	N/A	N/A	N/A	0.11
14	N/A	N/A	0.13	N/A	N/A	N/A	0.13
15	N/A	N/A	0.10	N/A	N/A	N/A	0.10
16	N/A	N/A	0.12	N/A	N/A	N/A	0.12
17	N/A	N/A	0.10	N/A	N/A	N/A	0.10
18	N/A	N/A	0.10	N/A	N/A	N/A	0.10
19	N/A	N/A	0.09	N/A	N/A	N/A	0.09
20	N/A	N/A	0.13	N/A	N/A	N/A	0.13
21	N/A	N/A	0.12	N/A	N/A	N/A	0.12
22	N/A	N/A	0.10	N/A	N/A	N/A	0.10
23	N/A	N/A	0.16	N/A	N/A	N/A	0.16
24	N/A	N/A	0.14	N/A	N/A	N/A	0.14
25	N/A	N/A	0.10	N/A	N/A	N/A	0.10
26	N/A	N/A	0.09	N/A	N/A	N/A	0.09
27	N/A	N/A	0.10	N/A	N/A	N/A	0.10
28	N/A	N/A	0.10	N/A	N/A	N/A	0.10
29	N/A	N/A	0.10	N/A	N/A	N/A	0.10
30	N/A	N/A	0.12	N/A	N/A	N/A	0.12
31	N/A	N/A	Down	N/A	N/A	N/A	Down

Slow Sand/Membrane/DE Filtration/ Unfiltered		Monthly Summary	
95% of daily turbidity readings ≤ 1 NTU? YES	CT's met everyday? (see back) YES	All CL2 residual at entry point ≥ 0.2 mg/l? YES	
All daily readings ≤ 5 NTU? YES	PRINTED NAME: Joe Rogers		
Notes:	SIGNATURE 	DATE 10/1/2021	
	PHONE #: (503) -723-3505	CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: Sept 2021

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
09/01/21	0600AM	1.2	64	74	18.5	7.6	27	Yes	4801
09/02/21	0600AM	1.2	58	71	18.4	7.6	27	Yes	5878
09/03/21	0600AM	1.1	58	66	18.3	7.9	30	Yes	6108
09/04/21	0600AM	1.1	69	76	17.8	7.6	27	Yes	4892
09/05/21	0600AM	1.1	67	75	18.5	7.6	26	Yes	4571
09/06/21	0600AM	1.1	68	78	19.2	7.5	24	Yes	5300
09/07/21	0600AM	1.1	71	81	19.7	7.6	25	Yes	4664
09/08/21	0600AM	1.2	63	73	19.0	7.9	29	Yes	4867
09/09/21	0600AM	1.2	60	70	19.4	7.8	27	Yes	5887
09/10/21	0600AM	1.2	58	68	19.1	7.7	27	Yes	6428
09/11/21	0600AM	1.2	58	68	17.4	7.6	28	Yes	6497
09/12/21	0600AM	1.1	62	71	18.3	7.6	27	Yes	6117
09/13/21	0600AM	1.1	71	78	17.2	7.6	28	Yes	4799
09/14/21	0600AM	1.1	60	66	17.3	7.8	30	Yes	5333
09/15/21	0600AM	1.2	60	71	17.9	7.8	30	Yes	5755
09/16/21	0600AM	1.2	59	69	17.3	7.7	30	Yes	6160
09/17/21	0600AM	1.2	61	72	16.2	7.6	30	Yes	6265
09/18/21	0600AM	1.2	70	84	16.5	7.7	31	Yes	4868
09/19/21	0600AM	1.2	67	81	16.5	7.7	31	Yes	5206
09/20/21	0600AM	1.3	57	72	16.2	7.7	32	Yes	6000
09/21/21	0600AM	1.2	67	82	16.4	7.7	31	Yes	4538
09/22/21	0600AM	1.2	59	71	16.5	7.7	31	Yes	5699
09/23/21	0600AM	1.2	61	73	16.4	7.7	31	Yes	6039
09/24/21	0600AM	1.2	62	72	16.6	7.8	32	Yes	6111
09/25/21	0600AM	1.1	61	68	16.7	7.6	29	Yes	6272
09/26/21	0600AM	1.1	61	69	16.9	7.7	30	Yes	6267
09/27/21	0600AM	1.2	63	77	16.9	7.8	32	Yes	4863
09/28/21	0600AM	1.2	65	79	13.4	7.8	40	Yes	4738
09/29/21	0600AM	1.3	66	86	15.1	7.7	34	Yes	4928
09/30/21	0600AM	1.3	61	81	15.2	7.6	32	Yes	5126
	0600AM		DOWN	DOWN			DOWN	DOWN	

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day