


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: Oct 2021							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.10	N/A	N/A	N/A	0.10
2	N/A	N/A	0.08	N/A	N/A	N/A	0.08
3	N/A	N/A	0.08	N/A	N/A	N/A	0.08
4	N/A	N/A	0.09	N/A	N/A	N/A	0.09
5	N/A	N/A	0.09	N/A	N/A	N/A	0.09
6	N/A	N/A	0.11	N/A	N/A	N/A	0.11
7	N/A	N/A	0.11	N/A	N/A	N/A	0.11
8	N/A	N/A	0.08	N/A	N/A	N/A	0.08
9	N/A	N/A	0.08	N/A	N/A	N/A	0.08
10	N/A	N/A	0.09	N/A	N/A	N/A	0.09
11	N/A	N/A	0.09	N/A	N/A	N/A	0.09
12	N/A	N/A	0.09	N/A	N/A	N/A	0.09
13	N/A	N/A	0.10	N/A	N/A	N/A	0.10
14	N/A	N/A	0.10	N/A	N/A	N/A	0.10
15	N/A	N/A	0.10	N/A	N/A	N/A	0.10
16	N/A	N/A	0.09	N/A	N/A	N/A	0.09
17	N/A	N/A	0.08	N/A	N/A	N/A	0.08
18	N/A	N/A	0.09	N/A	N/A	N/A	0.09
19	N/A	N/A	0.09	N/A	N/A	N/A	0.09
20	N/A	N/A	0.12	N/A	N/A	N/A	0.12
21	N/A	N/A	0.09	N/A	N/A	N/A	0.09
22	N/A	N/A	0.09	N/A	N/A	N/A	0.09
23	N/A	N/A	0.08	N/A	N/A	N/A	0.08
24	N/A	N/A	0.07	N/A	N/A	N/A	0.07
25	N/A	N/A	0.11	N/A	N/A	N/A	0.11
26	N/A	N/A	0.10	N/A	N/A	N/A	0.10
27	N/A	N/A	0.12	N/A	N/A	N/A	0.12
28	N/A	N/A	0.11	N/A	N/A	N/A	0.11
29	N/A	N/A	0.13	N/A	N/A	N/A	0.13
30	N/A	N/A	0.09	N/A	N/A	N/A	0.09
31	N/A	N/A	0.09	N/A	N/A	N/A	0.09
<b>Slow Sand/Membrane/DE Filtration/ Unfiltered</b>				<b>Monthly Summary</b>			
95% of daily turbidity readings ≤ 1 NTU? <b>YES</b>				CT's met everyday? (see back) <b>YES</b>		All CL2 residual at entry point ≥ 0.2 mg/l? <b>YES</b>	
All daily readings ≤ 5 NTU? <b>YES</b>				PRINTED NAME: Joe Rogers			
Notes:				SIGNATURE 		DATE 11/02/2021	
				PHONE #: (503) 723-3505		CERT #: T-09162	

**OHA - Drinking Water Program - Surface Water Quality Data Form**

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-BI Month/Year: OCT 2021

**SLOW SAND FILTERS**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
10/01/21	0600AM	1.3	76	99	14.9	7.7	34	Yes	4451
10/02/21	0600AM	1.3	75	98	14.8	8.0	39	Yes	4174
10/03/21	0600AM	1.4	81	112	14.7	7.8	37	Yes	4166
10/04/21	0600AM	1.3	82	109	14.8	7.8	36	Yes	3782
10/05/21	0600AM	1.4	76	104	14.6	7.9	38	Yes	4170
10/06/21	0600AM	1.4	70	97	13.5	7.8	40	Yes	4801
10/07/21	0600AM	1.3	71	95	13.2	7.9	43	Yes	4455
10/08/21	0600AM	1.4	97	131	13.1	7.9	43	Yes	3278
10/09/21	0600AM	1.4	76	104	12.6	8.0	47	Yes	4175
10/10/21	0600AM	1.4	76	110	12.8	8.0	46	Yes	4174
10/11/21	0600AM	1.4	77	108	12.6	8.2	51	Yes	4168
10/12/21	0600AM	1.4	85	118	12.0	8.1	51	Yes	3980
10/13/21	0600AM	1.4	78	108	11.4	8.1	53	Yes	3947
10/14/21	0600AM	1.4	74	104	11.5	8.1	53	Yes	4452
10/15/21	0600AM	1.5	93	135	11.8	8.0	50	Yes	3379
10/16/21	0600AM	1.4	76	109	11.9	7.8	46	Yes	4168
10/17/21	0600AM	1.4	85	123	11.8	7.6	43	Yes	3475
10/18/21	0600AM	1.5	77	113	11.8	7.6	43	Yes	4175
10/19/21	0600AM	1.4	75	104	11.3	7.6	44	Yes	4171
10/20/21	0600AM	1.4	89	124	11.3	7.7	46	Yes	3480
10/21/21	0600AM	1.5	85	129	11.8	7.6	44	Yes	3809
10/22/21	0600AM	1.3	92	122	12.2	7.7	43	Yes	3598
10/23/21	0600AM	1.4	92	124	11.8	7.7	44	Yes	3519
10/24/21	0600AM	1.4	82	117	11.4	7.6	44	Yes	3825
10/25/21	0600AM	1.4	92	126	11.1	7.6	45	Yes	3481
10/26/21	0600AM	1.4	91	124	10.8	7.5	44	Yes	3470
10/27/21	0600AM	1.7	71	119	10.9	7.7	49	Yes	4178
10/28/21	0600AM	1.3	74	97	10.7	7.6	46	Yes	4449
10/29/21	0600AM	1.4	83	117	11.8	7.5	41	Yes	3867
10/30/21	0600AM	1.3	110	147	11.5	7.5	42	Yes	2791
10/31/21	0600AM	1.3	121	160	10.8	7.6	46	Yes	2541

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day