


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: Dec 2021								
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]	
1	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
2	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
3	N/A	N/A	0.11	N/A	N/A	N/A	0.11	
4	N/A	N/A	0.12	N/A	N/A	N/A	0.12	
5	N/A	N/A	0.09	N/A	N/A	N/A	0.09	
6	N/A	N/A	0.15	N/A	N/A	N/A	0.15	
7	N/A	N/A	0.28	N/A	N/A	N/A	0.28	
8	N/A	N/A	0.31	N/A	N/A	N/A	0.31	
9	N/A	N/A	0.23	N/A	N/A	N/A	0.23	
10	N/A	N/A	0.23	N/A	N/A	N/A	0.23	
11	N/A	N/A	0.19	N/A	N/A	N/A	0.19	
12	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
13	N/A	N/A	0.31	N/A	N/A	N/A	0.31	
14	N/A	N/A	0.44	N/A	N/A	N/A	0.44	
15	N/A	N/A	0.68	N/A	N/A	N/A	0.68	
16	N/A	N/A	0.66	N/A	N/A	N/A	0.66	
17	N/A	N/A	0.64	N/A	N/A	N/A	0.64	
18	N/A	N/A	0.42	N/A	N/A	N/A	0.42	
19	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
20	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
21	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
22	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
23	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
24	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
25	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
26	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
27	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
28	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
29	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
30	N/A	N/A	0.25	N/A	N/A	N/A	0.25	
31	N/A	N/A	0.48	N/A	N/A	N/A	0.48	
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary				
95% of daily turbidity readings \leq 1 NTU? YES All daily readings \leq 5 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point \geq 0.2 mg/l? YES		
Notes:				PRINTED NAME: Joe Rogers				
				SIGNATURE 			DATE 01/05/2022	
				PHONE #: (503) -723-3505			CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: DEC 2021

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
12/01/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
12/02/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
12/03/21	0600AM	1.2	252	310	9.7	8.3	63	Yes	1192
12/04/21	0600AM	1.8	136	251	8.7	8.0	65	Yes	2228
12/05/21	0600AM	1.6	91	142	8.8	7.9	60	Yes	3298
12/06/21	0600AM	1.6	84	130	8.1	7.5	54	Yes	3768
12/07/21	0600AM	1.7	84	138	7.9	7.8	62	Yes	3760
12/08/21	0600AM	1.5	100	152	8.5	7.5	52	Yes	3012
12/09/21	0600AM	1.5	92	137	8.1	8.0	65	Yes	3154
12/10/21	0600AM	1.5	92	140	7.7	7.9	64	Yes	3434
12/11/21	0600AM	1.4	93	130	7.4	7.5	54	Yes	3482
12/12/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
12/13/21	0600AM	1.6	109	169	8.0	7.5	54	Yes	2814
12/14/21	0600AM	1.7	87	151	7.0	7.8	66	Yes	3487
12/15/21	0600AM	1.5	85	124	6.4	7.5	58	Yes	3771
12/16/21	0600AM	1.4	96	135	6.4	8.0	70	Yes	3348
12/17/21	0600AM	1.4	90	129	6.7	8.0	70	Yes	3585
12/18/21	0600AM	1.5	90	134	6.5	7.5	58	Yes	3569
12/19/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
12/20/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
12/21/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
12/22/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
12/23/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
12/24/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
12/25/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
12/26/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
12/27/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
12/28/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
12/29/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
12/30/21	0600AM	1.9	109	201	4.5	4.5	40	Yes	2760
12/31/21	0600AM	1.4	93	134	4.8	4.8	37	Yes	3488

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day