


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: 2/2022								
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]	
1	N/A	N/A	0.48	N/A	N/A	N/A	0.48	
2	N/A	N/A	0.42	N/A	N/A	N/A	0.42	
3	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
4	N/A	N/A	0.24	N/A	N/A	N/A	0.24	
5	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
6	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
7	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
8	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
9	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
10	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
11	N/A	N/A	0.49	N/A	N/A	N/A	0.49	
12	N/A	N/A	0.43	N/A	N/A	N/A	0.43	
13	N/A	N/A	0.49	N/A	N/A	N/A	0.49	
14	N/A	N/A	0.48	N/A	N/A	N/A	0.48	
15	N/A	N/A	0.35	N/A	N/A	N/A	0.35	
16	N/A	N/A	0.30	N/A	N/A	N/A	0.30	
17	N/A	N/A	0.26	N/A	N/A	N/A	0.26	
18	N/A	N/A	0.23	N/A	N/A	N/A	0.23	
19	N/A	N/A	0.21	N/A	N/A	N/A	0.21	
20	N/A	N/A	0.28	N/A	N/A	N/A	0.28	
21	N/A	N/A	0.36	N/A	N/A	N/A	0.36	
22	N/A	N/A	0.37	N/A	N/A	N/A	0.37	
23	N/A	N/A	0.29	N/A	N/A	N/A	0.29	
24	N/A	N/A	0.24	N/A	N/A	N/A	0.24	
25	N/A	N/A	0.23	N/A	N/A	N/A	0.23	
26	N/A	N/A	0.19	N/A	N/A	N/A	0.19	
27	N/A	N/A	0.15	N/A	N/A	N/A	0.15	
28	N/A	N/A	0.16	N/A	N/A	N/A	0.16	
29	N/A	N/A	0.15	N/A	N/A	N/A	0.15	
30	N/A	N/A	0.14	N/A	N/A	N/A	0.14	
31	N/A	N/A	0.14	N/A	N/A	N/A	0.14	
<b>Slow Sand/Membrane/DE Filtration/ Unfiltered</b>				<b>Monthly Summary</b>				
95% of daily turbidity readings ≤ 1 NTU? <b>YES</b> All daily readings ≤ 5 NTU? <b>YES</b>				CT's met everyday? (see back) <b>YES</b>		All CL2 residual at entry point ≥ 0.2 mg/l? <b>YES</b>		
Notes:				PRINTED NAME: Joe Rogers				
				SIGNATURE 			2/3/2022	
				PHONE #: (503) 723-3605			CERT #: T-09162	

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: FEB 2022**

**SLOW SAND FILTERS**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
01/01/22	0600AM	1.6	95	148	4.2	7.7	74	Yes	3300
01/02/22	0600AM	1.5	94	143	3.9	7.8	79	Yes	3398
01/03/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/04/22	0600AM	1.4	119	165	5.8	8.1	76	Yes	2484
01/05/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/06/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/07/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/08/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/09/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/10/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/11/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/12/22	0600AM	1.6	88	144	6.8	7.9	69	Yes	3424
01/13/22	0600AM	1.4	84	121	6.5	8.0	70	Yes	3904
01/14/22	0600AM	1.6	84	130	7.1	8.1	72	Yes	3766
01/15/22	0600AM	1.3	90	119	6.3	7.8	65	Yes	3549
01/16/22	0600AM	1.5	98	150	6.1	8.2	79	Yes	2996
01/17/22	0600AM	1.3	101	135	6.0	7.8	66	Yes	3113
01/18/22	0600AM	1.3	101	135	6.5	7.9	67	Yes	3128
01/19/22	0600AM	1.4	94	133	6.4	7.9	68	Yes	3357
01/20/22	0600AM	1.5	97	148	6.5	8.1	74	Yes	3054
01/21/22	0600AM	1.4	85	121	7.1	7.9	65	Yes	3803
01/22/22	0600AM	1.3	93	124	7.0	7.7	60	Yes	3504
01/23/22	0600AM	1.4	89	121	6.9	8.1	71	Yes	3472
01/24/22	0600AM	1.4	109	155	6.2	7.9	69	Yes	2782
01/25/22	0600AM	1.4	96	133	5.8	7.9	70	Yes	3199
01/26/22	0600AM	1.4	99	139	5.4	7.7	66	Yes	3211
01/27/22	0600AM	1.4	97	136	5.1	8.1	79	Yes	3288
01/28/22	0600AM	1.4	99	139	5.0	8.1	79	Yes	3215
01/29/22	0600AM	1.4	96	139	4.9	7.8	71	Yes	3196
01/30/22	0600AM	1.3	97	129	4.8	7.9	74	Yes	3278
01/31/22	0600AM	1.3	89	119	5.0	7.9	73	Yes	3468

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day