


OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: 2/2022

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.15	N/A	N/A	N/A	0.15
2	N/A	N/A	0.17	N/A	N/A	N/A	0.17
3	N/A	N/A	0.18	N/A	N/A	N/A	0.18
4	N/A	N/A	0.16	N/A	N/A	N/A	0.16
5	N/A	N/A	0.13	N/A	N/A	N/A	0.13
6	N/A	N/A	0.11	N/A	N/A	N/A	0.11
7	N/A	N/A	0.10	N/A	N/A	N/A	0.10
8	N/A	N/A	0.10	N/A	N/A	N/A	0.10
9	N/A	N/A	0.09	N/A	N/A	N/A	0.09
10	N/A	N/A	0.08	N/A	N/A	N/A	0.08
11	N/A	N/A	0.10	N/A	N/A	N/A	0.10
12	N/A	N/A	0.08	N/A	N/A	N/A	0.08
13	N/A	N/A	0.09	N/A	N/A	N/A	0.09
14	N/A	N/A	0.10	N/A	N/A	N/A	0.10
15	N/A	N/A	0.09	N/A	N/A	N/A	0.09
16	N/A	N/A	0.12	N/A	N/A	N/A	0.12
17	N/A	N/A	0.12	N/A	N/A	N/A	0.12
18	N/A	N/A	0.13	N/A	N/A	N/A	0.13
19	N/A	N/A	0.09	N/A	N/A	N/A	0.09
20	N/A	N/A	0.09	N/A	N/A	N/A	0.09
21	N/A	N/A	0.09	N/A	N/A	N/A	0.09
22	N/A	N/A	0.08	N/A	N/A	N/A	0.08
23	N/A	N/A	0.09	N/A	N/A	N/A	0.09
24	N/A	N/A	0.09	N/A	N/A	N/A	0.09
25	N/A	N/A	0.12	N/A	N/A	N/A	0.12
26	N/A	N/A	0.08	N/A	N/A	N/A	0.08
27	N/A	N/A	0.10	N/A	N/A	N/A	0.10
28	N/A	N/A	0.16	N/A	N/A	N/A	0.16
29	N/A	N/A		N/A	N/A	N/A	
30	N/A	N/A		N/A	N/A	N/A	
31	N/A	N/A		N/A	N/A	N/A	

Slow Sand/Membrane/DE Filtration/ Unfiltered		Monthly Summary	
95% of daily turbidity readings ≤ 1 NTU? YES		CT's met everyday? (see back) YES	All CL2 residual at entry point ≥ 0.2 mg/l? YES
All daily readings ≤ 5 NTU? YES		PRINTED NAME: Joe Rogers	
Notes:		SIGNATURE 	DATE 2-1-22
		PHONE #: (503) 23-3505	CERT #: T-09162

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: 2/2022

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
02/01/22	0600AM	1.4	84	117	5.5	7.8	69	Yes	3808
02/02/22	0600AM	1.4	87	124	5.5	7.9	72	Yes	3619
02/03/22	0600AM	1.6	59	93	6.4	7.9	70	Yes	5562
02/04/22	0600AM	1.6	120	190	5.8	8.0	75	Yes	2533
02/05/22	0600AM	1.3	96	124	6.0	7.7	64	Yes	3303
02/06/22	0600AM	1.3	97	128	6.2	7.8	66	Yes	3294
02/07/22	0600AM	1.4	92	131	5.8	7.8	68	Yes	3493
02/08/22	0600AM	1.4	93	126	6.7	8.0	69	Yes	3463
02/09/22	0600AM	1.3	95	126	6.0	8.1	74	Yes	3279
02/10/22	0600AM	1.4	105	146	5.9	8.1	75	Yes	2957
02/11/22	0600AM	1.5	98	144	4.5	8.1	84	Yes	3182
02/12/22	0600AM	1.5	94	141	6.2	8.1	75	Yes	3279
02/13/22	0600AM	1.3	91	118	6.0	7.9	69	Yes	3539
02/14/22	0600AM	1.3	86	110	6.5	8.0	69	Yes	3518
02/15/22	0600AM	1.4	89	120	6.7	7.9	66	Yes	3532
02/16/22	0600AM	1.4	104	144	6.4	8.0	70	Yes	2981
02/17/22	0600AM	1.4	105	144	6.8	7.9	66	Yes	2955
02/18/22	0600AM	1.3	92	117	6.4	8.0	69	Yes	3484
02/19/22	0600AM	1.3	93	120	6.0	7.9	69	Yes	3459
02/20/22	0600AM	1.3	91	118	6.7	8.0	69	Yes	3542
02/21/22	0600AM	1.4	108	146	6.7	7.9	66	Yes	2781
02/22/22	0600AM	1.4	72	100	6.1	8.0	72	Yes	4540
02/23/22	0600AM	1.4	92	129	5.2	8.0	75	Yes	3447
02/24/22	0600AM	1.3	92	119	5.1	8.0	75	Yes	3512
02/25/22	0600AM	1.4	91	124	4.3	8.0	80	Yes	3494
02/26/22	0600AM	1.4	87	118	3.8	8.1	88	Yes	3577
02/27/22	0600AM	1.3	89	114	4.6	8.0	78	Yes	3677
02/28/22	0600AM	1.3	88	116	5.5	7.8	68	Yes	3686
03/01/22	0600AM								
03/02/22	0600AM								
03/03/22	0600AM								

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day