


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

**System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: March 2022**

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
2	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
3	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
4	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
5	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
6	N/A	N/A	0.06	N/A	N/A	N/A	0.06
7	N/A	N/A	0.34	N/A	N/A	N/A	0.34
8	N/A	N/A	0.26	N/A	N/A	N/A	0.26
9	N/A	N/A	0.24	N/A	N/A	N/A	0.24
10	N/A	N/A	0.21	N/A	N/A	N/A	0.21
11	N/A	N/A	0.17	N/A	N/A	N/A	0.17
12	N/A	N/A	0.12	N/A	N/A	N/A	0.12
13	N/A	N/A	0.11	N/A	N/A	N/A	0.11
14	N/A	N/A	0.13	N/A	N/A	N/A	0.13
15	N/A	N/A	0.15	N/A	N/A	N/A	0.15
16	N/A	N/A	0.22	N/A	N/A	N/A	0.22
17	N/A	N/A	0.16	N/A	N/A	N/A	0.16
18	N/A	N/A	0.14	N/A	N/A	N/A	0.14
19	N/A	N/A	0.12	N/A	N/A	N/A	0.12
20	N/A	N/A	0.14	N/A	N/A	N/A	0.14
21	N/A	N/A	0.14	N/A	N/A	N/A	0.14
22	N/A	N/A	0.17	N/A	N/A	N/A	0.17
23	N/A	N/A	0.24	N/A	N/A	N/A	0.24
24	N/A	N/A	0.23	N/A	N/A	N/A	0.23
25	N/A	N/A	0.18	N/A	N/A	N/A	0.18
26	N/A	N/A	0.13	N/A	N/A	N/A	0.13
27	N/A	N/A	0.11	N/A	N/A	N/A	0.11
28	N/A	N/A	0.12	N/A	N/A	N/A	0.12
29	N/A	N/A	0.10	N/A	N/A	N/A	0.10
30	N/A	N/A	0.18	N/A	N/A	N/A	0.18
31	N/A	N/A	0.14	N/A	N/A	N/A	0.14

<b>Slow Sand/Membrane/DE Filtration/ Unfiltered</b>		<b>Monthly Summary</b>	
95% of daily turbidity readings ≤ 1 NTU? <b>YES</b> All daily readings ≤ 5 NTU? <b>YES</b>		CT's met everyday? (see back) <b>YES</b>	All CL2 residual at entry point ≥ 0.2 mg/l? <b>YES</b>
Notes:		<b>PRINTED NAME: Joe Rogers</b>	
		SIGNATURE 	DATE 04/01/2022
		PHONE #: (503) -723-3505	CERT #: T-09162

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: March 2022**

**SLOW SAND FILTERS**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
03/01/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/02/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/03/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/04/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/05/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/06/22	6:00 AM	1.32	91	120	6.9	8.0	68	Yes	3353
03/07/22	6:00 AM	1.31	92	121	7.0	8.0	67	Yes	3501
03/08/22	6:00 AM	1.40	90	126	7.1	7.9	65	Yes	3526
03/09/22	6:00 AM	1.31	100	131	7.1	7.9	65	Yes	3160
03/10/22	6:00 AM	1.32	98	129	7.2	8.0	67	Yes	3251
03/11/22	6:00 AM	1.28	94	120	7.0	8.1	70	Yes	3430
03/12/22	6:00 AM	1.26	92	115	7.0	8.2	73	Yes	3359
03/13/22	6:00 AM	1.31	118	154	7.1	7.8	62	Yes	2618
03/14/22	6:00 AM	1.23	82	101	7.4	7.8	61	Yes	3716
03/15/22	6:00 AM	1.27	74	94	7.2	8.0	66	Yes	4030
03/16/22	6:00 AM	1.30	91	119	8.0	7.7	57	Yes	3485
03/17/22	6:00 AM	1.31	93	121	8.1	7.8	59	Yes	3479
03/18/22	6:00 AM	1.18	89	106	8.5	7.9	59	Yes	3277
03/19/22	6:00 AM	1.29	106	136	8.2	7.9	61	Yes	2881
03/20/22	6:00 AM	1.23	97	120	7.8	7.8	60	Yes	3240
03/21/22	6:00 AM	1.28	76	98	7.8	7.8	60	Yes	4023
03/22/22	6:00 AM	1.38	76	104	8.0	7.6	55	Yes	3921
03/23/22	6:00 AM	1.33	91	122	8.9	7.8	56	Yes	3522
03/24/22	6:00 AM	1.40	90	126	8.7	7.8	57	Yes	3224
03/25/22	6:00 AM	1.40	106	149	9.5	8.0	58	Yes	2889
03/26/22	6:00 AM	1.36	109	149	9.4	8.0	58	Yes	2811
03/27/22	6:00 AM	1.33	120	159	9.8	7.8	53	Yes	2601
03/28/22	6:00 AM	1.27	105	133	10.1	7.7	50	Yes	2863
03/29/22	6:00 AM	1.41	97	137	9.7	8.0	57	Yes	3086
03/30/22	6:00 AM	1.34	97	130	10.2	7.7	49	Yes	3293
03/31/22	6:00 AM	1.36	95	129	9.5	7.7	52	Yes	3368

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day