

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B1 Month/Year: April 2022							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.13	N/A	N/A	N/A	0.13
2	N/A	N/A	0.09	N/A	N/A	N/A	0.09
3	N/A	N/A	0.10	N/A	N/A	N/A	0.10
4	N/A	N/A	0.13	N/A	N/A	N/A	0.13
5	N/A	N/A	0.13	N/A	N/A	N/A	0.13
6	N/A	N/A	0.14	N/A	N/A	N/A	0.14
7	N/A	N/A	0.20	N/A	N/A	N/A	0.20
8	N/A	N/A	0.15	N/A	N/A	N/A	0.15
9	N/A	N/A	0.11	N/A	N/A	N/A	0.11
10	N/A	N/A	0.10	N/A	N/A	N/A	0.10
11	N/A	N/A	0.10	N/A	N/A	N/A	0.10
12	N/A	N/A	0.16	N/A	N/A	N/A	0.16
13	N/A	N/A	0.33	N/A	N/A	N/A	0.33
14	N/A	N/A	0.32	N/A	N/A	N/A	0.32
15	N/A	N/A	0.27	N/A	N/A	N/A	0.27
16	N/A	N/A	0.17	N/A	N/A	N/A	0.17
17	N/A	N/A	0.14	N/A	N/A	N/A	0.14
18	N/A	N/A	0.12	N/A	N/A	N/A	0.12
19	N/A	N/A	0.12	N/A	N/A	N/A	0.12
20	N/A	N/A	0.22	N/A	N/A	N/A	0.22
21	N/A	N/A	0.21	N/A	N/A	N/A	0.21
22	N/A	N/A	0.13	N/A	N/A	N/A	0.13
23	N/A	N/A	0.11	N/A	N/A	N/A	0.11
24	N/A	N/A	0.11	N/A	N/A	N/A	0.11
25	N/A	N/A	0.10	N/A	N/A	N/A	0.10
26	N/A	N/A	0.12	N/A	N/A	N/A	0.12
27	N/A	N/A	0.11	N/A	N/A	N/A	0.11
28	N/A	N/A	0.12	N/A	N/A	N/A	0.12
29	N/A	N/A	0.12	N/A	N/A	N/A	0.12
30	N/A	N/A	0.09	N/A	N/A	N/A	0.09
31	N/A	N/A		N/A	N/A	N/A	0.00
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings ≤ 1 NTU? YES All daily readings ≤ 5 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point ≥ 0.2 mg/l? YES	
Notes: 				PRINTED NAME: Joe Rogers			
				SIGNATURE			DATE 05/03/2022
				PHONE #: (503) -723-3505			CERT #: T-09162

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: April 2022

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
04/01/22	6:00 AM	1.4	95	128	9.4	7.8	54	Yes	3402
04/02/22	6:00 AM	1.3	96	127	9.8	7.9	55	Yes	3292
04/03/22	6:00 AM	1.3	96	122	9.7	7.8	53	Yes	3302
04/04/22	6:00 AM	1.5	98	146	9.4	7.9	57	Yes	3265
04/05/22	6:00 AM	1.4	100	138	8.8	8.0	61	Yes	3068
04/06/22	6:00 AM	1.3	87	113	8.5	7.9	60	Yes	3629
04/07/22	6:00 AM	1.3	97	121	9.0	7.8	56	Yes	3252
04/08/22	6:00 AM	1.3	95	118	9.0	7.9	58	Yes	3330
04/09/22	6:00 AM	1.3	96	126	9.2	7.8	55	Yes	3228
04/10/22	6:00 AM	1.3	90	119	8.8	7.8	56	Yes	3520
04/11/22	6:00 AM	1.4	95	135	8.2	7.8	59	Yes	3197
04/12/22	6:00 AM	1.3	76	99	7.5	7.5	54	Yes	4147
04/13/22	6:00 AM	1.3	88	115	7.1	7.8	62	Yes	3649
04/14/22	6:00 AM	1.4	102	143	7.4	7.8	62	Yes	3126
04/15/22	6:00 AM	1.3	98	132	7.6	8.0	65	Yes	3201
04/16/22	6:00 AM	1.3	112	145	8.1	8.0	63	Yes	2856
04/17/22	6:00 AM	1.4	101	136	8.1	7.8	59	Yes	3165
04/18/22	6:00 AM	1.3	109	142	8.4	7.6	53	Yes	2759
04/19/22	6:00 AM	1.4	82	115	8.1	7.7	57	Yes	3600
04/20/22	6:00 AM	1.3	98	131	8.2	7.8	58	Yes	3245
04/21/22	6:00 AM	1.3	97	130	8.2	8.0	63	Yes	3274
04/22/22	6:00 AM	1.4	101	136	7.8	8.0	65	Yes	3128
04/23/22	6:00 AM	1.4	97	133	9.1	8.1	62	Yes	3317
04/24/22	6:00 AM	1.3	93	121	9.8	7.7	51	Yes	3379
04/25/22	6:00 AM	1.3	95	124	10.2	7.7	49	Yes	3339
04/26/22	6:00 AM	1.3	90	117	9.5	7.7	52	Yes	3341
04/27/22	6:00 AM	1.4	89	124	9.7	7.7	51	Yes	3506
04/28/22	6:00 AM	1.3	92	124	9.8	7.8	53	Yes	3491
04/29/22	6:00 AM	1.4	97	136	9.0	7.9	58	Yes	3308
04/30/22	6:00 AM	1.5	95	142	9.9	7.8	53	Yes	3254
	6:00 AM		DOWN	DOWN			DOWN	DOWN	

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day