


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: May 2022								
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]	
1	N/A	N/A	0.13	N/A	N/A	N/A	0.13	
2	N/A	N/A	0.15	N/A	N/A	N/A	0.15	
3	N/A	N/A	0.10	N/A	N/A	N/A	0.10	
4	N/A	N/A	0.14	N/A	N/A	N/A	0.14	
5	N/A	N/A	0.12	N/A	N/A	N/A	0.12	
6	N/A	N/A	0.14	N/A	N/A	N/A	0.14	
7	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
8	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
9	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
10	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
11	N/A	N/A	0.16	N/A	N/A	N/A	0.16	
12	N/A	N/A	0.12	N/A	N/A	N/A	0.12	
13	N/A	N/A	0.14	N/A	N/A	N/A	0.14	
14	N/A	N/A	0.15	N/A	N/A	N/A	0.15	
15	N/A	N/A	0.16	N/A	N/A	N/A	0.16	
16	N/A	N/A	0.19	N/A	N/A	N/A	0.19	
17	N/A	N/A	0.23	N/A	N/A	N/A	0.23	
18	N/A	N/A	0.11	N/A	N/A	N/A	0.11	
19	N/A	N/A	0.13	N/A	N/A	N/A	0.13	
20	N/A	N/A	0.11	N/A	N/A	N/A	0.11	
21	N/A	N/A	0.09	N/A	N/A	N/A	0.09	
22	N/A	N/A	0.10	N/A	N/A	N/A	0.10	
23	N/A	N/A	0.11	N/A	N/A	N/A	0.11	
24	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
25	N/A	N/A	0.10	N/A	N/A	N/A	0.10	
26	N/A	N/A	0.10	N/A	N/A	N/A	0.10	
27	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
28	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
29	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
30	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
31	N/A	N/A	0.11	N/A	N/A	N/A	0.11	
<b>Slow Sand/Membrane/DE Filtration/ Unfiltered</b>				<b>Monthly Summary</b>				
95% of daily turbidity readings $\leq$ 1 NTU? <b>YES</b> All daily readings $\leq$ 5 NTU? <b>YES</b>				CT's met everyday? (see back) <b>YES</b>		All CL2 residual at entry point $\geq$ 0.2 mg/l? <b>YES</b>		
<b>Notes:</b>				<b>PRINTED NAME: Joe Rogers</b>				
				SIGNATURE 			DATE 06/01/2022	
				PHONE #: (503) -723-3505			CERT #: T-09162	

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: May 2022**

**SLOW SAND FILTERS**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
05/01/22	6:00 AM	1.3	97	128	9.8	7.8	53	Yes	3279
05/02/22	6:00 AM	1.4	97	131	10.4	7.9	53	Yes	3200
05/03/22	6:00 AM	1.3	66	86	9.8	7.6	49	Yes	4539
05/04/22	6:00 AM	1.4	101	141	9.2	8.0	59	Yes	3045
05/05/22	6:00 AM	1.5	97	146	10.5	7.9	53	Yes	3278
05/06/22	6:00 AM	1.3	100	130	10.3	8.0	55	Yes	3159
05/07/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/08/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/09/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/10/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/11/22	6:00 AM	1.3	100	130	10.2	7.8	51	Yes	3001
05/12/22	6:00 AM	1.4	104	145	9.8	7.5	47	Yes	2971
05/13/22	6:00 AM	1.4	93	130	9.3	7.9	57	Yes	3358
05/14/22	6:00 AM	1.5	94	141	9.2	7.9	58	Yes	3360
05/15/22	6:00 AM	1.3	96	125	10.1	7.8	52	Yes	3325
05/16/22	6:00 AM	1.3	97	126	10.4	7.6	47	Yes	3291
05/17/22	6:00 AM	1.3	93	120	10.5	7.9	52	Yes	3282
05/18/22	6:00 AM	1.4	66	92	11.1	8.0	52	Yes	4629
05/19/22	6:00 AM	1.4	94	132	10.9	7.9	51	Yes	3414
05/20/22	6:00 AM	1.4	96	135	9.4	7.9	56	Yes	3344
05/21/22	6:00 AM	1.5	92	138	10.0	7.9	55	Yes	3411
05/22/22	6:00 AM	1.4	94	131	10.7	7.6	46	Yes	3404
05/23/22	6:00 AM	1.4	89	125	11.5	7.9	49	Yes	3378
05/24/22	6:00 AM	1.4	82	115	11.9	7.7	44	Yes	4025
05/25/22	6:00 AM	1.5	82	123	12.1	7.9	47	Yes	3980
05/26/22	6:00 AM	1.4	82	115	12.8	7.9	44	Yes	3995
05/27/22	6:00 AM	1.4	87	121	12.3	8.1	50	Yes	3799
05/28/22	6:00 AM	1.4	86	120	12.2	8.3	54	Yes	3407
05/29/22	6:00 AM	1.4	95	133	11.9	7.9	47	Yes	3383
05/30/22	6:00 AM	1.4	97	135	11.4	7.9	49	Yes	3299
05/31/22	6:00 AM	1.4	89	125	11.4	7.8	47	Yes	3559

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day