


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B1 Month/Year: 6/2022									
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]		
1	N/A	N/A	0.09	N/A	N/A	N/A	0.09		
2	N/A	N/A	0.08	N/A	N/A	N/A	0.08		
3	N/A	N/A	0.10	N/A	N/A	N/A	0.10		
4	N/A	N/A	0.07	N/A	N/A	N/A	0.07		
5	N/A	N/A	0.09	N/A	N/A	N/A	0.09		
6	N/A	N/A	0.16	N/A	N/A	N/A	0.16		
7	N/A	N/A	0.07	N/A	N/A	N/A	0.07		
8	N/A	N/A	0.13	N/A	N/A	N/A	0.13		
9	N/A	N/A	0.09	N/A	N/A	N/A	0.09		
10	N/A	N/A	0.09	N/A	N/A	N/A	0.09		
11	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN		
12	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN		
13	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN		
14	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN		
15	N/A	N/A	0.18	N/A	N/A	N/A	0.18		
16	N/A	N/A	0.16	N/A	N/A	N/A	0.16		
17	N/A	N/A	0.16	N/A	N/A	N/A	0.16		
18	N/A	N/A	0.10	N/A	N/A	N/A	0.10		
19	N/A	N/A	0.09	N/A	N/A	N/A	0.09		
20	N/A	N/A	0.08	N/A	N/A	N/A	0.08		
21	N/A	N/A	0.08	N/A	N/A	N/A	0.08		
22	N/A	N/A	0.08	N/A	N/A	N/A	0.08		
23	N/A	N/A	0.07	N/A	N/A	N/A	0.07		
24	N/A	N/A	0.10	N/A	N/A	N/A	0.10		
25	N/A	N/A	0.09	N/A	N/A	N/A	0.09		
26	N/A	N/A	0.07	N/A	N/A	N/A	0.07		
27	N/A	N/A	0.08	N/A	N/A	N/A	0.08		
28	N/A	N/A	0.07	N/A	N/A	N/A	0.07		
29	N/A	N/A	0.08	N/A	N/A	N/A	0.08		
30	N/A	N/A	0.09	N/A	N/A	N/A	0.09		
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary					
95% of daily turbidity readings ≤ 1 NTU? YES All daily readings ≤ 5 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point ≥ 0.2 mg/l? YES			
Notes:				PRINTED NAME: Joe Rogers					
				SIGNATURE 				7/1/2022	
				PHONE #: (503) 723-3505				CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: June 2022

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
06/01/22	0600AM	1.4	90	130	12.5	7.8	44	Yes	3576
06/02/22	0600AM	1.4	90	123	12.8	7.8	43	Yes	3556
06/03/22	0600AM	1.4	88	121	13.4	8.0	44	Yes	3590
06/04/22	0600AM	1.4	90	124	12.7	8.0	46	Yes	3517
06/05/22	0600AM	1.4	93	128	12.8	8.0	46	Yes	3480
06/06/22	0600AM	1.4	93	132	13.5	7.8	41	Yes	3360
06/07/22	0600AM	1.4	80	112	12.8	7.8	43	Yes	4044
06/08/22	0600AM	1.4	84	118	13.2	7.8	42	Yes	3943
06/09/22	0600AM	1.3	84	109	13.5	8.0	43	Yes	3953
06/10/22	0600AM	1.3	84	110	13.2	7.9	43	Yes	3988
06/11/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
06/12/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
06/13/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
06/14/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
06/15/22	0600AM	1.0	148	140	12.5	7.9	43	Yes	2033
06/16/22	0600AM	1.7	87	145	12.4	8.0	49	Yes	3606
06/17/22	0600AM	1.4	76	104	12.4	7.8	44	Yes	4499
06/18/22	0600AM	1.6	83	136	11.5	8.0	52	Yes	3620
06/19/22	0600AM	1.4	84	118	12.1	7.9	47	Yes	3760
06/20/22	0600AM	1.4	84	115	12.1	7.8	45	Yes	3865
06/21/22	0600AM	1.4	72	101	13.1	8.1	47	Yes	4379
06/22/22	0600AM	1.3	67	88	13.9	7.9	40	Yes	4650
06/23/22	0600AM	1.5	72	105	15.0	7.9	37	Yes	4501
06/24/22	0600AM	1.3	73	98	15.0	8.0	38	Yes	4094
06/25/22	0600AM	1.4	60	83	15.8	7.9	35	Yes	5646
06/26/22	0600AM	1.4	58	81	16.8	7.7	31	Yes	6298
06/27/22	0600AM	1.2	58	72	17.8	7.7	29	Yes	6516
06/28/22	0600AM	1.2	60	75	18.0	7.7	29	Yes	6355
06/29/22	0600AM	1.3	61	78	17.0	7.8	32	Yes	6086
06/30/22	0600AM	1.5	60	88	17.8	17.8	48	Yes	6104

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day