


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: July 2022

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.09	N/A	N/A	N/A	0.09
2	N/A	N/A	0.07	N/A	N/A	N/A	0.07
3	N/A	N/A	0.09	N/A	N/A	N/A	0.09
4	N/A	N/A	0.07	N/A	N/A	N/A	0.07
5	N/A	N/A	0.07	N/A	N/A	N/A	0.07
6	N/A	N/A	0.08	N/A	N/A	N/A	0.08
7	N/A	N/A	0.08	N/A	N/A	N/A	0.08
8	N/A	N/A	0.08	N/A	N/A	N/A	0.08
9	N/A	N/A	0.08	N/A	N/A	N/A	0.08
10	N/A	N/A	0.09	N/A	N/A	N/A	0.09
11	N/A	N/A	0.08	N/A	N/A	N/A	0.08
12	N/A	N/A	0.08	N/A	N/A	N/A	0.08
13	N/A	N/A	0.08	N/A	N/A	N/A	0.08
14	N/A	N/A	0.07	N/A	N/A	N/A	0.07
15	N/A	N/A	0.06	N/A	N/A	N/A	0.06
16	N/A	N/A	0.08	N/A	N/A	N/A	0.08
17	N/A	N/A	0.07	N/A	N/A	N/A	0.07
18	N/A	N/A	0.08	N/A	N/A	N/A	0.08
19	N/A	N/A	0.06	N/A	N/A	N/A	0.06
20	N/A	N/A	0.09	N/A	N/A	N/A	0.09
21	N/A	N/A	0.08	N/A	N/A	N/A	0.08
22	N/A	N/A	0.09	N/A	N/A	N/A	0.09
23	N/A	N/A	0.07	N/A	N/A	N/A	0.07
24	N/A	N/A	0.07	N/A	N/A	N/A	0.07
25	N/A	N/A	0.08	N/A	N/A	N/A	0.08
26	N/A	N/A	0.07	N/A	N/A	N/A	0.07
27	N/A	N/A	0.08	N/A	N/A	N/A	0.08
28	N/A	N/A	0.07	N/A	N/A	N/A	0.07
29	N/A	N/A	0.08	N/A	N/A	N/A	0.08
30	N/A	N/A	0.08	N/A	N/A	N/A	0.08
31	N/A	N/A	0.07	N/A	N/A	N/A	0.07

Slow Sand/Membrane/DE Filtration/ Unfiltered		Monthly Summary	
95% of daily turbidity readings \leq 1 NTU? YES All daily readings \leq 5 NTU? YES		CT's met everyday? (see back) YES	All CL2 residual at entry point \geq 0.2 mg/l? YES
Notes:		PRINTED NAME: Joe Rogers	
		SIGNATURE 	DATE 08/01/2022
		PHONE #: (503) 723-3505	CERT #: T-09162

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: July 2022

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
								Yes / No	
07/01/22	6:00 AM	1.3	63	84	18.2	8.0	32	Yes	5899
07/02/22	6:00 AM	1.3	63	81	17.9	8.0	32	Yes	5778
07/03/22	6:00 AM	1.3	66	88	17.0	7.8	32	Yes	5498
07/04/22	6:00 AM	1.3	64	83	17.0	7.8	32	Yes	5400
07/05/22	6:00 AM	1.4	73	102	18.0	7.9	31	Yes	4159
07/06/22	6:00 AM	1.3	68	89	17.8	7.9	31	Yes	4846
07/07/22	6:00 AM	1.4	83	118	17.5	7.9	32	Yes	3671
07/08/22	6:00 AM	1.4	60	81	18.1	8.1	33	Yes	5173
07/09/22	6:00 AM	1.5	67	98	18.8	8.0	31	Yes	5003
07/10/22	6:00 AM	1.4	63	87	18.5	8.1	32	Yes	5133
07/11/22	6:00 AM	1.3	66	84	18.9	7.9	29	Yes	4749
07/12/22	6:00 AM	1.4	62	86	17.9	7.8	30	Yes	5531
07/13/22	6:00 AM	1.3	65	81	20.1	7.6	25	Yes	5547
07/14/22	6:00 AM	1.4	62	88	19.5	7.6	26	Yes	6003
07/15/22	6:00 AM	1.3	61	78	18.5	7.8	29	Yes	6264
07/16/22	6:00 AM	1.3	60	76	20.2	7.6	24	Yes	6345
07/17/22	6:00 AM	1.3	58	75	19.2	7.7	27	Yes	5833
07/18/22	6:00 AM	1.3	66	87	18.1	7.9	31	Yes	4836
07/19/22	6:00 AM	1.2	61	74	19.5	7.9	28	Yes	5550
07/20/22	6:00 AM	1.3	62	79	20.6	7.7	25	Yes	5677
07/21/22	6:00 AM	1.4	46	63	21.1	7.6	23	Yes	7314
07/22/22	6:00 AM	1.3	61	81	22.1	7.6	21	Yes	6193
07/23/22	6:00 AM	1.4	59	85	19.9	7.8	27	Yes	6143
07/24/22	6:00 AM	1.2	61	75	19.1	7.8	28	Yes	5969
07/25/22	6:00 AM	1.4	59	84	21.1	7.7	24	Yes	6153
07/26/22	6:00 AM	1.3	59	76	21.8	7.6	22	Yes	6450
07/27/22	6:00 AM	1.2	58	68	22.4	7.6	21	Yes	6637
07/28/22	6:00 AM	1.1	59	66	22.5	7.6	20	Yes	6502
07/29/22	6:00 AM	1.2	58	70	22.6	7.7	21	Yes	6613
07/30/22	6:00 AM	1.2	59	70	22.1	7.5	21	Yes	6558
07/31/22	6:00 AM	1.2	58	69	22.5	7.7	21	Yes	6659

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day