


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B1 Month/Year: August 2022

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.09	N/A	N/A	N/A	0.09
2	N/A	N/A	0.11	N/A	N/A	N/A	0.11
3	N/A	N/A	0.10	N/A	N/A	N/A	0.10
4	N/A	N/A	0.10	N/A	N/A	N/A	0.10
5	N/A	N/A	0.08	N/A	N/A	N/A	0.08
6	N/A	N/A	0.09	N/A	N/A	N/A	0.09
7	N/A	N/A	0.09	N/A	N/A	N/A	0.09
8	N/A	N/A	0.09	N/A	N/A	N/A	0.09
9	N/A	N/A	0.08	N/A	N/A	N/A	0.08
10	N/A	N/A	0.10	N/A	N/A	N/A	0.10
11	N/A	N/A	0.10	N/A	N/A	N/A	0.10
12	N/A	N/A	0.09	N/A	N/A	N/A	0.09
13	N/A	N/A	0.09	N/A	N/A	N/A	0.09
14	N/A	N/A	0.09	N/A	N/A	N/A	0.09
15	N/A	N/A	0.10	N/A	N/A	N/A	0.10
16	N/A	N/A	0.09	N/A	N/A	N/A	0.09
17	N/A	N/A	0.09	N/A	N/A	N/A	0.09
18	N/A	N/A	0.13	N/A	N/A	N/A	0.13
19	N/A	N/A	0.09	N/A	N/A	N/A	0.09
20	N/A	N/A	0.08	N/A	N/A	N/A	0.08
21	N/A	N/A	0.09	N/A	N/A	N/A	0.09
22	N/A	N/A	0.09	N/A	N/A	N/A	0.09
23	N/A	N/A	0.09	N/A	N/A	N/A	0.09
24	N/A	N/A	0.08	N/A	N/A	N/A	0.08
25	N/A	N/A	0.08	N/A	N/A	N/A	0.08
26	N/A	N/A	0.10	N/A	N/A	N/A	0.10
27	N/A	N/A	0.09	N/A	N/A	N/A	0.09
28	N/A	N/A	0.09	N/A	N/A	N/A	0.09
29	N/A	N/A	0.10	N/A	N/A	N/A	0.10
30	N/A	N/A	0.09	N/A	N/A	N/A	0.09
31	N/A	N/A	0.15	N/A	N/A	N/A	0.15

Slow Sand/Membrane/DE Filtration/ Unfiltered		Monthly Summary	
95% of daily turbidity readings ≤ 1 NTU? YES		CT's met everyday? (see back) YES	All CL2 residual at entry point ≥ 0.2 mg/l? YES
All daily readings ≤ 5 NTU? YES		PRINTED NAME: Joe Rogers	
Notes:		SIGNATURE 	DATE 09/01/2022
		PHONE #: (503) 723-3505	CERT #: T-09162

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: August 2022

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
08/01/22	6:00 AM	1.2	52	62	22.7	7.7	21	Yes	6338
08/02/22	6:00 AM	1.2	62	74	21.5	8.0	25	Yes	5204
08/03/22	6:00 AM	1.3	57	71	22.6	7.7	21	Yes	6514
08/04/22	6:00 AM	1.3	58	74	22.2	7.8	23	Yes	6502
08/05/22	6:00 AM	1.2	60	70	21.0	7.8	24	Yes	6433
08/06/22	6:00 AM	1.3	60	78	20.8	7.7	24	Yes	6482
08/07/22	6:00 AM	1.1	60	69	21.4	7.6	22	Yes	6371
08/08/22	6:00 AM	1.2	59	71	22.2	7.5	20	Yes	6536
08/09/22	6:00 AM	1.2	59	73	21.4	7.7	23	Yes	6485
08/10/22	6:00 AM	1.2	59	73	21.4	7.7	23	Yes	6492
08/11/22	6:00 AM	1.2	59	72	20.0	7.6	25	Yes	6460
08/12/22	6:00 AM	1.2	60	73	21.1	7.7	24	Yes	6338
08/13/22	6:00 AM	1.2	60	70	20.1	7.8	26	Yes	6398
08/14/22	6:00 AM	1.2	52	65	20.9	7.8	25	Yes	6424
08/15/22	6:00 AM	1.2	64	79	21.1	7.8	24	Yes	4835
08/16/22	6:00 AM	1.2	60	74	21.4	7.7	23	Yes	5687
08/17/22	6:00 AM	1.3	62	78	21.2	7.6	23	Yes	6076
08/18/22	6:00 AM	1.3	55	72	21.5	7.6	22	Yes	6284
08/19/22	6:00 AM	1.2	71	83	19.9	7.8	26	Yes	4459
08/20/22	6:00 AM	1.3	63	82	21.0	7.8	25	Yes	5418
08/21/22	6:00 AM	1.3	58	73	20.2	7.7	25	Yes	5782
08/22/22	6:00 AM	1.2	66	81	21.0	7.8	25	Yes	4790
08/23/22	6:00 AM	1.3	62	80	21.1	7.5	22	Yes	5930
08/24/22	6:00 AM	1.2	60	73	21.2	7.5	22	Yes	6249
08/25/22	6:00 AM	1.2	60	69	21.6	7.5	21	Yes	6203
08/26/22	6:00 AM	1.2	60	71	21.7	7.5	21	Yes	6332
08/27/22	6:00 AM	1.2	60	72	20.8	7.5	23	Yes	6380
08/28/22	6:00 AM	1.2	60	70	19.0	7.6	26	Yes	6355
08/29/22	6:00 AM	1.2	61	71	19.8	7.6	25	Yes	6263
08/30/22	6:00 AM	1.2	61	74	20.9	7.6	23	Yes	6207
08/31/22	6:00 AM	1.2	62	74	21.2	7.5	22	Yes	5989

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day