


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B1 Month/Year: September 2022

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.11	N/A	N/A	N/A	0.11
2	N/A	N/A	0.10	N/A	N/A	N/A	0.10
3	N/A	N/A	0.10	N/A	N/A	N/A	0.10
4	N/A	N/A	0.08	N/A	N/A	N/A	0.08
5	N/A	N/A	0.08	N/A	N/A	N/A	0.08
6	N/A	N/A	0.07	N/A	N/A	N/A	0.07
7	N/A	N/A	0.07	N/A	N/A	N/A	0.07
8	N/A	N/A	0.09	N/A	N/A	N/A	0.09
9	N/A	N/A	0.09	N/A	N/A	N/A	0.09
10	N/A	N/A	0.07	N/A	N/A	N/A	0.07
11	N/A	N/A	0.07	N/A	N/A	N/A	0.07
12	N/A	N/A	0.08	N/A	N/A	N/A	0.08
13	N/A	N/A	0.07	N/A	N/A	N/A	0.07
14	N/A	N/A	0.11	N/A	N/A	N/A	0.11
15	N/A	N/A	0.09	N/A	N/A	N/A	0.09
16	N/A	N/A	0.08	N/A	N/A	N/A	0.08
17	N/A	N/A	0.10	N/A	N/A	N/A	0.10
18	N/A	N/A	0.13	N/A	N/A	N/A	0.13
19	N/A	N/A	0.08	N/A	N/A	N/A	0.08
20	N/A	N/A	0.08	N/A	N/A	N/A	0.08
21	N/A	N/A	0.08	N/A	N/A	N/A	0.08
22	N/A	N/A	0.09	N/A	N/A	N/A	0.09
23	N/A	N/A	0.08	N/A	N/A	N/A	0.08
24	N/A	N/A	0.09	N/A	N/A	N/A	0.09
25	N/A	N/A	0.08	N/A	N/A	N/A	0.08
26	N/A	N/A	0.09	N/A	N/A	N/A	0.09
27	N/A	N/A	0.08	N/A	N/A	N/A	0.08
28	N/A	N/A	0.08	N/A	N/A	N/A	0.08
29	N/A	N/A	0.08	N/A	N/A	N/A	0.08
30	N/A	N/A	0.07	N/A	N/A	N/A	0.07

Slow Sand/Membrane/DE Filtration/ Unfiltered		Monthly Summary	
95% of daily turbidity readings ≤ 1 NTU? YES		CT's met everyday? (see back) YES	All CL2 residual at entry point ≥ 0.2 mg/l? YES
All daily readings ≤ 5 NTU? YES		PRINTED NAME: Joe Rogers	
Notes:		SIGNATURE 	DATE 10/01/2022
		PHONE #: (503) 723-3505	CERT #: T-09162

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: **September 2022**

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
09/01/22	6:00 AM	1.2	60	74	21.1	7.8	24	Yes	6219
09/02/22	6:00 AM	1.3	63	78	20.8	8.1	28	Yes	5959
09/03/22	6:00 AM	1.2	60	73	20.2	7.8	26	Yes	6139
09/04/22	6:00 AM	1.2	62	71	19.1	8.0	30	Yes	5968
09/05/22	6:00 AM	1.2	62	74	19.8	7.9	28	Yes	5546
09/06/22	6:00 AM	1.2	66	76	19.5	7.8	27	Yes	4714
09/07/22	6:00 AM	1.2	61	75	19.5	7.7	26	Yes	5597
09/08/22	6:00 AM	1.3	52	66	19.2	7.7	27	Yes	6184
09/09/22	6:00 AM	1.3	60	75	18.5	7.7	28	Yes	6107
09/10/22	6:00 AM	1.2	61	73	18.2	7.8	29	Yes	5976
09/11/22	6:00 AM	1.2	61	74	17.9	7.9	31	Yes	6011
09/12/22	6:00 AM	1.2	58	69	18.0	7.8	30	Yes	5694
09/13/22	6:00 AM	1.2	75	87	17.9	7.7	29	Yes	4044
09/14/22	6:00 AM	1.2	65	80	17.6	7.6	28	Yes	5196
09/15/22	6:00 AM	1.3	67	84	17.5	7.8	31	Yes	5387
09/16/22	6:00 AM	1.2	52	63	17.5	7.9	32	Yes	6803
09/17/22	6:00 AM	1.2	69	82	16.8	7.9	33	Yes	5347
09/18/22	6:00 AM	1.2	70	82	16.4	7.8	32	Yes	5357
09/19/22	6:00 AM	1.2	61	73	16.8	7.5	28	Yes	5318
09/20/22	6:00 AM	1.3	70	90	17.1	7.8	31	Yes	4495
09/21/22	6:00 AM	1.3	63	80	17.0	7.8	32	Yes	5494
09/22/22	6:00 AM	1.2	61	74	16.4	7.5	28	Yes	5852
09/23/22	6:00 AM	1.4	58	81	16.3	7.8	33	Yes	5376
09/24/22	6:00 AM	1.2	66	81	16.0	7.8	33	Yes	5402
09/25/22	6:00 AM	1.3	73	91	16.2	8.0	36	Yes	4693
09/26/22	6:00 AM	1.2	71	85	16.4	7.8	32	Yes	4803
09/27/22	6:00 AM	1.3	71	90	16.6	7.9	34	Yes	4764
09/28/22	6:00 AM	1.1	76	83	16.6	7.8	32	Yes	4217
09/29/22	6:00 AM	1.3	64	83	16.2	7.7	32	Yes	5157
09/30/22	6:00 AM	1.3	65	83	15.8	7.8	34	Yes	5231

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day