


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: October 2022

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.07	N/A	N/A	N/A	0.07
2	N/A	N/A	0.09	N/A	N/A	N/A	0.09
3	N/A	N/A	0.09	N/A	N/A	N/A	0.09
4	N/A	N/A	0.08	N/A	N/A	N/A	0.08
5	N/A	N/A	0.10	N/A	N/A	N/A	0.10
6	N/A	N/A	0.11	N/A	N/A	N/A	0.11
7	N/A	N/A	0.09	N/A	N/A	N/A	0.09
8	N/A	N/A	0.09	N/A	N/A	N/A	0.09
9	N/A	N/A	0.09	N/A	N/A	N/A	0.09
10	N/A	N/A	0.08	N/A	N/A	N/A	0.08
11	N/A	N/A	0.08	N/A	N/A	N/A	0.08
12	N/A	N/A	0.11	N/A	N/A	N/A	0.11
13	N/A	N/A	0.11	N/A	N/A	N/A	0.11
14	N/A	N/A	0.09	N/A	N/A	N/A	0.09
15	N/A	N/A	0.09	N/A	N/A	N/A	0.09
16	N/A	N/A	0.08	N/A	N/A	N/A	0.08
17	N/A	N/A	0.10	N/A	N/A	N/A	0.10
18	N/A	N/A	0.08	N/A	N/A	N/A	0.08
19	N/A	N/A	0.07	N/A	N/A	N/A	0.07
20	N/A	N/A	0.11	N/A	N/A	N/A	0.11
21	N/A	N/A	0.08	N/A	N/A	N/A	0.08
22	N/A	N/A	0.08	N/A	N/A	N/A	0.08
23	N/A	N/A	0.09	N/A	N/A	N/A	0.09
24	N/A	N/A	0.08	N/A	N/A	N/A	0.08
25	N/A	N/A	0.08	N/A	N/A	N/A	0.08
26	N/A	N/A	0.09	N/A	N/A	N/A	0.09
27	N/A	N/A	0.10	N/A	N/A	N/A	0.10
28	N/A	N/A	0.10	N/A	N/A	N/A	0.10
29	N/A	N/A	0.13	N/A	N/A	N/A	0.13
30	N/A	N/A	0.09	N/A	N/A	N/A	0.09
31	N/A	N/A	0.08	N/A	N/A	N/A	0.08

Slow Sand/Membrane/DE Filtration/ Unfiltered	Monthly Summary	
95% of daily turbidity readings \leq 1 NTU? YES	CT's met everyday? (see back) YES	All CL2 residual at entry point \geq 0.2 mg/l? YES
All daily readings \leq 5 NTU? YES	PRINTED NAME: Joe Rogers	
Notes:	SIGNATURE 	DATE 11/01/2022
	PHONE #: (503) -723-3505	CERT #: T-09162

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: October 2022

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
								Yes / No	
10/01/22	6:00 AM	1.2	69	84	15.9	8.0	36	Yes	5018
10/02/22	6:00 AM	1.3	66	85	16.3	8.0	35	Yes	5023
10/03/22	6:00 AM	1.2	74	89	16.5	7.7	31	Yes	4164
10/04/22	6:00 AM	1.3	66	86	16.2	7.6	31	Yes	5110
10/05/22	6:00 AM	1.3	71	92	15.2	7.6	32	Yes	4645
10/06/22	6:00 AM	1.3	70	91	14.8	7.7	34	Yes	4839
10/07/22	6:00 AM	1.3	72	94	15.6	7.8	34	Yes	4844
10/08/22	6:00 AM	1.3	69	90	15.5	7.7	33	Yes	4931
10/09/22	6:00 AM	1.4	66	92	15.5	7.7	34	Yes	4972
10/10/22	6:00 AM	1.3	72	94	15.4	7.9	36	Yes	4051
10/11/22	6:00 AM	1.4	71	100	15.4	7.7	34	Yes	4461
10/12/22	6:00 AM	1.2	71	85	15.2	7.6	31	Yes	4773
10/13/22	6:00 AM	1.3	71	92	14.8	7.8	36	Yes	4790
10/14/22	6:00 AM	1.2	71	84	14.8	7.9	37	Yes	4844
10/15/22	6:00 AM	1.4	70	97	14.2	8.0	41	Yes	4889
10/16/22	6:00 AM	1.3	68	88	14.4	8.0	40	Yes	5199
10/17/22	6:00 AM	1.2	86	104	14.9	7.8	35	Yes	3641
10/18/22	6:00 AM	1.3	85	110	14.1	8.0	41	Yes	3546
10/19/22	6:00 AM	1.5	73	109	14.0	7.9	40	Yes	4520
10/20/22	6:00 AM	1.5	66	100	13.8	7.7	38	Yes	5066
10/21/22	6:00 AM	1.2	65	78	13.1	7.8	41	Yes	5406
10/22/22	6:00 AM	1.3	55	72	12.3	7.8	44	Yes	5261
10/23/22	6:00 AM	1.6	77	123	12.2	8.1	51	Yes	4087
10/24/22	6:00 AM	1.3	70	91	12.1	7.7	43	Yes	4544
10/25/22	6:00 AM	1.3	85	111	11.6	8.0	50	Yes	3531
10/26/22	6:00 AM	1.3	74	96	11.1	7.8	48	Yes	4352
10/27/22	6:00 AM	1.2	94	113	10.8	7.8	49	Yes	3471
10/28/22	6:00 AM	1.2	80	96	11.1	7.8	48	Yes	4010
10/29/22	6:00 AM	1.2	85	102	10.7	7.8	50	Yes	3505
10/30/22	6:00 AM	1.2	92	110	11.3	7.8	48	Yes	3478
10/31/22	6:00AM	1.3	82	107	11.5	7.9	49	Yes	3513

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day