


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: November 2022								
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]	
1	N/A	N/A	0.09	N/A	N/A	N/A	0.09	
2	N/A	N/A	0.17	N/A	N/A	N/A	0.17	
3	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
4	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
5	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
6	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
7	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
8	N/A	N/A	0.10	N/A	N/A	N/A	0.10	
9	N/A	N/A	0.17	N/A	N/A	N/A	0.17	
10	N/A	N/A	0.42	N/A	N/A	N/A	0.42	
11	N/A	N/A	0.33	N/A	N/A	N/A	0.33	
12	N/A	N/A	0.33	N/A	N/A	N/A	0.33	
13	N/A	N/A	0.31	N/A	N/A	N/A	0.31	
14	N/A	N/A	0.30	N/A	N/A	N/A	0.30	
15	N/A	N/A	0.24	N/A	N/A	N/A	0.24	
16	N/A	N/A	0.26	N/A	N/A	N/A	0.26	
17	N/A	N/A	0.22	N/A	N/A	N/A	0.22	
18	N/A	N/A	0.23	N/A	N/A	N/A	0.23	
19	N/A	N/A	0.15	N/A	N/A	N/A	0.15	
20	N/A	N/A	0.12	N/A	N/A	N/A	0.12	
21	N/A	N/A	0.10	N/A	N/A	N/A	0.10	
22	N/A	N/A	0.10	N/A	N/A	N/A	0.10	
23	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
24	N/A	N/A	0.12	N/A	N/A	N/A	0.12	
25	N/A	N/A	0.12	N/A	N/A	N/A	0.12	
26	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
27	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
28	N/A	N/A	0.09	N/A	N/A	N/A	0.09	
29	N/A	N/A	0.13	N/A	N/A	N/A	0.13	
30	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary				
95% of daily turbidity readings ≤ 1 NTU? YES All daily readings ≤ 5 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point ≥ 0.2 mg/l? YES		
Notes:				PRINTED NAME: Joe Rogers				
				SIGNATURE 			DATE 12/01/2022	
				PHONE #: (503) -723-3505			CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:- WTP-B1 Month/Year: November 2022

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
11/01/22	6:00 AM	1.3	89	112	11.1	7.7	46	Yes	3367
11/02/22	6:00 AM	1.2	83	99	10.2	7.6	47	Yes	3865
11/03/22	6:00 AM	1.4	92	132	9.6	7.8	54	Yes	3554
11/04/22	6:00 AM	1.5	90	131	9.5	8.0	59	Yes	3617
11/05/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/06/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/07/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/08/22	6:00 AM	1.5	155	231	9.2	8.0	60	Yes	1888
11/09/22	6:00 AM	1.4	79	114	8.4	8.1	65	Yes	3688
11/10/22	6:00 AM	1.7	97	165	7.4	7.7	62	Yes	3285
11/11/22	6:00 AM	1.7	95	161	7.2	7.7	63	Yes	3361
11/12/22	6:00 AM	1.5	87	131	7.2	7.6	58	Yes	3648
11/13/22	6:00 AM	1.5	108	161	6.8	7.8	65	Yes	2925
11/14/22	6:00 AM	1.5	85	128	6.5	7.5	58	Yes	3659
11/15/22	6:00 AM	1.6	98	156	6.2	8.0	73	Yes	3150
11/16/22	6:00 AM	1.6	92	147	6.1	7.7	66	Yes	3427
11/17/22	6:00 AM	1.5	86	129	5.8	7.8	68	Yes	3915
11/18/22	6:00 AM	1.6	86	138	5.2	7.9	74	Yes	3915
11/19/22	6:00 AM	1.7	86	147	4.8	7.9	78	Yes	3903
11/20/22	6:00 AM	1.6	91	145	4.8	8.0	79	Yes	3309
11/21/22	6:00 AM	1.6	100	160	4.5	8.0	82	Yes	3177
11/22/22	6:00 AM	1.6	96	153	5.0	7.9	75	Yes	3372
11/23/22	6:00 AM	1.7	98	166	5.8	7.9	73	Yes	3303
11/24/22	6:00 AM	1.5	98	146	5.9	7.9	71	Yes	3336
11/25/22	6:00 AM	1.5	97	146	5.9	8.0	73	Yes	3311
11/26/22	6:00 AM	1.7	92	157	5.1	8.0	79	Yes	3483
11/27/22	6:00 AM	1.7	88	149	5.6	8.0	77	Yes	3550
11/28/22	6:00 AM	1.4	97	136	5.9	7.9	70	Yes	3207
11/29/22	6:00 AM	1.5	87	131	5.9	7.9	71	Yes	3699
11/30/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day