


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: December 2022							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.13	N/A	N/A	N/A	0.13
2	N/A	N/A	0.32	N/A	N/A	N/A	0.32
3	N/A	N/A	0.52	N/A	N/A	N/A	0.52
4	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
5	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
6	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
7	N/A	N/A	0.33	N/A	N/A	N/A	0.33
8	N/A	N/A	0.33	N/A	N/A	N/A	0.33
9	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
10	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
11	N/A	N/A	0.22	N/A	N/A	N/A	0.22
12	N/A	N/A	0.23	N/A	N/A	N/A	0.23
13	N/A	N/A	0.46	N/A	N/A	N/A	0.46
14	N/A	N/A	0.41	N/A	N/A	N/A	0.41
15	N/A	N/A	0.34	N/A	N/A	N/A	0.34
16	N/A	N/A	0.31	N/A	N/A	N/A	0.31
17	N/A	N/A	0.35	N/A	N/A	N/A	0.35
18	N/A	N/A	0.35	N/A	N/A	N/A	0.35
19	N/A	N/A	0.29	N/A	N/A	N/A	0.29
20	N/A	N/A	0.25	N/A	N/A	N/A	0.25
21	N/A	N/A	0.26	N/A	N/A	N/A	0.26
22	N/A	N/A	0.27	N/A	N/A	N/A	0.27
23	N/A	N/A	0.33	N/A	N/A	N/A	0.33
24	N/A	N/A	0.32	N/A	N/A	N/A	0.32
25	N/A	N/A	0.39	N/A	N/A	N/A	0.39
26	N/A	N/A	0.31	N/A	N/A	N/A	0.31
27	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
28	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
29	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
30	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
31	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
<b>Slow Sand/Membrane/DE Filtration/ Unfiltered</b>				<b>Monthly Summary</b>			
95% of daily turbidity readings ≤ 1 NTU? <b>YES</b>				CT's met everyday? (see back) <b>YES</b>		All CL2 residual at entry point ≥ 0.2 mg/l? <b>YES</b>	
All daily readings ≤ 5 NTU? <b>YES</b>				PRINTED NAME: Joe Rogers			
Notes:				SIGNATURE 		DATE 1/01/2023	
				PHONE #: (503) 723-3505		CERT #: T-09162	

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: December 2022**

**SLOW SAND FILTERS**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT (C x T)	Temp (°C)	pH	Required CT (Use Tables)	CT Met?*(Yes / No)	Peak Hourly Demand Flow (gpm)
12/01/22	6:00 AM	1.5	85	130	5.6	8.0	75	Yes	3500
12/02/22	6:00 AM	1.6	89	138	5.6	7.9	72	Yes	3710
12/03/22	6:00 AM	1.4	117	160	5.8	8.1	76	Yes	2702
12/04/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/05/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/06/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/07/22	6:00 AM	1.1	174	191	5.3	8.0	72	Yes	1730
12/08/22	6:00 AM	1.4	327	458	5.2	8.3	85	Yes	885
12/09/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/10/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/11/22	6:00 AM	1.5	225	342	5.4	8.2	82	Yes	1335
12/12/22	6:00 AM	1.6	89	145	5.6	7.7	68	Yes	3366
12/13/22	6:00 AM	1.5	94	142	6.1	7.8	67	Yes	3466
12/14/22	6:00 AM	1.5	113	167	6.1	7.9	70	Yes	2711
12/15/22	6:00 AM	1.6	116	183	5.6	7.8	70	Yes	2644
12/16/22	6:00 AM	1.5	128	187	4.9	7.8	72	Yes	2402
12/17/22	6:00 AM	1.4	133	192	4.6	8.0	79	Yes	2311
12/18/22	6:00 AM	1.5	131	196	4.5	8.0	80	Yes	2317
12/19/22	6:00 AM	1.5	159	243	5.0	8.0	77	Yes	1914
12/20/22	6:00 AM	1.6	154	241	5.0	8.0	78	Yes	1932
12/21/22	6:00 AM	1.6	149	239	5.7	8.0	75	Yes	2036
12/22/22	6:00 AM	1.6	126	200	4.8	7.9	76	Yes	2393
12/23/22	6:00 AM	1.4	129	183	2.6	7.9	90	Yes	2418
12/24/22	6:00 AM	1.4	151	207	2.9	7.9	87	Yes	2011
12/25/22	6:00 AM	1.2	156	182	3.4	7.9	82	Yes	1976
12/26/22	6:00 AM	1.3	206	266	3.8	8.2	90	Yes	1386
12/27/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/28/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/29/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/30/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/31/22	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day